

INTERNATIONAL ELECTROTECHNICAL COMMISSION

IEC TR 62271-305
Edition 1.0 2009-11

High-voltage switchgear and controlgear –

**Part 305: Capacitive current switching capability of air-insulated
Disconnectors for rated voltages above 52 kV**

CORRIGENDUM 1

5.6 Test circuit

Replace the existing second paragraph after Figure 1 by the following new paragraph:

For each test current, the ratio C_S/C_L should be agreed between the manufacturer and the user.

*(<https://standards.iteh.ai>)
Document Preview*

[IEC TR 62271-305:2009/COR1:2017](https://standards.iteh.ai/catalog/standards/iec/59e6ca5f-5146-4d8a-bcc8-1e77b24d0b99/iec-tr-62271-305-2009-cor1-2017)

<https://standards.iteh.ai/catalog/standards/iec/59e6ca5f-5146-4d8a-bcc8-1e77b24d0b99/iec-tr-62271-305-2009-cor1-2017>