

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Field device integration (FDI) –
Part 109-1: Profiles – HART® and WirelessHART®**
(standards.iteh.ai)

**Intégration des appareils de terrain (FDI) –
Partie 109-1: Profils – HART® et WirelessHART®**
<https://standards.iteh.ai/catalog/standards/sist/c51a8667-2deb-4d86-a44b-a893b499068e/iec-62769-109-1-2020>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2020 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22.000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67.000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22.000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

67.000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.



INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Field device integration (FDI) –
Part 109-1: Profiles – HART® and WirelessHART®**
(standards.iteh.ai)

**Intégration des appareils de terrain (FDI) –
Partie 109-1: Profils – HART® et WirelessHART®**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.040.40; 35.100.05

ISBN 978-2-8322-8140-6

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD	4
1 Scope	6
2 Normative references	6
3 Terms, definitions, abbreviated terms and conventions	6
3.1 Terms and definitions	6
3.2 Abbreviated terms and acronyms	6
3.3 Conventions	7
3.3.1 EDDL syntax	7
3.3.2 XML syntax	7
3.3.3 Capitalizations	7
4 Profile for CP 9/1 (HART®) or CP 9/2 (WirelessHART®)	8
4.1 General	8
4.2 Catalog profile	8
4.2.1 Protocol support file	8
4.2.2 CommunicationProfile definition	8
4.2.3 Profile device	9
4.2.4 Protocol version information	9
4.3 Associating a Package with a CP 9/1 device	9
4.3.1 Device type identification mapping	9
4.3.2 Device type revision mapping	10
4.4 Information Model mapping	10
4.4.1 ProtocolType definition	10
4.4.2 DeviceType mapping	10
4.4.3 FunctionalGroup Identification definition	11
4.5 Topology elements	11
4.5.1 ConnectionPoint definition	11
4.5.2 Communication Device definition	17
4.5.3 Communication service provider definition	18
4.5.4 Network definition	18
4.6 Methods	19
4.6.1 Methods for FDI Communication Servers	19
4.6.2 Methods for Gateways	23
Annex A (normative) Topology scan schema	31
A.1 General	31
A.2 IdentificationType	31
A.3 AddressTypeTP	33
A.4 AddressTypeIP	33
A.5 AddressTypeTDMA	34
A.6 AddressType	34
A.7 ConnectionPointType	35
A.8 NetworkType	36
A.9 Network	36
Annex B (normative) Transfer service parameters	37
B.1 General	37
B.2 receiveData	37
B.3 sendData	37

B.4	TransferResultDataT.....	37
B.5	TransferSendDataT.....	38
	Bibliography.....	39
Table 1	– Device Information Files.....	8
Table 2	– CommunicationProfile definition.....	8
Table 3	– Catalog values for profile devices.....	9
Table 4	– Protocol Version Information.....	9
Table 5	– Device type catalog mapping.....	9
Table 6	– ProtocolType HART definition.....	10
Table 7	– Inherited DeviceType Property mapping.....	10
Table 8	– Identification parameters.....	11
Table 9	– ConnectionPointType HART_TP definition.....	12
Table 10	– ConnectionPointType HART_IP Definition.....	14
Table 11	– ConnectionPointType HART_TDMA Definition.....	16
Table 12	– Method Connect arguments.....	20
Table 13	– Method Disconnect arguments.....	20
Table 14	– Method Transfer arguments.....	21
Table 15	– Method GetPublishedData arguments.....	22
Table 16	– Method SetAddress arguments.....	23
Table 17	– Method Connect arguments.....	24
Table 18	– Method Disconnect arguments.....	25
Table 19	– Method Transfer arguments.....	26
Table 20	– Method GetPublishedData arguments.....	27
Table 21	– Method SetAddress arguments.....	28
Table A.1	– Attributes of IdentificationT.....	32
Table A.2	– Elements of AddressTypeTP.....	33
Table A.3	– Elements of AddressTypeIP.....	34
Table A.4	– Elements of AddressTypeTDMA.....	34
Table A.5	– Elements of AddressT.....	35
Table A.6	– Elements of ConnectionPointT.....	35
Table A.7	– Elements of NetworkT.....	36
Table B.1	– Attributes of TransferResultDataT.....	37
Table B.2	– Attributes of TransferSendDataT.....	38

INTERNATIONAL ELECTROTECHNICAL COMMISSION

FIELD DEVICE INTEGRATION (FDI) –

Part 109-1: Profiles – HART® and WirelessHART®

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62769-109-1 has been prepared by subcommittee 65E: Devices and integration in enterprise systems, of IEC technical committee 65: Industrial-process measurement, control and automation.

This second edition cancels and replaces the first edition published in 2015. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) support for generic protocol extension for faster adoption of other technologies;
- b) support for Package Developers to build EDDs targeted for today's EDD bases system under a single development tool.

The text of this International Standard is based on the following documents:

CDV	Report on voting
65E/624/CDV	65E/687A/RVC

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62769 series, published under the general title *Field Device Integration (FDI)*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[IEC 62769-109-1:2020](#)

<https://standards.iteh.ai/catalog/standards/sist/e3fa8867-2deb-4d86-a44b-a893b499068e/iec-62769-109-1-2020>

FIELD DEVICE INTEGRATION (FDI) –

Part 109-1: Profiles – HART® and WirelessHART®

1 Scope

This part of IEC 62769 specifies an FDI profile of IEC 62769 for IEC 61784-1_CP 9/1 (HART®)¹ and IEC 61784-1_CP 9/2 (WirelessHART®)¹.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 62541-100:2015, *OPC Unified Architecture Specification – Part 100: Device Interface*

IEC 62769-4:–², *Field device integration (FDI) – Part 4: FDI Packages*

IEC 62769-5, *Field device integration (FDI) – Part 5: FDI Information Model*

IEC 62769-7, *Field device integration (FDI) – Part 7: FDI Communication Devices*

<https://standards.iteh.ai/catalog/standards/sist/e3fa8867-2deb-4d86-a44b->

<https://standards.iteh.ai/catalog/standards/sist/e3fa8867-2deb-4d86-a44b->

3 Terms, definitions, abbreviated terms and conventions

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 62541-100, IEC 62769-4, IEC 62769-5 and IEC 62769-7 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.2 Abbreviated terms and acronyms

For the purposes of this document, the following abbreviations apply:

CP	Communication profile (see IEC 61784-1 or IEC 61784-2)
CPF	Communication profile family (see IEC 61784-1 or IEC 61784-2)
EDD	Electronic device description (see IEC 61804)
EDDL	Electronic device description language (see IEC 61804)

¹ HART® and wirelessHART® are the registered trademark of FieldComm Group. This information is given for the convenience of users of this document and does not constitute an endorsement by IEC of the product named. Equivalent products may be used if they can be shown to lead to the same results.

² Under preparation. Stage at the time of publication: IEC/RFDIS 62769-4:2020.

FDI	Field device integration
FSK	Frequency-Shift-Keying
HCF	HART Communication Foundation
ID	Identification
IM	Information Model
IP	Internet protocol
PDU	Protocol data unit
PSK	Phase-Shift-Keying
TCP	Transmission Control Protocol (see IETF RFC 793)
UDP	User Datagram Protocol (see IETF RFC 768)
XML	Extensible markup language

3.3 Conventions

3.3.1 EDDL syntax

This document specifies content for the EDD component that is part of FDI Communication Packages. EDDL syntax uses the font Courier New. EDDL syntax is used for method signature, variable, data structure and component declarations.

3.3.2 XML syntax

XML syntax examples use font Courier New. The XML syntax is used to describe XML document schema.

EXAMPLE `<xs:simpleType name="Example1">1:2020`

3.3.3 Capitalizations

The IEC 62769 series uses capitalized terms to emphasize that these terms have an FDI specific meaning.

Some of these terms using an acronym as a prefix, for example

- FDI Client or
- FDI Server.

Some of these terms are compound terms such as:

- FDI Communication Servers or
- Profile Package.

Parameter names or attributes are concatenated to a single term, where the original terms start in this term with a capital letter such as:

- ProtocolSupportFile or
- ProtocolType.

Parameter names or attributes can also be constructed by using an underscore character to concatenate two or more terms like:

- PROFILE_ID or
- HART_Network.

4 Profile for CP 9/1 (HART®) or CP 9/2 (WirelessHART®)

4.1 General

This profile document to the FDI specification in IEC 62769 selects the protocol specifics needed for FDI Packages describing FDI Communication Servers, gateways and devices.

4.2 Catalog profile

4.2.1 Protocol support file

Device information files provide metadata for the dynamic runtime data that is supplied by the device. This metadata is a subset of information that is contained in the EDD. The device information files may be extracted from the package by light-weight gateway or server implementations to exchange runtime device information with minimal implementation overhead. Device information files do not replace the need for the EDD part because device information files only contain a subset of the information from the EDD, and do not provide any user-interface elements.

The formats of the Device Information Files are described in Table 1.

Table 1 – Device Information Files

Part	Content
Content Type	Not specified here
Root Namespace	Not specified here
Source Relationship	http://fdi-cooperation.com/2010/relationships/attachment-protocol
Filename	Not specified here

The Device Information Files are specified in FCG AG21073.

4.2.2 CommunicationProfile definition

IEC 62769-4 defines a CommunicationProfileT string type for the Catalog XML schema. Table 2 defines the CP 9/1 specific values for this enumeration.

Table 2 – CommunicationProfile definition

CommunicationProfile	Description
hart_fsk	CP 9/1 device type that supports an FSK physical layer (Frequency-Shift-Keying on a pair of wires)
hart_psk	CP 9/1 device type that supports a PSK physical layer (Phase-Shift-Keying on a pair of wires). Devices supporting PSK are required to also inherently support FSK, and therefore PSK will always be used only in combination with at least FSK.
hart_wirelesshart	CP 9/2 device type that supports a wireless physical layer (communication between device and gateway).
hart_ip	CP 9/1 device type that supports Internet Protocol (these devices support both TCP and UDP).
hart_rs485	CP 9/1 device type that supports EIA-485 digital communication.
hart_ir	CP 9/1 device type that supports an Infrared physical layer (designed to be transparent to FSK masters – included only as information to indicate that the device supports IR connection).
NOTE It is possible for a single CP 9/1 device to support more than one CP.	

4.2.3 Profile device

A Profile Package shall provide the catalog values for profile devices, enabling the FDI Server to leverage a generic device description, if a specific one is not available. The definitions in Table 3 focus on catalog content that is vendor independent.

Table 3 – Catalog values for profile devices

Element	Attribute	Content
PackageType	—	Profile
DeviceModel	—	Empty
Manufacturer	—	Empty

4.2.4 Protocol version information

IEC 62769-4 defines an element type named InterfaceT for the Catalog XML Schema. Element type InterfaceT contains an element named Version which is supposed to provide version information about the applied communication protocol profile. The value has to follow the IEC 62769-4 defined version information schema defined in element type VersionT. Subclause 4.2.4 describes how to apply the currently known protocol versions for CP 9/1 or CP 9/2 entries in the device catalog. The general rule is to use the Universal Revision of the protocol for the major version part of VersionT, and the value "0" for the minor version and build parts. Table 4 shows the Protocol Version Information.

Table 4 – Protocol Version Information

Protocol Version	InterfaceT Version value
HART Universal Revision 5	5.0.0
HART Universal Revision 6	6.0.0
HART Universal Revision 7	7.0.0
The Protocol Version defined in a package is provided for informational purposes only and shall not be used to determine the compatibility or applicability of a package to a device.	

4.3 Associating a Package with a CP 9/1 device

4.3.1 Device type identification mapping

CP 9/1 device types are uniquely identified by parameters Manufacturer, Model and DeviceRevision. These parameters are used to associate a given device instance to an FDI Device Package. These parameters are mapped to the FDI Device Package Catalog according to Table 5.

Table 5 – Device type catalog mapping

Catalog element	CP mapping (See Table A.)
Manufacturer element of InterfaceT (IEC 62769-4:–, Clause E.10)	Manufacturer String format "0xddd" where dddd is the MANUFACTURER_ID in hexadecimal format.
DeviceModel element of InterfaceT (IEC 62769-4:–, Clause E.10)	Model String format "0xddd" where dddd is the DEVICE_TYPE in hexadecimal format.

Catalog element	CP mapping (See Table A.)
DeviceRevision element ListOfSupportedDeviceRevisionsT (IEC 62769-4:–, Clause E.20)	DeviceRevision String format "x.0.0" where x is the DEVICE_REVISION in decimal format (no leading zeros).

4.3.2 Device type revision mapping

Each device type is identified as per 4.3.1. If a package with matching DeviceRevision is not available, any CP 9/1 FDI package for a corresponding manufacturer and model shall always be compatible with a field device as long as the device revision of the field device is equal to or greater than the device revision specified in the FDI package.

4.4 Information Model mapping

4.4.1 ProtocolType definition

Table 6 defines the ProtocolType used to identify CP 9/1 network communications.

Table 6 – ProtocolType HART definition

Attribute	Value										
BrowseName	HART										
IsAbstract	False										
References	<table border="1"> <thead> <tr> <th>NodeClass</th> <th>BrowseName</th> <th>Data Type</th> <th>TypeDefinition</th> <th>ModellingRule</th> </tr> </thead> <tbody> <tr> <td colspan="5">Inherits the properties of ProtocolType defined in IEC 62541-100.</td> </tr> </tbody> </table>	NodeClass	BrowseName	Data Type	TypeDefinition	ModellingRule	Inherits the properties of ProtocolType defined in IEC 62541-100.				
NodeClass	BrowseName	Data Type	TypeDefinition	ModellingRule							
Inherits the properties of ProtocolType defined in IEC 62541-100.											

[IEC 62769-109-1:2020](https://standards.iteh.ai/catalog/standards/sist/e3fa8867-2deb-4d86-a44b-a893b499068e/iec-62769-109-1-2020)

[https://standards.iteh.ai/catalog/standards/sist/e3fa8867-2deb-4d86-a44b-](https://standards.iteh.ai/catalog/standards/sist/e3fa8867-2deb-4d86-a44b-a893b499068e/iec-62769-109-1-2020)

4.4.2 DeviceType mapping

Each device type inherits the properties of DeviceType. The mapping of the inherited properties from DeviceType is defined in Table 7.

Table 7 – Inherited DeviceType Property mapping

Property	Foundation mapping
SerialNumber	Unique ID of a device, mapped to SERIAL_NUMBER of IdentificationT.
RevisionCounter	Configuration change counter, mapped to REV_COUNTER of IdentificationT
Manufacturer	String taken from FDI package catalog (ManufacturerName from PackageT)
Model	String taken from FDI package catalog (Name of DeviceTypeT, which is a localized name)
DeviceManual	Entry text string (not supported) ^a
DeviceRevision	Device revision level of a device, mapped to DEVICE_REVISION of IdentificationT
SoftwareRevision	Software revision level of a device, mapped to SOFTWARE_REVISION of IdentificationT
HardwareRevision	Hardware revision level of a device, mapped to HARDWARE_REVISION of IdentificationT
^a Device manuals are exposed as attachments of the FDI Device Package.	

4.4.3 FunctionalGroup Identification definition

As defined in IEC 62541-100, each device representation in the FDI Server hosted Information Model shall contain a protocol specific FunctionalGroup called Identification. This FunctionalGroup organizes variables found in the device type instance. The FunctionalGroup Identification for CP 9/1 is defined in Table 8.

Table 8 – Identification parameters

BrowseName	Data Type	Optional/Mandatory
MANUFACTURER_ID	UInt16	Mandatory
DEVICE_TYPE	UInt16	Mandatory
DEVICE_REVISION	UInt8	Mandatory
UNIVERSAL_REVISION	UInt8	Optional
SERIAL_NUMBER	UInt24	Optional
HARDWARE_REVISION	UInt8	Optional
SOFTWARE_REVISION	UInt8	Optional
REVISION_COUNTER	UInt16	Optional

4.5 Topology elements

4.5.1 ConnectionPoint definition

4.5.1.1 General

CP 9/1 devices can support up to five different ConnectionPoint types that are used for network communications.

4.5.1.2 HART_TP5, HART_TP6, HART_TP7

The ConnectionPoint types HART_TP5, HART_TP6, and HART_TP7 shall be used to identify CP 9/1 token passing network communication and are defined in Table 9. HART_TP5, HART_TP6, and HART_TP7 all contain the same properties, but each provides different qualification information for some of the properties (described below). The Protocol Version (UNIVERSAL_REVISION) described in 4.2.4 can be used as an aid to determine which of the three token passing Connection Point types is the most appropriate. CP 9/1 token passing communications can be used on a variety of physical layers. FSK, PSK, RS485, and Infrared physical layer connections shall all use the HART_TP connection type. The ConnectionPoint types HART_TP5, HART_TP6, and HART_TP7 are subtypes of abstract type ConnectionPointType defined in IEC 62769-5.

The DevAddr property shall be the long address (5 bytes) for the device and is the only parameter necessary to communicate with the field device.

The DevMfg property shall be the 2-byte Manufacturer ID and can be used to help automate the process of assigning live devices in the scan list to offline placeholders.

The DevType property shall be the 2-byte extended device type and can be used to help automate the process of assigning live devices in the scan list to offline placeholders.

The DevRev property shall be the device revision and can be used to help automate the process of assigning live devices in the scan list to offline placeholders.

The DevTag property shall be the long tag for HART® protocol version 6 or 7 devices. The DevTag property shall be the tag for protocol version 5 devices. The DevTag property can be used to help automate the process of assigning live devices in the scan list to offline

placeholders. HART_TP5 Connection Points shall limit the DevTag to 8 characters in length. HART_TP6 and HART_TP7 Connection Points shall limit the DevTag to 32 characters in length.

The DevPollAddr property shall be the poll address and can be used to identify which device is located at a specific poll address. HART_TP5 Connection Points shall be limited to values between 0 and 15 for the DevPollAddr property. HART_TP6 Connection Points shall be limited to values between 0 and 31 for the DevPollAddr property. HART_TP7 Connection Points shall be limited to values between 0 and 63 for the DevPollAddr property.

For forward compatibility, a lower revision HART_TP Connection Point is compatible and can be used for a higher universal revision device connection. For example, if a future HART universal revision 8 device is encountered, and no HART_TP8 is available in the FDI server, HART_TP7 will be compatible and shall be used to connect to the device. If the Protocol Version (i.e. the Universal Revision) is unknown for any reason, the HART_TP5 Connection Point can be used, and will be forward compatible to later universal revisions.

Table 9 – ConnectionPointType HART_TP definition

Attribute	Value				
BrowseName	ConnectionPoint_HART_TP5 or ConnectionPoint_HART_TP6 or ConnectionPoint_HART_TP7				
IsAbstract	False				
References	NodeClass	BrowseName	Data Type	TypeDefinition	ModellingRule
Inherits the properties of ConnectionPointType defined in IEC 62769-5					
HasProperty	Variable	DevAddr	UInt40	PropertyType	Mandatory
HasProperty	Variable	DevMfg	UInt16	PropertyType	Optional
HasProperty	Variable	DevType	UInt16	PropertyType	Optional
HasProperty	Variable	DevRev	UInt16	PropertyType	Optional
HasProperty	Variable	DevTag	String	PropertyType	Optional
HasProperty	Variable	DevPollAddr	UInt8	PropertyType	Optional

The ConnectionPoint type HART_TP5, HART_TP6, and HART_TP7 shall be described by an EDD element contained in a Communication Device related FDI Package that can drive a CP 9/1 network. Actual ConnectionPoint properties are declared by VARIABLE constructs grouped together in a COLLECTION named ConnectionPoint_HART_TP5, ConnectionPoint_HART_TP6, or ConnectionPoint_HART_TP7. The following EDDL source code is an example describing a TP5 Connection Point.

```

COMPONENT ConnectionPoint_HART_TP5
{
    LABEL "HART TP Connection Point";
    CLASSIFICATION NETWORK_CONNECTION_POINT;
    CAN_DELETE FALSE;
    PROTOCOL HART;
    CONNECTION_POINT ConnectionPoint_TP5;
}

VARIABLE DevAddr
{
    LABEL "Address";
    CLASS DEVICE;
    TYPE UNSIGNED_INTEGER(5);
    HANDLING READ & WRITE;
}
    
```

```
VARIABLE DevMfg
{
  LABEL "Manufacturer";
  CLASS DEVICE;
  TYPE UNSIGNED_INTEGER(2);
  HANDLING READ & WRITE;
}

VARIABLE DevType
{
  LABEL "Device Type";
  CLASS DEVICE;
  TYPE UNSIGNED_INTEGER(2);
  HANDLING READ & WRITE;
}

VARIABLE DevRev
{
  LABEL "Device Revision";
  CLASS DEVICE;
  TYPE UNSIGNED_INTEGER;
  HANDLING READ & WRITE;
}

VARIABLE DevTag
{
  LABEL "Tag";
  CLASS DEVICE;
  TYPE ASCII(32);
  HANDLING READ & WRITE;
}

VARIABLE DevPollAddr
{
  LABEL "Poll Address";
  CLASS DEVICE;
  TYPE UNSIGNED_INTEGER
  {
    MAX_VALUE 15; //Define appropriate max value for various revisions
  }
  HANDLING READ & WRITE;
}

COLLECTION ConnectionPoint_TP5
{
  LABEL "Connection Point";
  MEMBERS
  {
    ADDRESS,    DevAddr,    "Device Address";
    MFG,        DevMfg,     "Manufacturer";
    DEV_TYPE,   DevType,    "Device Type";
    DEV_REV,    DevRev,     "Device Revision";
    TAG,        DevTag,     "Device Tag";
    POLL_ADDR, DevPollAddr, "Poll Address";
  }
}
```

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 62769-109-1:2020](https://standards.iteh.ai/catalog/standards/sist/e3fa8867-2deb-4d86-a44b-a893b499068e/iec-62769-109-1-2020)

<https://standards.iteh.ai/catalog/standards/sist/e3fa8867-2deb-4d86-a44b-a893b499068e/iec-62769-109-1-2020>