

INTERNATIONAL STANDARD



**Household and similar electrical appliances –
Test code for the determination of airborne acoustical noise –
Part 2-7: Particular requirements for fans**

Document Preview

[IEC 60704-2-7:2020](#)

<https://standards.iteh.ai/catalog/standards/iec/d58e6b42-af12-4a86-b86b-633e21438fbd/iec-60704-2-7-2020>





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2020 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

[IEC 60704-2-7:2020](https://standards.iteh.ai/catalog/standards/iec/d58e6b42-af12-4a86-b86b-633e21438fbd/iec-60704-2-7-2020)

<https://standards.iteh.ai/catalog/standards/iec/d58e6b42-af12-4a86-b86b-633e21438fbd/iec-60704-2-7-2020>



IEC 60704-2-7

Edition 2.0 2020-01
REDLINE VERSION

INTERNATIONAL STANDARD



**Household and similar electrical appliances –
Test code for the determination of airborne acoustical noise –
Part 2-7: Particular requirements for fans**

Document Preview

[IEC 60704-2-7:2020](https://standards.iteh.ai/catalog/standards/iec/d58e6b42-af12-4a86-b86b-633e21438fbd/iec-60704-2-7-2020)

<https://standards.iteh.ai/catalog/standards/iec/d58e6b42-af12-4a86-b86b-633e21438fbd/iec-60704-2-7-2020>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 17.140.20; 23.120

ISBN 978-2-8322-7799-7

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	3
1 Scope and object	7
2 Normative references	8
3 Terms and definitions	9
4 Measurement methods and acoustical environments	9
5 Instrumentation	12
6 Operation and location of appliances under test	12
7 Measurement of sound pressure levels	13
8 Calculation of sound pressure and sound power levels	15
9 Information to be recorded	15
10 Information to be reported	15
Annexes	17
Annex B (normative) Test enclosure	17
Bibliography	17
Figure 101 – Measurement surface – hemisphere – with 10 microphone positions for partition (wall and window) fans and for wall-mounted table fans	16
Table 101 – Standard deviations of sound power levels	8
Table 102 – Standard deviations for declaration and verification	8

<https://standards.iteh.ai>
IEC 60704-2-7:2020

<https://standards.iteh.ai/catalog/standards/iec/d58e6b42-af12-4a86-b86b-633e21438fbd/iec-60704-2-7-2020>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**HOUSEHOLD AND SIMILAR ELECTRICAL APPLIANCES –
TEST CODE FOR THE DETERMINATION OF
AIRBORNE ACOUSTICAL NOISE –****Part 2-7: Particular requirements for fans**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

International Standard IEC 60704-2-7 has been prepared by subcommittee 59L: Small household appliances, of IEC technical committee 59: Performance of household and similar electrical appliances.

This second edition cancels and replaces the first edition published in 1997. This edition constitutes a technical revision.

This edition includes the following significant changes with respect to the previous edition:

- a) it includes additional fan categories as defined in IEC 60879:2019 and IEC 60665:2018;
- b) it includes standard deviations of sound power levels in 1.3;
- c) a comparison method has been added;
- d) the normative references have been updated (ISO 3744:2010 and ISO 3743-1:2010);
- e) it has been adjusted with regard to IEC 60704-1:2010.

The text of this standard is based on the following documents:

CDV	Report on voting
59L/168/CDV	59L/174/RVC

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60704 series, published under the general title *Household and similar electrical appliances – Test code for the determination of airborne acoustical noise*, can be found on the IEC website.

This International Standard is to be used in conjunction with IEC 60704-1:2010, *Household and similar electrical appliances – Test code for the determination of airborne acoustical noise – Part 1: General requirements*.

NOTE When “Part 1” is mentioned in this standard, it refers to IEC 60704-1:2010.

The relevant text of Part 1 as amended by this standard establishes the test code for fans.

This Part 2-7 supplements or modifies the corresponding clauses in IEC 60704-1:2010, so as to establish the test code for fans. When a particular subclause of Part 1 is not mentioned in this Part 2-7, that subclause is applicable as far as reasonable. Where this standard states “addition”, “modification” or “replacement”, the relevant requirements, test specifications or explanatory matter in Part 1 should be adapted accordingly.

Subclauses, tables and figures that are numbered starting from 101 are additional to those in Part 1.

Unless notes are in a new subclause or involve notes in Part 1, they are numbered starting from 101, including those in a replaced clause or subclause.

Additional annexes are lettered AA, BB, etc.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 60704-2-7:2020](#)

<https://standards.iteh.ai/catalog/standards/iec/d58e6b42-af12-4a86-b86b-633e21438fbd/iec-60704-2-7-2020>

INTRODUCTION

The measuring conditions specified in this Part 2-7 provide for sufficient accuracy in determining the noise emitted and the comparison of the results of measurements taken by different laboratories, whilst simulating as far as possible the practical use of household fans.

It is recommended to consider the determination of noise levels as part of a comprehensive testing procedure covering many aspects of the properties and performance of household fans.

NOTE As stated in the introduction to IEC 60704-1, this test code is concerned with airborne noise only.

iTeh Standards
(<https://standards.itih.ai>)
Document Preview

[IEC 60704-2-7:2020](https://standards.itih.ai/catalog/standards/iec/d58e6b42-af12-4a86-b86b-633e21438fbd/iec-60704-2-7-2020)

<https://standards.itih.ai/catalog/standards/iec/d58e6b42-af12-4a86-b86b-633e21438fbd/iec-60704-2-7-2020>

HOUSEHOLD AND SIMILAR ELECTRICAL APPLIANCES – TEST CODE FOR THE DETERMINATION OF AIRBORNE ACOUSTICAL NOISE –

Part 2-7: Particular requirements for fans

1 Scope and object

This clause of Part 1 is applicable except as follows:

1.1 Scope

1.1.1 General

Replacement:

This document applies to electrical fans (including their accessories and their component parts) for household and similar use, designed for AC or DC supply.

The motor, the impeller and their housing, if any, form a single unit.

These particular requirements apply to:

- conventional fans,
- table fans,
- pedestal fans,
- ceiling fans,
- bladeless fans,
- wall bracket fans,
- ceiling bracket fans,
- louver fans,
- tower fans,
- ventilating and partition ventilating fans.

This standard does not apply to:

- fans that are part of a ventilation system,
- fans designed exclusively for industrial purposes,
- fans that are part of an appliance (for example cooling fans),
- fans with additional functions (for example heating, humidifying).

Limitations for the use of this test code are given in the scope of IEC 60704-1.

1.1.2 Type of noise

Replacement:

The methods specified in ISO 3743-1, ISO 3743-2 and ISO 3744 can be used for measuring noise emitted by fans.

1.1.3 Size of source

Replacement:

The method specified in ISO 3744 is applicable to noise sources of any size. When applying ISO 3743-1 and ISO 3743-2, care should be taken to ensure that the maximum size of the appliance under test fulfils the requirements specified in 1.2 of ISO 3743-1:2010 and 1.3 of ISO 3743-2:1994.

1.2 Object

Addition:

This document describes the determination of the noise emission of household fans in normal operation at maximum speed. Other speeds can, in addition, be used. Requirements for the declaration of noise emission values are not within the scope of this document.

The aim of this document is to ~~measure~~ give direction for measuring the noise in a room resulting from the operation of a fan.

NOTE 101 For determining and verifying noise emission values declared in product specifications, see IEC 60704-3.

1.3 Measurement uncertainty

Replacement:

The estimated values of standard deviations of sound power levels determined in accordance with this document are given in Table 101:

Table 101 – Standard deviations of sound power levels

Standard deviation (dB)	
σ_r (repeatability)	σ_R (reproducibility)
0,4	1,0

Addition:

1.101 Standard deviation for declaration and verification

For the purpose of determining and verifying declared noise emission values in accordance with IEC 60704-3, the values in Table 102 apply:

Table 102 – Standard deviations for declaration and verification

Standard deviation (dB)		
σ_p (production)	σ_t (total)	σ_M (reference)
0,5 to 1,0	1,0 to 1,4	1,5

2 Normative references

This clause of Part 1 is applicable except as follows:

Replacement:

ISO 3743-1:2010, *Acoustics – Determination of sound power levels and sound energy levels of noise sources using sound pressure – Engineering methods for small movable sources in reverberant fields – Part 1: Comparison method for a hard-walled test room*

ISO 3744:2010, *Acoustics – Determination of sound power levels and sound energy levels of noise sources using sound pressure – Engineering methods for an essentially free field over a reflecting plane*

Addition:

~~IEC 60665:1980, A.C. electric ventilating fans and regulators for household and similar purposes~~

IEC 60704-1:1997/2010, *Household and similar electrical appliances – Test code for the determination of airborne acoustical noise – Part 1: General requirements*¹⁾

~~IEC 60879:1986, Performance and construction of electric circulating fans and regulators~~

3 Terms and definitions

This clause of Part 1 is applicable except as follows:

Addition:

~~3.101 **table fan:** A smaller diameter propeller-bladed fan having two or more blades, intended for use with free inlet and outlet of air. It may be a table fan or bracket-mounted fan for wall or ceiling mounting. [IEC 60879]~~

~~NOTE – Adjustment of height, position and oscillation may be possible.~~

~~3.102 **pedestal fan:** A propeller type fan having two or more blades mounted on a pedestal of fixed or variable height and intended for use with free inlet and outlet of air. [IEC 60879]~~

~~NOTE – Adjustment of position and oscillation may be possible.~~

~~3.103 **ceiling fan:** A propeller-bladed fan having two or more blades, and provided with a device for suspension from the ceiling of a room so that the blades rotate in a horizontal plane. [IEC 60879]~~

~~3.104 **partition (wall and window) fans:** Fans designed for installation in wall or window openings. The air is displaced from one room to another or to atmosphere, or vice versa (see also IEC 60665).~~

3.101

conventional fan

comfort fan with a propeller having two or more blades, with free inlet and outlet of air

[SOURCE: IEC 60879:2019, 3.2]

3.102

tower fan

comfort fan for use directly on the floor having a vertically elongated design of the cross flow type, tangential type or centrifugal type or impeller type with a free inlet and outlet of air

¹⁾ ~~To be published.~~

[SOURCE: IEC 60879:2019, 3.3]

**3.103
bladeless fan**

comfort fan of any type that is not fitted with a propeller

[SOURCE: IEC 60879:2019, 3.4]

**3.104
ceiling fan**

conventional fan provided with a device for suspension from the ceiling of a room so that the blades rotate in a horizontal plane with the diameter of the blade not larger than 1800 mm

[SOURCE: IEC 60879:2019, 3.5]

**3.105
table fan**

comfort fan intended for use on a table

Note 1 to entry: Table fans have a maximum adjustable or non-adjustable height not greater than 1200mm

Note 2 to entry: Adjustment of height, position and oscillation can be possible.

Note 3 to entry: It can be a table fan or bracket-mounted fan for wall or ceiling mounting.

[SOURCE: IEC 60879:2019, 3.6, modified – Note 2 to entry and Note 3 to entry added]

**3.106
pedestal fan**

comfort fan mounted on a pedestal of fixed or variable height

Note 1 to entry: Pedestal fans have a maximum adjustable height or non-adjustable height greater than 1 200 mm

Note 2 to entry: Adjustment of position and oscillation can be possible.

[SOURCE: IEC 60879:2019, 3.7, modified – Note 2 to entry added]

**3.107
wall bracket fan**

comfort fan for mounting on the wall

[SOURCE: IEC 60879:2019, 3.8]

**3.108
ceiling bracket fan**

comfort fan for mounting on the ceiling

[SOURCE: IEC 60879:2019, 3.9]

**3.109
louvre fan**

comfort fan having a moving louvre which provides a continuously changing multi-directional air flow

[SOURCE: IEC 60879:2019, 3.10]

**3.110
ventilating fan**

fan intended to displace air either from one side of a partition to the other, or within a duct installed either on the fan inlet or on the fan outlet or both

[SOURCE: IEC 60665:2018, 3.2]

**3.111
partition ventilating fan
type A ventilating fan**

ventilating fan installed in or upon the aperture of a partition in order to displace air from one side of the partition to the other side, both the sides being free spaces

[SOURCE: IEC 60665:2018, 3.3]

**3.112
free inlet partition ventilating fan
type B ventilating fan**

ventilating fan with a direct inlet from free space and with ducted outlet

[SOURCE: IEC 60665:2018, 3.4]

**3.113
free outlet partition ventilating fan
type C ventilating fan**

ventilating fan with ducted inlet, and with direct outlet to free space

[SOURCE: IEC 60665:2018, 3.5]

**3.114
fully ducted ventilating fan
type D ventilating fan**

ventilating fan with ducted inlet and ducted outlet

[SOURCE: IEC 60665:2018, 3.6]

4 Measurement methods and acoustical environments

This clause of Part 1 is applicable except as follows:

4.2 Direct method

Addition:

~~NOTE — If pure tone components are present in the noise emitted, proper precautions should be taken as specified in ISO 3743-1, ISO 3743-2 and ISO 3744.~~

If pure tone components are present in the noise emitted by the source, the estimated standard deviation of the measured sound pressure levels in the special reverberation room can increase. In such cases, additional microphone positions or source positions can be necessary, such as those specified in ISO 3743-2.

4.3 Comparison method

Modification:

~~The comparison method described in ISO 3743-1 is not applicable.~~

NOTES

~~1— Measurement according to ISO 3743-1 is under consideration.~~

~~2— If pure components are present in the noise emitted, proper precautions should be taken as specified in ISO 3743-1, ISO 3743-2 and ISO 3744.~~

Addition:

If pure tone components are present in the noise emitted by the source, the estimated standard deviation of the measured sound pressure levels in the hard-walled test room or in the special reverberation room can increase. In such cases, additional microphone positions or source positions can be necessary, such as those specified in ISO 3743-1 or ISO 3743-2.

5 Instrumentation

This clause of Part 1 is applicable except as follows:

Addition:

The use of a windscreen is mandatory, and necessary corrections for changes in the microphone sensitivity shall be added to the observed sound pressure levels.

6 Operation and location of appliances under test

This clause of Part 1 is applicable except as follows:

6.2 Supply of electricity and of water or gas**6.2.3**

Not applicable.

[IEC 60704-2-7:2020](https://standards.iteh.ai/catalog/standards/iec/d58e6b42-af12-4a86-b86b-633e21438fbd/iec-60704-2-7-2020)

<https://standards.iteh.ai/catalog/standards/iec/d58e6b42-af12-4a86-b86b-633e21438fbd/iec-60704-2-7-2020>

Not applicable.

6.4 Loading and operating of appliances during tests**6.4.1****Replacement:**

Load and operation should simulate normal use. Fans that can be tilted during normal use shall be located in the position with the highest emitted noise level, and the duration of the measurement shall be at least 10 s.

Fans that can oscillate automatically ~~will~~ shall operate when oscillating. In the case of oscillating appliances, the A-weighted sound pressure level shall be averaged on at least one complete cycle.

6.4.3

Not applicable.