



Designation: **E2486/E2486M – 13 E2486/E2486M – 13 (Reapproved 2018)**

Standard Test Method for Impact Resistance of Class PB and PI Exterior Insulation and Finish Systems (EIFS)¹

This standard is issued under the fixed designation E2486/E2486M; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This test method covers a procedure for rapidly deforming by impact an EIFS for evaluating the effect of such deformation.

1.2 The values stated in either SI units or inch-pound units are to be regarded separately as standard. The values stated in each system may not be exact equivalents; therefore, each system shall be used independently of the other. Combining values from the two systems may result in non-conformance with the standard.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and to determine the applicability of regulatory limitations prior to use.*

1.4 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 *ASTM Standards:*²

[D2794 Test Method for Resistance of Organic Coatings to the Effects of Rapid Deformation \(Impact\)](#)

[E631 Terminology of Building Constructions](#)

[E2110 Terminology for Exterior Insulation and Finish Systems \(EIFS\)](#)

3. Terminology

3.1 For general terminology regarding EIFS and building in general, see Terminology [E2110](#) (for EIFS terms) and Terminology [E631](#) (for buildings in general).

4. Summary of Test Method

4.1 Specimens shall be subjected to rapid deformation by a falling standard weight. By gradually increasing the distance the weight drops, the point at which failure occurs can be determined.

4.2 The impact resistance classification shall be determined by the number of joules [inch-lb] achieved when at least six out of ten tests do not display broken reinforcing mesh that is visible to the naked eye under normal lighting conditions.

5. Significance and Use

5.1 This specification determines levels of impact resistance under Classes PB and PI EIFS.

5.2 This test method does not purport to simulate impact encountered in service.

6. Apparatus

6.1 The apparatus shall be as specified in the Apparatus Section of Test Method [D2794](#) with the following exceptions:

6.1.1 The cylindrical weight shall be 1.82 kg [4.0 lb],

¹ This test method is under the jurisdiction of ASTM Committee [E06](#) on Performance of Buildings and is the direct responsibility of Subcommittee [E06.58](#) on Exterior Insulation and Finish Systems (EIFS).

Current edition approved Sept. 1, 2013; Sept. 1, 2018. Published September 2013; September 2018. Originally approved in 2006. Last previous edition approved in 2006/2013 as [E2486/E2486M – 06](#). DOI: 10.1520/E2486-E2486M-13-13. DOI: 10.1520/E2486-E2486M-13R18.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the [standard's Document Summary page](#) on the ASTM website.