

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Household and similar electrical appliances – Safety –
Part 2-51: Particular requirements for stationary circulation pumps for heating
and service water installations

Appareils électrodomestiques et analogues – Sécurité –
Partie 2-51: Exigences particulières pour les pompes de circulation fixes pour
installations de chauffage et de distribution d'eau



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22,000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67,000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.



INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Household and similar electrical appliances – Safety –
Part 2-51: Particular requirements for stationary circulation pumps for heating
and service water installations**

**Appareils électrodomestiques et analogues – Sécurité –
Partie 2-51: Exigences particulières pour les pompes de circulation fixes pour
installations de chauffage et de distribution d'eau**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 23.080; 91.140.10

ISBN 978-2-8322-6811-7

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	6
4 General requirement.....	7
5 General conditions for the tests	7
6 Classification.....	7
7 Marking and instructions.....	8
8 Protection against access to live parts.....	8
9 Starting of motor-operated appliances	8
10 Power input and current.....	8
11 Heating.....	9
12 Void.....	9
13 Leakage current and electric strength at operating temperature.....	9
14 Transient overvoltages.....	9
15 Moisture resistance.....	9
16 Leakage current and electric strength.....	9
17 Overload protection of transformers and associated circuits	10
18 Endurance.....	10
19 Abnormal operation	10
20 Stability and mechanical hazards.....	10
21 Mechanical strength	10
22 Construction	10
23 Internal wiring.....	10
24 Components	11
25 Supply connection and external flexible cords	11
26 Terminals for external conductors.....	11
27 Provision for earthing	11
28 Screws and connections.....	11
29 Clearances, creepage distances and solid insulation	11
30 Resistance to heat and fire.....	11
31 Resistance to rusting.....	11
32 Radiation, toxicity and similar hazards.....	11
Annexes	12
Annex A (informative) Routine tests	12
Bibliography.....	13
Table 101 – Temperature classification of circulation pumps.....	7


 (standards.iteh.ai)
<https://standards.iteh.ai/catalog/standards/sist/bd90caf-42e4-4165-a668-cdda8d8c1e3/iec-60335-2-51-2019>
 IEC 60335-2-51:2019

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HOUSEHOLD AND SIMILAR ELECTRICAL APPLIANCES – SAFETY –**Part 2-51: Particular requirements for stationary circulation pumps
for heating and service water installations**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60335-2-51 has been prepared by IEC technical committee 61: Safety of household and similar electrical appliances.

This fourth edition cancels and replaces the third edition published in 2002, Amendment 1:2008 and Amendment 2:2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- some instructions are no longer required (7.12);
- converted some notes to normative text (7.12.1, 11.3, 11.8);
- new instructions for installation of thermal insulation (7.12.1);
- the leakage current value is modified (Clause A.2).

The text of this International Standard is based on the following documents:

FDIS	Report on voting
61/5785/FDIS	61/5802/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60335 series, under the general title: *Household and similar electrical appliances – Safety*, can be found on the IEC website.

This part 2 is to be used in conjunction with the latest edition of IEC 60335-1 and its amendments. It was established on the basis of the fifth edition (2010) of that standard.

NOTE 1 When “Part 1” is mentioned in this standard, it refers to IEC 60335-1.

This part 2 supplements or modifies the corresponding clauses in IEC 60335-1, so as to convert that publication into the IEC standard: Safety requirements for electric stationary circulation pumps for heating and service water installations.

When a particular subclause of Part 1 is not mentioned in this part 2, that subclause applies as far as is reasonable. When this standard states “addition”, “modification” or “replacement”, the relevant text in Part 1 is to be adapted accordingly.

NOTE 2 The following numbering system is used:

- subclauses, tables and figures that are numbered starting from 101 are additional to those in Part 1;
- unless notes are in a new subclause or involve notes in Part 1, they are numbered starting from 101, including those in a replaced clause or subclause;
- additional annexes are lettered AA, BB, etc.

NOTE 3 The following print types are used:

- requirements: in roman type;
- *test specifications: in italic type;*
- notes: in small roman type.

Words in **bold** in the text are defined in Clause 3. When a definition concerns an adjective, the adjective and the associated noun are also in bold.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

NOTE 4 The attention of National Committees is drawn to the fact that equipment manufacturers and testing organizations may need a transitional period following publication of a new, amended or revised IEC publication in which to make products in accordance with the new requirements and to equip themselves for conducting new or revised tests.

It is the recommendation of the committee that the content of this publication be adopted for implementation nationally not earlier than 12 months or later than 36 months from the date of publication.

INTRODUCTION

It has been assumed in the drafting of this International Standard that the execution of its provisions is entrusted to appropriately qualified and experienced persons.

This standard recognizes the internationally accepted level of protection against hazards such as electrical, mechanical, thermal, fire and radiation of appliances when operated as in normal use taking into account the manufacturer's instructions. It also covers abnormal situations that can be expected in practice and takes into account the way in which electromagnetic phenomena can affect the safe operation of appliances.

This standard takes into account the requirements of IEC 60364 as far as possible so that there is compatibility with the wiring rules when the appliance is connected to the supply mains. However, national wiring rules may differ.

If an appliance within the scope of this standard also incorporates functions that are covered by another part 2 of IEC 60335, the relevant part 2 is applied to each function separately, as far as is reasonable. If applicable, the influence of one function on the other is taken into account.

When a part 2 standard does not include additional requirements to cover hazards dealt with in Part 1, Part 1 applies.

NOTE 1 This means that the technical committees responsible for the part 2 standards have determined that it is not necessary to specify particular requirements for the appliance in question over and above the general requirements.

(standards.iteh.ai)

This standard is a product family standard dealing with the safety of appliances and takes precedence over horizontal and generic standards covering the same subject.

<https://standards.iteh.ai/catalog/standards/sist/bd90caf-42c4-4165-a668-4136ac06c19/iec-60335-2-51-2019>

NOTE 2 Horizontal and generic standards covering a hazard are not applicable since they have been taken into consideration when developing the general and particular requirements for the IEC 60335 series of standards. For example, in the case of temperature requirements for surfaces on many appliances, generic standards, such as ISO 13732-1 for hot surfaces, are not applicable in addition to Part 1 or part 2 standards.

An appliance that complies with the text of this standard will not necessarily be considered to comply with the safety principles of the standard if, when examined and tested, it is found to have other features that impair the level of safety covered by these requirements.

An appliance employing materials or having forms of construction differing from those detailed in the requirements of this standard may be examined and tested according to the intent of the requirements and, if found to be substantially equivalent, may be considered to comply with the standard.

HOUSEHOLD AND SIMILAR ELECTRICAL APPLIANCES – SAFETY –

Part 2-51: Particular requirements for stationary circulation pumps for heating and service water installations

1 Scope

This clause of Part 1 is replaced by the following.

This International Standard deals with the safety of electric **stationary circulation pumps** for household and similar purposes intended for use in heating systems or in service water systems, their **rated voltage** being not more than 250 V for single-phase appliances and 480 V for other appliances.

NOTE 101 The hydraulic and electrical parts of the pump can be in the same enclosure, so that the water flows through the motor and serves as a coolant, or they can be separated.

Appliances not intended for normal household use, but that nevertheless may be a source of danger to the public, such as appliances intended to be used by laymen in shops, in light industry and on farms, are within the scope of this standard.

As far as is practicable, this standard deals with the common hazards presented by appliances that are encountered by all persons in and around the home. However, in general, it does not take into account

- persons (including children) whose [IEC 60335-2-51:2019](https://standards.iteh.ai/catalog/standards/sist/bd90caf-42c4-4165-a668-cdad60c1c9/iec-60335-2-51-2019) <https://standards.iteh.ai/catalog/standards/sist/bd90caf-42c4-4165-a668-cdad60c1c9/iec-60335-2-51-2019> physical, sensory or mental capabilities; or
 - lack of experience and knowledge prevents them from using the appliance safely without supervision or instruction;
- children playing with the appliance.

NOTE 102 Attention is drawn to the fact that

- for appliances intended to be used in vehicles or on board ships or aircraft, additional requirements can be necessary;
- in many countries additional requirements are specified by the national health authorities, the national authorities responsible for the protection of labour and similar authorities.

NOTE 103 This standard does not apply to

- pumps for circulating liquids other than water;
- pumps, other than circulation pumps (IEC 60335-2-41);
- circulation pumps intended exclusively for industrial purposes;
- circulation pumps intended to be used in locations where special conditions prevail, such as the presence of a corrosive or explosive atmosphere (dust, vapour, or gas).

2 Normative references

This clause of Part 1 is applicable.

3 Terms and definitions

This clause of Part 1 is applicable except as follows.

3.1 Definitions relating to physical characteristics

Replacement:

3.1.9 normal operation

operation of the circulation pump with the water pressure and flow rate adjusted within their specified limits, so that the highest power input is attained

4 General requirement

This clause of Part 1 is applicable.

5 General conditions for the tests

This clause of Part 1 is applicable except as follows.

5.7 Addition:

The water temperature at the inlet is maintained between 0 °C and –5 °C of the value corresponding to the TF class of the pump.

For circulation pumps intended to be located within the enclosure of a boiler, the tests of Clauses 10, 11 and 13 are carried out at an ambient temperature of 55 °C or at the temperature specified in the instructions, whichever is higher.

5.101 Circulation pumps having a three-phase motor that does not incorporate a **protective device** are installed with an appropriate device in accordance with the instructions.

6 Classification

This clause of Part 1 is applicable except as follows.

6.1 Modification:

Circulation pumps shall be **class I, class II** or **class III**.

6.2 Addition:

Circulation pumps shall be at least IPX2.

6.101 Circulation pumps shall be of one of the classes shown in Table 101.

Table 101 – Temperature classification of circulation pumps

Class	Maximum temperature of the circulating water °C
TF 60	60
TF 95	95
TF 110	110

Compliance is checked by inspection.

7 Marking and instructions

This clause of Part 1 is applicable except as follows.

7.1 Addition:

Circulation pumps shall be marked with

- the TF class;
- the direction of the water flow;
- the direction of rotation (for pumps having three-phase motors);
- the rated current (for pumps having three-phase motors if a **protective device** has to be installed in the fixed wiring).

7.12 Modification:

The instruction concerning persons (including children) with reduced physical, sensory or mental capabilities, or lack of experience and knowledge is not applicable.

The instruction regarding supervision of children is not applicable.

7.12.1 Addition:

The installation instructions shall state the substance of the following:

- the maximum flow rate or total head;
- the maximum ambient temperature at which the pump is to be used;
- the maximum system pressure, which shall not be less than:
 - 0,6 MPa for pumps for heating systems;
 - 1,0 MPa for pumps for service water systems;
- the intended orientation of the pump;
- a protective device is to be installed in the fixed wiring and its characteristics are to be specified (for pumps having a three-phase motor not incorporating a **protective device**).
- for the thermal insulation of circulation pumps in heating systems, only the supplied kit or a kit made available by the manufacturer shall be used. It shall be ensured that the drain openings of the motor are not sealed after installation of the thermal insulation.

8 Protection against access to live parts

This clause of Part 1 is applicable.

9 Starting of motor-operated appliances

This clause of Part 1 is not applicable.

10 Power input and current

This clause of Part 1 is applicable.

11 Heating

This clause of Part 1 is applicable except as follows.

11.2 Addition:

Circulation pumps that are only fixed by the water pipes are positioned against one wall of the test corner and away from the other.

11.3 Addition:

The temperatures t_1 and t_2 are the ambient temperatures of the environment in which the pump is installed, for instance inside the enclosure of a boiler.

11.7 Replacement:

Circulation pumps are operated until steady conditions are established.

11.8 Addition:

The temperature rise limits of pumps located within the enclosure of a boiler are reduced by the difference between the ambient temperature at which the test is carried out and 25 °C.

The temperature rise of the external enclosure is not measured.

For circulation pumps in which water flows through the motor, the temperature rise limits for windings are increased by 5 K. The temperature rise limits are increased further by

- 5 K, if the winding insulation is class 130 (B);
- 10 K, if the winding insulation is class 155 (F) or 180 (H).

For circulation pumps in which water flows through the motor, the increase of 5 K allowed by footnote ^a to Table 3 does not apply.

12 Void

13 Leakage current and electric strength at operating temperature

This clause of Part 1 is applicable.

14 Transient overvoltages

This clause of Part 1 is applicable.

15 Moisture resistance

This clause of Part 1 is applicable.

16 Leakage current and electric strength

This clause of Part 1 is applicable.

17 Overload protection of transformers and associated circuits

This clause of Part 1 is applicable.

18 Endurance

This clause of Part 1 is not applicable.

19 Abnormal operation

This clause of Part 1 is applicable except as follows.

19.1 Addition:

Circulation pumps are also subjected to the test of 19.101.

19.7 Addition:

The test is carried out with the water flow stopped or reduced to 5 l/min, whichever is more unfavourable.

19.101 *Circulation pumps are supplied at rated voltage and operated at approximately half the maximum system pressure for 5 min, after which the water is drained off and the operation continued for 7 h. The system is replenished with water and the pump operated again for 5 min at approximately half the maximum system pressure.*

If the pump becomes inoperable during the test, it is disconnected from the supply and the system filled with water.

20 Stability and mechanical hazards

This clause of Part 1 is applicable.

21 Mechanical strength

This clause of Part 1 is applicable.

22 Construction

This clause of Part 1 is applicable except as follows.

22.101 *Circulation pumps shall withstand the water pressure occurring in normal use.*

Compliance is checked by subjecting the pump to a water pressure equal to 1,2 times the maximum system pressure for 1 min.

The pump shall not leak.

23 Internal wiring

This clause of Part 1 is applicable.