

# INTERNATIONAL STANDARD



Luminaires –  
Part 2-22: Particular requirements – Luminaires for emergency lighting

iTeh Standards  
(<https://standards.itih.ai>)  
Document Preview

[IEC 60598-2-22:2021](https://standards.itih.ai/catalog/standards/iec/e82a3455-32bc-47f9-bcea-d69da9851310/iec-60598-2-22-2021)

<https://standards.itih.ai/catalog/standards/iec/e82a3455-32bc-47f9-bcea-d69da9851310/iec-60598-2-22-2021>



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2021 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

#### IEC publications search - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

#### IEC online collection - [oc.iec.ch](http://oc.iec.ch)

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

#### IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [sales@iec.ch](mailto:sales@iec.ch).

International Standards  
standards.iteh.ai  
Document Preview

[IEC 60598-2-22:2021](https://standards.iteh.ai/catalog/standards/iec/e82a3455-32bc-47f9-bcea-d69da9851310/iec-60598-2-22-2021)

<https://standards.iteh.ai/catalog/standards/iec/e82a3455-32bc-47f9-bcea-d69da9851310/iec-60598-2-22-2021>



IEC 60598-2-22

Edition 5.0 2021-12  
REDLINE VERSION

# INTERNATIONAL STANDARD



---

**Luminaires –  
Part 2-22: Particular requirements – Luminaires for emergency lighting**

iTeh Standards  
(<https://standards.itih.ai>)  
Document Preview

[IEC 60598-2-22:2021](https://standards.itih.ai/catalog/standards/iec/e82a3455-32bc-47f9-bcea-d69da9851310/iec-60598-2-22-2021)

<https://standards.itih.ai/catalog/standards/iec/e82a3455-32bc-47f9-bcea-d69da9851310/iec-60598-2-22-2021>

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 29.140.40

ISBN 978-2-8322-4256-8

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD .....	3
<del>INTRODUCTION to Amendment 1 .....</del>	<del>3</del>
22.1 Scope .....	7
22.2 Normative references .....	7
22.3 Terms and definitions .....	8
22.4 General test requirements .....	12
22.5 Classification of luminaires .....	13
22.6 Marking .....	13
22.7 Construction .....	15
22.8 Creepage distances and clearances .....	18
22.9 Provision of earthing .....	18
22.10 Terminals .....	19
22.11 External and internal wiring .....	19
22.12 Protection against electric shock .....	19
22.13 Endurance test and thermal test .....	19
22.14 Resistance to dust and moisture .....	21
22.15 Insulation resistance and electric strength .....	21
22.16 Resistance to heat, fire and tracking .....	21
22.17 Photometric data .....	22
22.18 Changeover operation .....	24
22.19 High temperature operation .....	24
22.20 Battery chargers for self-contained emergency luminaires .....	25
22.21 Test devices for emergency operation .....	25
Annex A (normative) <del>Batteries</del> ESSs for self-contained emergency luminaires .....	26
Annex B (normative) Luminaire classification .....	31
Annex C (normative) Luminance measurements .....	33
Annex D (informative) Rest mode and <del>inhibition</del> remote inhibiting mode facilities .....	34
Annex E (normative) Requirements for self-contained portable emergency luminaires .....	36
Bibliography .....	41
Figure C.1 – Typical example of measurement positions .....	33
<del>Table 1 – Voltage limits for discharge durations up to the end of declared battery life .....</del>	<del>20</del>
Table 1 – Voltage per cell to which the battery is discharged .....	20
Table D.1 – Time scale rest mode and inhibiting mode versus status of normal mains supply .....	35

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

### LUMINAIRES –

### Part 2-22: Particular requirements – Luminaires for emergency lighting

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

**This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 60598-2-22:2014+AMD1:2017 CSV. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.**

IEC 60598-2-22 has been prepared by subcommittee 34D: Luminaires of IEC technical committee 34: Lighting. It is an International Standard.

This fifth edition cancels and replaces the fourth edition published in 2014 and Amendment 1:2017. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) update of requirements for rest mode and inhibiting mode;
- b) clarification of high temperature operation tests;
- c) introduction of new requirements for lithium batteries;
- d) introduction of new requirements for electric double layer capacitors (EDLCs);
- e) clarification of resistance to heat, fire and tracking;
- f) clarification of test facilities for self-contained luminaires;
- g) clarification of the test method for contrast measurements of exit signs.

The text of this International Standard is based on the following documents:

Draft	Report on voting
34D/1635/FDIS	34D/1642/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/standardsdev/publications](http://www.iec.ch/standardsdev/publications).

This Part 2-22 is to be used in conjunction with the latest edition of IEC 60598-1 and its amendment(s). It was established on the basis of the ninth edition (2020) of that standard.

NOTE 1 When "Part 1" is mentioned in this document, it refers to IEC 60598-1.

NOTE 2 In this document, the following print type is used:

- compliance statements: *in italic type*.

A list of all parts in the IEC 60598 series, published under the general title *Luminaires*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](https://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

**iTeh Standards**  
**(<https://standards.iteh.ai>)**  
**Document Preview**

[IEC 60598-2-22:2021](https://standards.iteh.ai/catalog/standards/iec/e82a3455-32bc-47f9-bcea-d69da9851310/iec-60598-2-22-2021)

<https://standards.iteh.ai/catalog/standards/iec/e82a3455-32bc-47f9-bcea-d69da9851310/iec-60598-2-22-2021>

## INTRODUCTION to Amendment 1

The light output of LED light sources depends also on the temperature at which it is operated. Typically the temperature is controlled by a heat sink on which it is mounted (e.g. luminaire surface).

For this reason, the calculation of the ratio of the electrical parameter ( $EOF_x$ ) will be introduced in the LED controlgear standards IEC 61347-2-13 and IEC 61347-2-7, as the direct measurement of EBLF is not practicable.

In particular  $EOF_I$  is defined as the ratio of the current in emergency mode from constant current controlgear divided by the nominal current of LED ( $I_{\text{normal mode}}$ ):

$$EOF_I = I_{\text{emergency}} / I_{\text{normal mode}}$$

Knowing that the light output of an LED light source is nearly<sup>4</sup> directly proportional with the forward current flowing through it, it is possible to calculate the luminous flux of the luminaire in emergency mode by using the  $EOF_I$  or  $I_{\text{emergency}}$  from constant current controlgear.

This document contains a proposal for the modification of IEC 60598-2-22 to use the factor  $EOF_I$  or  $I_{\text{emergency}}$  in the luminaire.

iTeh Standards  
(<https://standards.itih.ai>)  
Document Preview

[IEC 60598-2-22:2021](#)

<https://standards.itih.ai/catalog/standards/iec/e82a3455-32bc-47f9-bcea-d69da9851310/iec-60598-2-22-2021>

---

<sup>4</sup> Any non-linearity due to the increased efficacy at lower operation temperature leads to an increased tolerance of the light output in the emergency mode but always positive.



## LUMINAIRES –

### Part 2-22: Particular requirements – Luminaires for emergency lighting

#### 22.1 Scope

This part of IEC 60598 specifies requirements for emergency luminaires for use with electrical lamps on emergency power supplies not exceeding 1 000 V.

This document does not cover the effects of non-emergency voltage reductions on luminaires incorporating high pressure discharge lamps.

This document gives general requirements for emergency lighting equipment.

In this document, the term "lamp" which also includes "light source(s)" where appropriate, is used.

#### 22.2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60073, *Basic and safety principles for man-machine interface, marking and identification – Coding principles for ~~indication devices~~ indicators and actuators*

<https://standards.ieh.ai/catalog/standards/iec/e82a3455-32bc-47f9-bcea-d69da9851310/iec-60598-2-22-2021>

IEC 60155, *Glow-starters for fluorescent lamps*

IEC 60598-1, *Luminaires – Part 1: General requirements and tests*

IEC 60896-21, *Stationary lead-acid batteries – Part 21: Valve regulated types – Methods of test*

IEC 61032:1997, *Protection of persons and equipment by enclosures – Probes for verification*

IEC 61056-1, *General purpose lead-acid batteries (valve-regulated types) – Part 1: General requirements, functional characteristics – Methods of test*

IEC TR 61341, *Method of measurement of centre beam intensity and beam angle(s) of reflector lamps*

IEC 61347-2-2, *Lamp controlgear – Part 2-2: Particular requirements for d.c. or a.c. supplied electronic step-down convertors for filament lamps*

IEC 61347-2-3:2011, *Lamp control gear – Part 2-3: Particular requirements for a.c. and/or d.c. supplied electronic control gear for fluorescent lamps*

IEC 61347-2-7:2011, *Lamp controlgear – Part 2-7: Particular requirements for battery supplied electronic controlgear for emergency lighting (self-contained)*

IEC 61347-2-7:2011/AMD1:2017

IEC 61347-2-7:2011/AMD2:2021

IEC 61347-2-12, *Lamp controlgear – Part 2-12: Particular requirements for d.c. or a.c. supplied electronic ballasts for discharge lamps (excluding fluorescent lamps)*

IEC 61347-2-13, *Lamp controlgear – Part 2-13: Particular requirements for d.c. or a.c. supplied electronic controlgear for LED modules*

IEC 61951-1, *Secondary cells and batteries containing alkaline or other non-acid electrolytes-~~Portable sealed rechargeable single cells~~ – Secondary sealed cells and batteries for portable applications – Part 1: Nickel-Cadmium*

IEC 61951-2, *Secondary cells and batteries containing alkaline or other non-acid electrolytes-~~Portable sealed rechargeable single cells~~ – Secondary sealed cells and batteries for portable applications – Part 2: Nickel-metal hydride*

IEC 62034, *Automatic test systems for battery powered emergency escape lighting*

IEC 62133-2:2017, *Secondary cells and batteries containing alkaline or other non-acid electrolytes – Safety requirements for portable sealed secondary lithium cells, and for batteries made from them, for use in portable applications – Part 2: Lithium systems*

IEC 62391-1:2015, *Fixed electric double-layer capacitors for use in electric and electronic equipment – Part 1: Generic specification*

IEC 62391-2:2006, *Fixed electric double-layer capacitors for use in electronic equipment – Part 2: Sectional specification – Electric double-layer capacitors for power application*

IEC 62620:2014, *Secondary cells and batteries containing alkaline or other non-acid electrolytes – Secondary lithium cells and batteries for use in industrial applications*

~~ISO 3864-1:2011, Graphical symbols — Safety colours and safety signs. Part 1: Design principles for safety signs and safety markings~~

ISO 3864-4:2011, *Graphical symbols – Safety colours and safety signs – Part 4: Colorimetric and photometric properties of safety sign materials*

ISO 30061:2007, *Emergency lighting*

CIE 121 SP1, ~~The photometry of emergency luminaires~~ *The Photometry and Goniophotometry of Luminaires – Supplement 1: Luminaires for Emergency Lighting*

CIE S025, *Test Method for LED Lamps, LED Luminaires and LED Modules*

### 22.3 Terms and definitions

For the purposes of this document, the terms and definitions given in Part 1 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>

- ISO Online browsing platform: available at <http://www.iso.org/obp>

### 22.3.1

#### **emergency lighting**

lighting for use when the supply to the normal lighting fails

Note 1 to entry: Emergency lighting includes emergency escape lighting, high-risk task-area lighting and standby lighting.

### 22.3.2

#### **emergency escape lighting**

that part of emergency lighting that provides illumination for the safety of people leaving an area or attempting to terminate a dangerous process before vacating an area

### 22.3.3

#### **standby lighting**

that part of emergency lighting that enables normal activities to continue substantially unchanged

### 22.3.4

#### **high-risk task-area lighting**

part of emergency lighting provided to ensure the safety of people involved in a potentially dangerous process or situation and to enable proper shut-down procedures for the safety of the operator and occupants of the premises

### 22.3.5

#### **maintained emergency luminaire**

luminaire in which the emergency lighting lamps are energized at all times when normal or emergency lighting is required

### 22.3.6

#### **non-maintained emergency luminaire**

luminaire in which the emergency lighting lamps are in operation only when the supply to the normal lighting fails

### 22.3.7

#### **combined emergency luminaire**

luminaire containing two or more lamps, at least one of which is energized from the emergency lighting supply and the others from the normal lighting supply

Note 1 to entry: A combined emergency luminaire is either maintained or non-maintained.

### 22.3.8

#### **self-contained emergency luminaire**

luminaire providing maintained or non-maintained emergency lighting in which all the elements, such as ~~the battery~~ the electric source for safety services (ESSS), the lamp, the control unit and the test and monitoring facilities, where provided, are contained within the luminaire or adjacent to it (that is, within 1 m cable length)

### 22.3.9

#### **centrally supplied emergency luminaire**

luminaire for maintained or non-maintained operation which is energized from a central emergency power system that is not contained within the luminaire

### 22.3.10

#### **compound self-contained emergency luminaire**

self-contained luminaire providing maintained or non-maintained emergency lighting and also providing emergency supply for operating a satellite luminaire

### 22.3.11

#### **satellite emergency luminaire**

luminaire for maintained or non-maintained operation which derives emergency operation supply from an associated compound self-contained emergency luminaire

### 22.3.12

#### **control unit**

unit or set of units comprising a supply changeover system, ~~a battery~~ an electric source for safety services (ESSS) charging device and, where appropriate, a means for testing

Note 1 to entry: This unit ~~may~~ can also contain the lamp control gear.

### 22.3.13

#### **normal supply failure**

condition in which the normal lighting can no longer provide a minimum illuminance for emergency escape purposes and when the emergency lighting should become operative

### 22.3.14

#### **emergency luminaire rated luminous flux**

lumen output as claimed by the luminaire manufacturer, 60 s (0,5 s for high-risk task-area luminaires) after failure of the normal supply, and continuously maintained to the end of the rated duration of operation

### 22.3.15

#### **rated duration of emergency operation**

time, as claimed by the manufacturer, during which the rated emergency lumen output is provided

### 22.3.16

#### **normal mode**

state of a self-contained emergency luminaire that is ready to operate in emergency mode while the normal supply is on

<https://standards.iteh.ai/>  
IEC 60598-2-22:2021

<https://standards.iteh.ai/> Note 1 to entry: In the case of a normal supply failure, the self-contained luminaire automatically changes over to the emergency mode.

### 22.3.17

#### **emergency mode**

state of a self-contained emergency luminaire that provides lighting when energized by its internal power source, the normal supply having failed

### 22.3.18

#### **rest mode**

state of a self-contained emergency luminaire that has been intentionally extinguished while the normal supply is off and that, in the event of restoration of the normal supply, automatically reverts to normal mode

### 22.3.19

#### **maximum overcharge rate**

maximum continuous charge rate (e.g. current or voltage) that ~~may~~ can be applied to a fully charged ~~battery~~ electric source for safety services (ESSS)

### 22.3.20

#### **remote inhibiting facility**

means for inhibiting remotely a luminaire associated with an emergency lighting system

**22.3.21****remote inhibiting mode**

state of a self-contained emergency luminaire which is inhibited from operating by a remote device while the normal supply is on and in the case of a normal supply failure when the luminaire does not change over to emergency mode

**22.3.22****internally illuminated safety sign**

self-contained or centrally supplied emergency luminaire intended to provide a specific safety message obtained by a combination of colour and geometric shapes

Note 1 to entry: Details are given in ISO 3864-1 and ISO 3864-4.

**22.3.23****practical emergency lamp flux**

## PELF

minimum luminous flux of the lamp observed during the rated duration of the emergency mode

Note 1 to entry:  $PELF = LDL \times EBLF$

where LDL is the rated luminous flux of fluorescent or discharge lamp; this is taken as the initial lighting design lumens at 100 h.

~~Note 2 to entry:— This note applies to the French language only.~~

**22.3.24****self-contained portable emergency luminaire**

portable luminaire providing emergency lighting where all of the elements, such as ~~the battery~~ **the electric source for safety services (ESSS)**, the lamp(s), the control unit, a manual switch for switching on or off one or more lamp and the test and monitoring facilities, where provided, are contained within the luminaire which can be detached from its base unit for use in the emergency mode

**22.3.25****emergency ballast lumen factor**

## EBLF

ratio of the emergency luminous flux of the lamp supplied by the emergency controlgear to the luminous flux of the same lamp operated with the appropriate reference ballast at its rated voltage and frequency

Note 1 to entry: The emergency ballast lumen factor is the minimum of the values measured at the appropriate time after failure of the normal supply and continuously to the end of the rated time duration.

~~Note 2 to entry:— This note applies to the French language only.~~

[SOURCE: IEC 61347-2-7:2011, 3.13]

**22.3.26****emergency luminaire mounted on lighting track system**

emergency luminaire specifically designed to be used on luminaire track systems

**22.3.27****emergency remote box**

box complying with the same requirements as the emergency luminaire

Note 1 to entry: Its purpose is to contain any of the components e.g. battery, controlgear that will not be fitted into the emergency luminaire.

**22.3.28****practical emergency light source flux**

## PELSF

minimum luminous flux of the light source observed during the rated duration of the emergency mode

Note 1 to entry: For LED light sources:

- a) if  $EOF_1$  is given:  $PELSF = LDL \times EOF_1$
- b) if  $I_{\text{emergency}}$  from constant current controlgear is defined:  $PELSF = LDL \times (I_{\text{emergency}} / I_{\text{normal mode}})$   
where LDL is the lumen output of the LED module under the condition corresponding to the operation in the luminaire (identical  $t_p$ ) operated at the same current ( $I_{\text{normal mode}}$ ).

~~Note 2 to entry: This note only applies to the French language.~~

### 22.3.29

#### **battery manufacturer's declaration of design**

document issued by the battery manufacturer that provides technical information necessary to evaluate the safe use of the battery and its operating regime in accordance with the requirements of this document

Note 1 to entry: Examples of the battery manufacturer's declaration of design for a lithium battery is given in IEC 61347-2-7.

### 22.3.30

#### **rated capacity**

capacity value of a battery determined under specified conditions and declared by the manufacturer

[SOURCE: IEC 60050-482:2004, 482-03-15]

### 22.3.31

#### **electric source for safety services**

#### **ESSS**

energy source for self-contained luminaire, intended to supply the emergency lighting luminaire in emergency mode

Note 1 to entry: The ESSS can also supply the luminaire in rest mode and inhibiting mode.

### 22.3.32

#### **electric double-layer capacitor**

[IEC 60598-2-22:2021](#)

#### **EDLC**

device that stores electrical energy using a double-layer in an electrochemical cell

## 22.4 General test requirements

The provisions of Section 0 of Part 1 shall apply. The tests described in each appropriate section of Part 1 shall be carried out in the order listed in this document.

When testing combined emergency luminaires in accordance with the requirements of this document, the tests shall cover those parts of the luminaire which are involved with providing emergency lighting taking into account the influence of all other luminaire parts and components. The components and parts of the luminaires designed to provide only normal lighting shall be subjected to the tests in accordance with the requirements of the relevant part of IEC 60598-2 (for example, if the luminaire is recessed, it shall be tested in accordance with the requirements of the part dealing with recessed luminaires).

If some elements of an emergency luminaire are adjacent (within a 1 m cable length) to the main part of the luminaire, all the elements of the luminaire, including the means of inter-connection, shall satisfy the relevant requirements of this document.

The additional requirements covering self-contained portable emergency luminaires are given in Annex E.

The photometric tests of Clause 22.17 shall be made on a separate sample luminaire.