

Edition 2.0 2020-06

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Electrical safety in low voltage distribution systems up to 1,000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures – Part 11: Effectiveness of residual current monitors (RCM) in TT, TN and IT systems https://standards.iteh.ai/catalog/standards/sist/0e70466f-ae69-4787-951ecae004af7598/iec-61557-11-2020

Sécurite électrique dans les réseaux de distribution basse tension au plus égale à 1 000 V c.a. et 1 500 V c.c. – Dispositifs de contrôle, de mesure ou de surveillance de mesures de protection –

Partie 11: Efficacité des contrôleurs d'isolement à courant différentiel résiduel (RCM) dans les réseaux TT, TN et IT





THIS PUBLICATION IS COPYRIGHT PROTECTED Copyright © 2020 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office 3, rue de Varembé CH-1211 Geneva 20 Switzerland Tel.: +41 22 919 02 11 info@iec.ch www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on line and 57. once a month by email. https://standards.iteh.ai/catalog/standards.iteh.ai/

IEC Customer Service Centre - webstore.iec.ch/csc⁷⁵⁹⁸/iec- collected from earlier publications of IEC TC 37, 77, 86 and If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.



Edition 2.0 2020-06

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Electrical safety in low voltage distribution systems up to 1000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures – Part 11: Effectiveness of residual current monitors (RCM) in TT, TN and IT systems https://standards.iteh.ai/catalog/standards/sist/0e70466f-ae69-4787-951ecae004af7598/iec-61557-11-2020

Sécurite électrique dans les réseaux de distribution basse tension au plus égale à 1 000 V c.a. et 1 500 V c.c. – Dispositifs de contrôle, de mesure ou de surveillance de mesures de protection –

Partie 11: Efficacité des contrôleurs d'isolement à courant différentiel résiduel (RCM) dans les réseaux TT, TN et IT

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMISSION ELECTROTECHNIQUE INTERNATIONALE

ICS 17.220.20; 29.080.01; 29.240.01

ISBN 978-2-8322-8496-4

Warning! Make sure that you obtained this publication from an authorized distributor. Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

 Registered trademark of the International Electrotechnical Commission Marque déposée de la Commission Electrotechnique Internationale

CONTENTS

| F | OREWO | RD | 3 | | | |
|--|----------|--|----|--|--|--|
| 1 | Scop | e | 5 | | | |
| 2 | Norm | ative references | 5 | | | |
| 3 | Term | Terms and definitions | | | | |
| 4 | Requ | Requirements | | | | |
| 4.1 General | | | | | | |
| | 4.2 | Functions | 7 | | | |
| | 4.2.1 | Operating test | 7 | | | |
| | 4.2.2 | Non-operating test | 10 | | | |
| | 4.2.3 | Test of actuating time | 10 | | | |
| | 4.3 | Fault voltages exceeding $U_{\sf L}$ | 10 | | | |
| | 4.4 | Overvoltage | 10 | | | |
| 5 | Mark | ing and operating instructions | 11 | | | |
| | 5.1 | Markings | 11 | | | |
| | 5.2 | Operating instructions | 11 | | | |
| | 5.2.1 | General | 11 | | | |
| | 5.2.2 | Information | 11 | | | |
| | 5.2.3 | Warnings Ell STANDARD FREVIEW | 11 | | | |
| 6 | Tests | (standards.iteh.ai) | 11 | | | |
| | 6.1 | General | 11 | | | |
| | 6.2 | Operating uncertainty | 12 | | | |
| | 6.3 | Test of protection against high fault voltages 70466f.ac69-4787-951e- | 13 | | | |
| | 6.4 | Test of overvoltage | 13 | | | |
| Bibliography14 | | | | | | |
| | | | | | | |
| Fi | gure 1 - | - Maximum step size of increasing smooth direct test current (I_{T}) | 8 | | | |
| Figure 2 – Maximum gradient of linearly increasing smooth direct test current (I_T)9 | | | | | | |
| Fi | gure 3 - | - Example for linearly increasing smooth direct test current ($I_{\sf T}$): $I_{\Delta \sf n}$ = 30 mA | 9 | | | |

| Table 1 – Calo | culation of operating | uncertainty | 1 | 13 |
|----------------|-----------------------|-------------|---|----|
|----------------|-----------------------|-------------|---|----|

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRICAL SAFETY IN LOW VOLTAGE DISTRIBUTION SYSTEMS UP TO 1 000 V AC AND 1 500 V DC – EQUIPMENT FOR TESTING, MEASURING OR MONITORING OF PROTECTIVE MEASURES –

Part 11: Effectiveness of residual current monitors (RCM) in TT, TN and IT systems

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- In order to promote international uniformity, JEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61557-11 has been prepared by IEC technical committee 85: Measuring equipment for electrical and electromagnetic quantities.

This second edition cancels and replaces the first edition published in 2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) document title modified to include all types of RCM;
- b) terms aligned with IEC 60050;
- c) addition of requirements for testing new types of RCM;
- d) moving of requirements for RCM Type B from former Annex A to main body text;

e) alignment of the structure with that of the whole IEC 61557 series.

The text of this International Standard is based on the following documents:

| FDIS | Report on voting |
|-------------|------------------|
| 85/720/FDIS | 85/722/RVD |

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

This International Standard is to be used in conjunction with IEC 61557-1:2019.

A list of all parts in the IEC 61557 series, published under the general title *Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,

iTeh STANDARD PREVIEW

- replaced by a revised edition standards.iteh.ai)
- amended.

<u>IEC 61557-11:2020</u> https://standards.iteh.ai/catalog/standards/sist/0e70466f-ae69-4787-951ecae004af7598/iec-61557-11-2020

ELECTRICAL SAFETY IN LOW VOLTAGE DISTRIBUTION SYSTEMS UP TO 1 000 V AC AND 1 500 V DC – EQUIPMENT FOR TESTING, MEASURING OR MONITORING OF PROTECTIVE MEASURES –

Part 11: Effectiveness of residual current monitors (RCM) in TT, TN and IT systems

1 Scope

This part of IEC 61557 specifies the requirements for test equipment applied to the testing of the effectiveness of residual current monitors (RCM) that are already installed in distribution systems.

This test equipment can be used in any kind of network, such as a TN, TT or IT system. The test equipment can also be used for testing directionally discriminating residual current monitors (RCM) in IT systems.

It is not the purpose of this document to verify the residual current monitors (RCM) according to their product standardseh STANDARD PREVIEW

2 Normative references (standards.iteh.ai)

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61010-1:2010, Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 1: General requirements

IEC 61557-1:2019, Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures – Part 1: General requirements

IEC 61557-6, Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures – Part 6: Effectiveness of residual current devices (RCD) in TT, TN and IT systems

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61557-1, IEC 61557-6, and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

- 6 -

3.1

earth fault current

current flowing to earth due to an insulation fault

[SOURCE: IEC 60050-442:1998, 442-01-23]

3.2

test current

 I_{T}

current superimposed by the test equipment for testing the effectiveness of the RCM

3.3

residual current

 I_{Δ}

RMS value of the vector sum of the currents flowing through the main circuit of the residual current device due to an insulation fault

[SOURCE: IEC 60050-442:2019, 442-05-19, modified – The wording "instantaneous values" has been deleted from the definition and "due to an insulation fault" has been added.]

3.4

rated residual operating current

 $I_{\Delta n}$

value of residual operating current assigned to the RCM by the manufacturer at which the RCM operates under specified conditions

(standards.iteh.ai)

3.5

residual operating current

IEC 61557-11:2020

 $I_{\Delta 0}$ https://standards.iteh.ai/catalog/standards/sist/0e70466f-ae69-4787-951e-value of residual current which causes4the residual current2monitoring device to operate under specified conditions

[SOURCE: IEC 60050-442:2019, 442-05-20, modified: "residual current device" has been replaced with "residual current monitoring device" and symbol " $I_{\Delta n}$ " has been replaced with " $I_{\Lambda o}$ ".]

3.6

residual non-operating current

value of residual current at and below which the RCM does not operate under specified conditions

[SOURCE: IEC 60050-442:2019, 442-05-21, modified – "residual current device" has been replaced with "RCM" and the symbol has been omitted.]

3.7

actuating time

t_a

time taken for an RCM to change from the non-alarm state to the alarm state in response to the sudden appearance of a residual current which exceeds the preset level

[SOURCE: IEC 62020-1:2020, 3.1.6, modified – The symbol has been added.]

3.8 residual current monitor

RCM

device or association of devices which monitors the residual current in an electrical installation, and which activates an alarm when the residual current exceeds the operating value of the device

[SOURCE: IEC 62020-1:2020, 3.1.1]

3.9

RCM Type A

type of RCM for which monitoring is ensured for residual sinusoidal alternating currents and residual pulsating direct currents, whether suddenly applied or slowly rising

[SOURCE: IEC 62020-1:2020, 5.2.6.2, modified – The words "initiating an alarm" have been replaced with "monitoring".]

3.10

RCM Type B

type of RCM for which monitoring is ensured for residual sinusoidal alternating currents, with residual pulsating direct currents and smooth residual direct currents independent of polarity, whether suddenly applied or slowly rising

Note 1 to entry: RCM Type B are described in IEC 62020-1:2020, 5.2.6.4.

3.11

directionally discriminating Rcmandards.iteh.ai)

type of RCM having the ability to discriminate between supply side and load side residual currents of the monitored lines, as declared by the manufacturer

Note 1 to entry: Directionally discriminating RCM are described in IEC 62020-1.

[SOURCE: IEC 62020-1:2020, 3.1.10]

4 Requirements

4.1 General

In addition to the requirements of IEC 61557-1:2019, Clause 4, the requirements of Clause 4 of this document shall apply.

4.2 Functions

4.2.1 Operating test

The testing equipment shall be capable of verifying that the residual operating current of an RCM Type A tested with an AC test current is less than or equal to the value of the rated residual operating current.

Testing of an RCM Type A shall be conducted with a calibrated AC current suddenly applied at a zero crossing.

The tests shall be carried out with a sinusoidal, or mains-derived quasi-sinusoidal, test current.

If the test equipment is capable of producing half-wave test currents, testing of an RCM Type A may be carried out alternatively with half-wave test currents and/or AC current with superimposed ±6 mA DC.

In the case of pulsed DC current, the test equipment shall be capable of testing in both polarities.

When testing an RCM Type B with a DC test current, it shall be verified that the residual operating current is less than or equal to 2 times the value of the rated residual operating current.

Testing of an RCM Type B shall be conducted separately with a suddenly applied, calibrated AC current and a linearly increasing smooth direct current.

The slope of the linear increase shall not be greater than 2 times $I_{\Lambda n}$ / 5 s.

If the slope of the linear increase is simulated by a stepwise or linearly increasing test current; the increase shall not be greater than 2 times $I_{\Delta n}$ / 30 (see Figure 1 to Figure 3).

In both cases, the starting current shall be less than 0,2 times $I_{\Lambda n}$.

The operating uncertainty of the increasing test current I_T shall not exceed ±10 % of the rated residual operating current $I_{\Lambda n}$.

The operating uncertainty of the calibrated test current I_T shall not exceed 0 % to +10 % of the rated residual operating current I_{AP} .

The test period shall be adapted to the set actuating time of the RCM and it shall be possible to extend the test period up to 10 s.



Figure 1 – Maximum step size of increasing smooth direct test current (I_T)

- 8 -



-9-

Figure 2 – Maximum gradient of linearly increasing smooth direct test current (I_T)





Key (for Figure 1 to Figure 3)

- t time
- $I_{\Delta n}$ rated residual operating current
- I_T smooth direct test current
- $\Delta I_{\rm T}$ slope of the linear increasing test current or steps of stepwise rising test current
- Δt time for one step for linearly increasing test current or time for steepness of continuous rising test current

A slow continuous or stepwise increase of the DC test current is required to prevent the AC sensitive part of the RCM Type B from operating during the DC test.

Example for ΔI_{T} = 2 mA: \geq 167 ms

Example for $\Delta I_{\rm T}$ = 0,5 mA: ≥ 42 ms

NOTE 1 Existing leakage currents downstream can influence the verification.

NOTE 2 The actual rise time depends on the system capacitance and the resistive load of the test equipment.

NOTE 3 Smooth DC test current refers to direct current with AC ripple up to 10 % (peak to peak).

4.2.2 Non-operating test

When a test at 50 % or less of the rated residual operating current is used to test the reliability of the RCM is included, the minimum test period shall be 10 s. The alarm shall not be activated.

When a non-operating test at 50 % or less of the rated residual operating current is included, the operating uncertainty of the calibrated test current shall not exceed 0 % to -10 % of the specified non-operating test current.

NOTE Existing leakage currents downstream can influence the verification.

4.2.3 Test of actuating time

If the set actuating time of the RCM is being tested with the test equipment, the setting of the test period on the test device shall have a resolution of minimum 0,5 s ranging up to 10 s. The setting uncertainty shall not exceed 0 % to -10 % of the set value. The test shall solely be performed with calibrated AC test current.

Other methods for the acquisition of the actuating time via optical recognition or interfacing are permissible.

NOTE The general function of RCMs is not to disconnect the power supply when a residual current above the value of the rated residual operating current occurs. The RCM indicates the increase of the residual current above the residual operating current with a signalling device, for example a lamp, buzzer, contact relay or interface-signal. Thus, the response time can only be tested via the visual or additional electrical detection of this signal.

According to IEC 62020-1, the actuating time of the RCM may only amount to a maximum of 10 s. The response time shall be specified by the manufacturer or shall be adjustable on the device. https://standards.iteh.a/catalog/standards/sist/0e70466f-ae69-4787-951ecae004af7598/iec-61557-11-2020

If the RCM is being used for the purpose of disconnection, the tests covered by IEC 61557-6 shall apply.

4.3 Fault voltages exceeding U_{L}

Prevention of danger due to fault voltages exceeding U_{L} within the system under test shall be ensured during the use of the test equipment. This can be achieved as follows:

- automatic disconnection in accordance with IEC 61010-1:2010, Figure 1, if the residual voltage is above 50 V AC or 120 V DC;
- application of test current I_T, gradually or permanently adjustable, where the test starts with a maximum current of 3,5 mA AC or 15 mA DC in accordance with IEC 61010-1:2010, 6.3.2 b), including parallel test circuits, is permitted. The possibility to change the test current I_T without generating a dangerous fault voltage shall be clearly identifiable, for instance on a voltmeter;
- in special locations, the touch voltage limit is 25 V AC or 60 V DC;
- the operating uncertainty for the detection of the fault voltage shall not exceed 0 % to -20 % of the limit.

4.4 Overvoltage

If the system is connected to 120 % of the nominal voltage of the system for which the test equipment is designed, neither the operator shall be harmed, nor the device be damaged. Protective devices shall not be activated. If the device is intended to be used in IT systems, the nominal voltage of the test equipment is the line-to-line voltage.