

INTERNATIONAL STANDARD



Determination of power losses in high-voltage direct current (HVDC) converter stations with line-commutated converters

(<https://standards.iteh.ai>)
Document Preview

IEC 61803:2020

<https://standards.iteh.ai/catalog/standards/iec/c4a1b1c6-86d0-403d-9240-813f47119b58/iec-61803-2020>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2020 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

[IEC 61803:2020](https://standards.iteh.ai/catalog/standards/iec/c4a1b1c6-86d0-403d-9240-813f47119b58/iec-61803-2020)

<https://standards.iteh.ai/catalog/standards/iec/c4a1b1c6-86d0-403d-9240-813f47119b58/iec-61803-2020>



IEC 61803

Edition 2.0 2020-10
REDLINE VERSION

INTERNATIONAL STANDARD



Determination of power losses in high-voltage direct current (HVDC) converter stations with line-commutated converters

iteh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 61803:2020](#)

<https://standards.iteh.ai/catalog/standards/iec/c4a1b1c6-86d0-403d-9240-813f47119b58/iec-61803-2020>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.200

ISBN 978-2-8322-8970-9

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	4
1 Scope	6
2 Normative references	6
3 Terms, definitions and symbols	6
3.1 Terms and definitions	7
3.2 Symbols	8
4 Overview	9
4.1 General	9
4.2 Ambient conditions	9
4.2.1 General	9
4.2.2 Outdoor standard reference temperature	9
4.2.3 Coolant standard reference temperature	10
4.2.4 Standard reference air pressure	10
4.3 Operating parameters	10
5 Determination of equipment losses	11
5.1 Thyristor valve losses	11
5.1.1 General	11
5.1.2 Thyristor conduction loss per valve	11
5.1.3 Thyristor spreading loss per valve	12
5.1.4 Other conduction losses per valve	13
5.1.5 DC voltage-dependent loss per valve	13
5.1.6 Damping loss per valve (resistor-dependent term)	14
5.1.7 Damping loss per valve (change of capacitor energy term)	15
5.1.8 Turn-off losses per valve	15
5.1.9 Reactor loss per valve	16
5.1.10 Total valve losses	16
5.1.11 Temperature effects	16
5.1.12 No-load operation loss per valve	17
5.2 Converter transformer losses	17
5.2.1 General	17
5.2.2 No-load operation losses	17
5.2.3 Operating losses	17
5.2.4 Auxiliary power losses	19
5.3 AC filter losses	19
5.3.1 General	19
5.3.2 AC filter capacitor losses	19
5.3.3 AC filter reactor losses	20
5.3.4 AC filter resistor losses	20
5.3.5 Total AC filter losses	20
5.4 Shunt capacitor bank losses	20
5.5 Shunt reactor losses	21
5.6 DC smoothing reactor losses	21
5.7 DC filter losses	22
5.7.1 General	22
5.7.2 DC filter capacitor losses	22
5.7.3 DC filter reactor losses	22

5.7.4	DC filter resistor losses	23
5.7.5	Total DC filter losses	23
5.8	Auxiliaries and station service losses	23
5.9	Radio interference/PLC Series filter losses	24
5.10	Other equipment losses	25
Annex A	(normative informative) Calculation of harmonic currents and voltages	31
A.1	Harmonic currents in converter transformers	31
A.2	Harmonic currents in the AC filters	31
A.3	Harmonic voltages on the DC side	32
A.4	DC side harmonic currents in the smoothing reactor	32
Annex B	(informative) Typical station losses	33
Annex C	(informative) HVDC converter station loss evaluation – An illustration	34
C.1	General	34
C.2	Loss evaluation under various cases	35
Bibliography	37
Figure 1	– Typical high-voltage direct current (HVDC) equipment for one pole (auxiliary equipment is not shown)	26
Figure 2	– Simplified three-phase diagram of an HVDC 12-pulse converter	27
Figure 3	– Simplified equivalent circuit of a typical thyristor valve	27
Figure 4	– Current and voltage waveforms of a valve operating in a 12-pulse converter (commutation overshoots are not shown)	28
Figure 5	– Thyristor on-state characteristic	29
Figure 6	– Conduction current and voltage drop	29
Figure 7	– Distribution of commutating inductance between L_1 and L_2	30
Figure 8	– Thyristor current during reverse recovery	30
Table B.1	– Typical values of losses	33
Table C.1	– Conditions for calculation of losses in case D1	36
Table C.2	– Conditions for calculation of losses in Case D2	36

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**DETERMINATION OF POWER LOSSES IN HIGH-VOLTAGE
DIRECT CURRENT (HVDC) CONVERTER STATIONS WITH
LINE-COMMUTATED CONVERTERS**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

International Standard IEC 61803 has been prepared by subcommittee 22F: Power electronics for electrical transmission and distribution systems, of IEC technical committee 22: Power electronic systems and equipment.

This second edition cancels and replaces the first edition published in 1999, Amendment 1:2010 and Amendment 2:2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) to facilitate the application of this document and to ensure its quality remains consistent, 5.1.8 and 5.8 have been reviewed, taking into consideration that the present thyristor production technology provides considerably less thyristor parameters dispersion comparing with the situation in 1999 when the first edition of IEC 61803 was developed, and therefore the production records of thyristors can be used for the power losses calculation;
- b) the calculation of the total station load losses (cases D1 and D2 in Annex C) has been corrected.

The text of this International Standard is based on the following documents:

CDV	Report on voting
22F/563/CDV	22F/580A/RVC

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

DETERMINATION OF POWER LOSSES IN HIGH-VOLTAGE DIRECT CURRENT (HVDC) CONVERTER STATIONS WITH LINE-COMMUTATED CONVERTERS

1 Scope

This document applies to all line-commutated high-voltage direct current (HVDC) converter stations used for power exchange (power transmission or back-to-back installation) in utility systems. This document presumes the use of 12-pulse thyristor converters but can, with due care, also be used for 6-pulse thyristor converters.

In some applications, synchronous compensators or static var compensators (SVC) may be connected to the AC bus of the HVDC converter station. The loss determination procedures for such equipment are not included in this document.

This document presents a set of standard procedures for determining the total losses of an HVDC converter station. ~~Typical HVDC equipment is shown in figure 1.~~ The procedures cover all parts, except as noted above, and address no-load operation and operating losses together with their methods of calculation which use, wherever possible, measured parameters.

Converter station designs employing novel components or circuit configurations compared to the typical design assumed in this document, or designs equipped with unusual auxiliary circuits that could affect the losses, ~~shall be~~ are assessed on their own merits.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60076-1:1993, *Power transformers – Part 1: General*

IEC 60076-6, *Power transformers – Part 6: Reactors*

~~IEC 60289:1988, *Reactors*~~

~~IEC 60633:1998, *Terminology for high-voltage direct current (HVDC) transmission*~~

IEC 60633, *High-voltage direct current (HVDC) transmission – Vocabulary*

IEC 60700-1:1998/2015, *Thyristor valves for high voltage direct current (HVDC) power transmission – Part 1: Electrical testing*

~~IEC 60747-6:1983, *Semiconductor devices – Discrete devices – Part 6: Thyristors*~~

IEC 60871-1:1997, *Shunt capacitors for a.c. power systems having a rated voltage above 1 000 V – Part 1: General ~~performance, testing and rating – Safety requirements – Guide for installation and operation~~*

3 Terms, definitions and symbols

~~For the purpose of this International Standard, the following definitions apply:~~

For the purposes of this document, the terms and definition given in IEC 60633 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1 Terms and definitions

3.1.1

auxiliary losses

electric power required to feed the converter station auxiliary loads

Note 1 to entry: The auxiliary losses depend on the number of converter units used and whether the station is in no-load operation or carrying load, in which case the auxiliary losses depend on the load level.

3.1.2

equipment no-load operation losses

losses produced in an item of equipment with the converter station energised but with the converters blocked and all station service loads and auxiliary equipment connected as required for immediate pick-up of load to specified minimum power

3.1.3

load level

direct current, direct voltage, firing angle, AC voltage, and converter transformer tap-changer position at which the converter station is operating

3.1.4

equipment operating losses

losses produced in an item of equipment at a given load level with the converter station energised and the converters operating

3.1.5

rated load

load related to operation at nominal values of DC current, DC voltage, AC voltage and converter firing angle

Note 1 to entry: The AC system shall be assumed to be at nominal frequency, and its 3-phase voltages are nominal and balanced. The position of the tap-changer of the converter transformer and the number of AC filters and shunt reactive elements connected shall be consistent with operation at rated load, coincident with nominal conditions.

3.1.6

total station no-load operation losses

~~the total station loss is the sum of all operating or no-load operation losses and the corresponding auxiliary losses~~

sum of all equipment no-load operation losses (3.1.2) and corresponding auxiliary losses (3.1.1)

3.1.7

total station operating losses

sum of all equipment operating losses (3.1.4) and corresponding auxiliary losses (3.1.1) at a particular load level

Note 1 to entry: An illustrative example using total station operating losses and corresponding loss evaluation is given in Annex C, case D1.

3.1.8

total station load losses

difference between total station operating losses (3.1.7) and total station no-load operation losses (3.1.6)

Note 1 to entry: Such calculated total station load losses are considered as being quantitatively equivalent to load losses as in conventional AC substation practice.

Note 2 to entry: It is recognized that some purchasers evaluate total station no-load operation losses (3.1.6) and total station load losses individually instead of the evaluating total station operating losses (3.1.7).

Note 3 to entry: An illustrative example to derive load losses, equivalent load losses and corresponding loss evaluation is given in Annex C, case D2.

3.1.9

station essential auxiliary load

load whose failure will affect the conversion capability of the HVDC converter station (e.g. valve cooling), as well as load that shall remain working in case of complete loss of AC power supply (e.g. battery chargers, operating mechanisms)

3.2 Symbols

α	(trigger/firing) delay angle, in radians (rad)
μ	commutation overlap angle, in radians (rad)
f	AC system frequency, in hertz (Hz)
I_d	direct current in the bridge d.c. connection, in amperes (A)
I_n	harmonic RMS current of order n , in amperes (A)
L_1	inductance, in henrys (H), referred to the valve winding, between the commutating voltage source and the point of common coupling between star- and delta-connected windings. L_1 shall include any external inductance between the transformer line-winding terminals and the point of connection of the AC harmonic filters.
L_2	inductance, in henrys (H), referred to the valve winding, between the point of common coupling between star- and delta-connected windings, and the valve. L_2 shall include the saturated inductance of the valve reactors.
m	electromagnetic notch coupling factor, $m = L_1/(L_1 + L_2)$
n	harmonic order
N_t	number of series-connected thyristors per valve
P	power loss in an item of equipment, in watts (W)
Q_n	quality factor at harmonic order n
R	resistance value, in ohms (W) (Ω)
U_d	direct voltage, in volts (V)
U_n	harmonic RMS voltage of order n , in volts (V)
U_{vo}	RMS value of the phase-to-phase no-load voltage on the valve side of the converter transformer excluding harmonics , in volts (V)
X_n	inductive reactance at harmonic order n , in ohms (Ω)

4 Overview

4.1 General

4.1—Introduction

Suppliers need to know in detail how and where losses are generated, since this affects component and equipment ratings. Purchasers are interested in a verifiable loss figure which allows equitable bid comparison and in a procedure after delivery which can objectively verify the guaranteed performance requirements of the supplier.

As a general principle, it would be desirable to determine the efficiency of an HVDC converter station by a direct measurement of its energy losses. However, attempts to determine the station losses by subtracting the measured output power from the measured input power should recognize that such measurements have an inherent inaccuracy, especially if performed at high voltage. The losses of an HVDC converter station at full load are generally less than 1 % of the transmitted power. Therefore, the loss measured as a small difference between two large quantities is not likely to be a sufficiently accurate indication of the actual losses.

In some special circumstances, it may be possible, for example, to arrange a temporary test connection in which two converters are operated from the same AC source and also connected together via their DC terminals. In this connection, the power drawn from the AC source equals the losses in the circuit. However, the AC source ~~must~~ shall also provide var support and commutating voltage to the two converters. Once again, there are practical measurement difficulties.

In order to avoid the problems described above, this document standardizes a method of calculating the HVDC converter station losses by summing the losses calculated for each item of equipment. The standardized calculation method will help the purchaser to meaningfully compare the competing bids. It will also allow an easy generation of performance curves for the wide range of operating conditions in which the performance has to be known. In the absence of an inexpensive experimental method which could be employed for an objective verification of losses during type tests, the calculation method is the next best alternative as it uses, wherever possible, experimental data obtained from measurements on individual equipment and components under conditions equivalent to those encountered in real operation.

The calculation of harmonic currents and voltages in HVDC equipment is described in Annex A.

It is important to note that the power loss in each item of equipment will depend on the ambient conditions under which it operates, as well as on the operating conditions or duty cycles to which it is subjected. Therefore, the ambient and operating conditions shall be defined for each item of equipment, based on the ambient and operating conditions of the entire HVDC converter station.

4.2 Ambient conditions

4.2.1 General

A set of standard reference ambient conditions shall be used for determining the power losses in HVDC converter stations.

4.2.2 Outdoor standard reference temperature

An outdoor ambient dry bulb temperature of 20 °C shall be used as the standard reference temperature for determining the total converter station losses. Corresponding valve hall temperature may be defined by the supplier if necessary. The equivalent wet-bulb temperature (where necessary) shall be defined by the purchaser.

If not defined, the wet-bulb temperature is recommended to be 14 °C, which corresponds to approximately 50 % RH at 20 °C dry bulb temperature.

4.2.3 Coolant standard reference temperature

Where forced cooling is used for equipment, the flow rate and temperature of the coolant can influence the temperature rise and associated losses of that equipment. Therefore, the coolant temperatures and flow rates established by the purchaser and the supplier shall be used as a basis for determining the losses.

4.2.4 Standard reference air pressure

The reference air pressure to be used for the evaluation of total converter station power losses shall be the standard atmospheric pressure (101,3 kPa) corrected to the altitude of the installation in question.

4.3 Operating parameters

The losses of an HVDC converter station depend on its operating parameters.

~~The losses of HVDC converter stations are classified into three categories, termed the no-load operation losses, operating losses and auxiliary losses.~~

The losses of HVDC converter stations are classified into two categories, referred to as operating losses (3.1.4 and 3.1.7) and no-load operation losses (3.1.2 and 3.1.6).

The operating losses and auxiliary losses are affected by the load level of the station because the numbers of certain types of energised equipment (for example harmonic filters and cooling equipment) may depend upon the load level and because losses in individual items of equipment themselves vary with the load level.

HVDC converter station losses shall be determined for nominal (balanced) AC system voltage and frequency, symmetrical impedances of the converter transformer and symmetrical firing angles. The transformer tap-changer shall be assumed to be in the position corresponding to nominal AC system voltage or as decided by the control system for the defined operating condition.

The operating losses shall be determined for the load levels specified by the purchaser, or at rated load if no such conditions are specified. For each load level, the valve-winding AC voltage, DC current, converter firing angle, shunt compensation and harmonic filtering equipment shall be consistent with the respective load level and other specified performance requirements, relating, for example, to harmonic distortion and reactive power. Cooling and other auxiliary equipment, as appropriate to the standard reference temperature (see 4.2.2 and 4.2.3), shall be assumed to be connected to support the respective load level.

For the no-load operation mode, converter transformers shall be energised and the converters blocked. All filters and reactive power compensation equipment shall be assumed to be disconnected except for those which are required to sustain operation at zero load in order, for example, to meet the specified reactive power requirements. Station service loads and auxiliary equipment (e.g. cooling-water pumps) shall be assumed to be connected as required for immediate pick-up of load for the converter station (without waiting for tap changer movement) to specified minimum power.

5 Determination of equipment losses

5.1 Thyristor valve losses

5.1.1 General

The loss production mechanisms applicable when the valves are blocked (no-load operation losses) are different from those applicable in normal operation (operating losses). Operating losses are dealt with in 5.1.2 to 5.1.11, and no-load operation losses are dealt with in 5.1.12. Auxiliary losses are dealt with in 5.8.

Typical high-voltage direct current (HVDC) equipment for one pole of a HVDC substation is shown in Figure 1.

A simplified three-phase diagram of an HVDC 12-pulse converter is shown in Figure 2. Individual valves are marked in the order of their conduction sequence.

A simplified equivalent circuit of a typical valve is shown in Figure 3. Symbol N_t "th" combines together the effects of N_t thyristors connected in series in the valve. C_{AC} and R_{AC} are the corresponding combined values of R-C damping circuits used for voltage sharing and overvoltage suppression. R_{DC} represents DC grading resistors and other resistive components which incur loss when the valve blocks voltage. It also includes the effects of the thyristor leakage current (see 5.1.5 and 5.1.12). C_s includes both stray capacitances and surge distribution capacitors (if used). L_s represents saturable reactors used to limit the di/dt stresses to safe values and to improve the distribution of fast rising voltages. R_s represents the resistances of the current conducting components of the valve such as the busbars, contact resistances, resistance of the windings of the saturable reactors, etc. Power losses in the valve surge arrester (not shown) shall be neglected.

Figure 4 shows, as an example, current and voltage waveforms of valve 1 (according to Figure 2) operating in rectifier – Figure 4 a) – and inverter – Figure 4 b) – modes. In the example shown, the firing instants of the valves of the upper bridge are delayed by 30° with respect to the valves of the lower bridge due to the phase shift between the two secondaries. For each valve, the length of the conduction intervals is $130^\circ (2\pi/3 + \mu)$. During commutations, the valve current is assumed, for this document, to be changing linearly whereas in reality the valve currents follow portions of sine waves. This simplification has negligible effect on the resulting losses, while the trapezoidal waveform significantly simplifies the calculations. The voltage blocked by the valve shows notches caused by commutations between individual valves.

5.1.2 Thyristor conduction loss per valve

A typical thyristor on-state characteristic is shown in Figure 5. This Thyristor conduction loss component is the product of the conduction current $i(t)$ – Figure 6 a) – and the corresponding ideal on-state voltage as shown in Figure 5 and 6. Formula P_{V1a} shall be used provided that the DC bridge current is well smoothed. In the event that the root sum square value of the DC side harmonic currents, determined in accordance with Clause A.4 (annex A), exceeds 5 % of the DC component, formula P_{V1b} shall be used instead.

$$P_{V1a} = \frac{N_t \times I_d}{3} \left[U_0 + R_0 \times I_d \times \left(\frac{2\pi - \mu}{2\pi} \right) \right]$$

$$R_{V1b} = \frac{N_t \times I_d \times U_0}{3} + \frac{N_t \times R_0}{3} \left(I_d^2 + \sum_{n=12}^{n=48} I_n^2 \right) \left(\frac{2\pi - \mu}{2\pi} \right)$$

where

U_0 is the current-independent component of the on-state voltage of the average thyristor (see note below), in volts;

R_0 is the slope resistance of the on-state characteristic of the average thyristor (see note below), in ohms;

I_n is the calculated RMS value of the n^{th} harmonic current in the bridge DC connection according to Clause A.4, in amperes.

NOTE U_0 and R_0 (see Figure 5) are determined from the fully spread on-state voltage measured at the appropriate current and junction temperature. The average value of U_0 and R_0 is obtained from production records of the thyristors ~~manufactured for the specific project at 100 % and 50 % of nominal d.c. current~~. The temperature dependence of U_0 and R_0 is established from type tests or routine tests on a statistically significant number of the thyristors employed, and is used, where necessary, to correct U_0 and R_0 to the appropriate service junction temperature. If parallel connection of p thyristors is employed, the appropriate 100 % current is the nominal DC bridge current divided by p . The calculated result is then multiplied by p .

5.1.3 Thyristor spreading loss per valve

This loss component is an additional conduction loss of the thyristors arising from the delay in establishing full conduction of the silicon after the thyristor has been turned on. The additional loss is the product of the current and the voltage by which the thyristor voltage exceeds the ideal thyristor on-state voltage drop – see the hatched area in Figure 6 b).

$$R_{V2} = N_t \times f \times \int_0^{t_1} [u_B(t) - u_A(t)] \times i(t) dt$$

where

t_1 is the length of the conduction interval, in seconds, which is given by:

$$t_1 = \frac{\frac{2}{3} \pi + \mu}{2\pi f};$$

$u_B(t)$ is the instantaneous on-state voltage, in volts, of a thyristor whose fully spread on-state voltage is typical for the thyristors used; the instantaneous on-state voltage shall be determined for the appropriate junction temperature measured with a trapezoidal current pulse exhibiting the correct amplitude and commutation overlap periods (see Figure 5 and Figure 6);

$u_A(t)$ is the calculated instantaneous on-state voltage of the average thyristor at the same junction temperature for the same current pulse but with the conducting area fully established throughout the conduction, as derived from its on-state characteristic represented by U_0 and R_0 only (see Figure 6);

$i(t)$ is the instantaneous current in the thyristor, in amperes.

NOTE—Instantaneous on-state voltage data, including the effects of spreading, are usually not available from production records. Measurements of typical thyristor on-state voltage, including spreading, should therefore be obtained during the valve periodic firing and