

INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**IEC TS 61724-3**  
Edition 1.0 2016-07

**PHOTOVOLTAIC SYSTEM PERFORMANCE –**

**Part 3: Energy evaluation method**

**CORRIGENDUM 1**

**6.8.3 Calculation of performance ratio**

*Replace for  $H_i$ , the plane-of-array irradiation, the unit of measurement  $\text{kW/m}^2$  (energy) by  $\text{kWh/m}^2$  (power).*

**iTeh Standards**  
**(<https://standards.itih.ai>)**  
**Document Preview**

[IEC TS 61724-3:2016/COR1:2018](https://standards.itih.ai/catalog/standards/iec/55735154-b0e8-42c6-b5f-8734f7dbe80e/iec-ts-61724-3-2016-cor1-2018)

<https://standards.itih.ai/catalog/standards/iec/55735154-b0e8-42c6-b5f-8734f7dbe80e/iec-ts-61724-3-2016-cor1-2018>