



Designation: E1293 – 02 (Reapproved 2019)

Standard Specification for Glass Measuring Pipets¹

This standard is issued under the fixed designation E1293; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This specification covers requirements for glass measuring pipets of precision and general purpose grades, used in measuring volumes of liquids.

1.2 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 *ASTM Standards:*²

E438 Specification for Glasses in Laboratory Apparatus

E542 Practice for Calibration of Laboratory Volumetric Apparatus

E671 Specification for Maximum Permissible Thermal Residual Stress in Annealed Glass Laboratory Apparatus

E694 Specification for Laboratory Glass Volumetric Apparatus

E920 Specification for Commercially Packaged Laboratory Apparatus

E921 Specification for Export Packaged Laboratory Apparatus

E1133 Practice for Performance Testing of Packaged Laboratory Apparatus for United States Government Procurements

E1157 Specification for Sampling and Testing of Reusable Laboratory Glassware

E1273 Specification for Color Coding of Reusable Laboratory Pipets

¹ This specification is under the jurisdiction of ASTM Committee E41 on Laboratory Apparatus and is the direct responsibility of Subcommittee E41.01 on Laboratory Ware and Supplies.

Current edition approved Jan. 1, 2019. Published February 2019. Originally approved in 1989. Last previous edition approved in 2012 as E1293 – 02(2012). DOI: 10.1520/E1293-02R19.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

3. Classification

3.1 *Style, Class, and Capacity*—Pipets covered by this specification shall be of the following styles, classes, and capacities:

3.1.1 *Style 1*—Standard taper tip.

3.1.1.1 *Class A*—Each pipet of precision grade shall be marked with the letter “A” to signify compliance with applicable construction and accuracy requirements in **Table 1**. Each pipet may be marked with a permanent serial number at the option of the manufacturer.

3.1.1.2 *Class B*—General purpose pipets are of the same basic design as Class A pipets. Volumetric tolerances for Class B pipets shall be within twice the specified range allowed for Class A pipets. These pipets need not be marked with their class designation or serial number. See **Table 1** for tolerances and dimensional requirements.

3.1.2 *Style 2*—Long taper tip (Class B only).

3.1.3 *Capacities, (mL)*—0.1, 0.2, 0.5, 1, 2, 5, 10, 25, and 50.

4. Design

4.1 *Shape*—The pipets shall be straight and of one-piece construction. Any cross section of a pipet taken in a plane perpendicular to the longitudinal axis shall be circular.

4.2 *Delivery Tips*—Delivery tips of Style 1 pipets shall be made with a gradual taper of 15 to 30 mm for capacities up to 5 mL inclusive, and 20 to 40 mm for 10 to 50 mL capacity pipets. Style 2 pipets shall have a taper at a distance of 50 to 65 mm from the tip end. The end of the tip shall be perpendicular to the longitudinal axis of the pipet. A sudden constriction at the orifice shall not be acceptable. The outside edge of the tip shall be beveled slightly at the end, and the bevel shall be ground or firepolished.

4.3 *Zero Graduation Line Position*—The distance from the top end to the top graduation of all pipets (except for 0.5 mL pipets) shall be not less than 90 mm; for 0.5 mL pipets this distance shall be not less than 80 mm.

4.4 *Dimensions and Outflow Times*—The limiting dimensions and outflow times are shown in **Table 1**. Outflow times shall be determined on unplugged pipets using distilled water at 25 ± 5 °C and by means of a stopwatch. Outflow time shall be determined by the unrestricted outflow of the water from the zero mark to base mark and until the water has ceased to flow.