

INTERNATIONAL STANDARD



Energy management system application program interface (EMS-API) –
Part 600-1: Common Grid Model Exchange Standard (CGMES) – Structure and
rules

<https://standards.iteh.ai/catalog/standards/sist/dba0f200-4196-40b4-8808-c227412e4905/iec-61970-600-1-2021>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2021 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

www.iec.ch IEC 61970-600-1:2021

<https://standards.iteh.ai/catalog/standards/sis/dba0200-4196-40b4-8808-c227412e4905/iec-61970-600-1-2021>

INTERNATIONAL STANDARD



**Energy management system application program interface (EMS-API) –
Part 600-1: Common Grid Model Exchange Standard (CGMES) – Structure and
rules**

[IEC 61970-600-1:2021](https://standards.iteh.ai/catalog/standards/sist/dba0f200-4196-40b4-8808-c227412e4905/iec-61970-600-1-2021)

[https://standards.iteh.ai/catalog/standards/sist/dba0f200-4196-40b4-8808-
c227412e4905/iec-61970-600-1-2021](https://standards.iteh.ai/catalog/standards/sist/dba0f200-4196-40b4-8808-c227412e4905/iec-61970-600-1-2021)

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.200

ISBN 978-2-8322-9814-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

| | |
|---|----|
| FOREWORD..... | 4 |
| INTRODUCTION..... | 7 |
| 1 Scope..... | 8 |
| 2 Normative references | 9 |
| 3 Terms, definitions and abbreviated terms | 10 |
| 3.1 Terms and definitions..... | 10 |
| 3.2 Abbreviated terms..... | 11 |
| 4 Data exchange context..... | 12 |
| 5 Specifications and functionalities..... | 15 |
| 5.1 General constraints..... | 15 |
| 5.2 Model authority sets (MAS)..... | 17 |
| 5.3 File header | 18 |
| 5.4 File body..... | 19 |
| 5.5 Profiles and instance file types..... | 19 |
| 5.5.1 General | 19 |
| 5.5.2 CGMES profiles' properties | 19 |
| 5.5.3 CGMES extensions..... | 21 |
| 5.5.4 Equipment profile and instance file..... | 22 |
| 5.5.5 Topology profile and instance file | 23 |
| 5.5.6 Steady state hypothesis profile and instance file..... | 23 |
| 5.5.7 State variables profile and instance file | 24 |
| 5.5.8 Equipment boundary profile and instance file..... | 24 |
| 5.5.9 Topology boundary profile and instance file..... | 24 |
| 5.5.10 Diagram layout profile and instance file..... | 24 |
| 5.5.11 Geographical location profile and instance file..... | 25 |
| 5.5.12 Dynamics profile and instance file..... | 25 |
| 5.6 File exchange | 26 |
| 5.7 Boundary point – properties and location | 27 |
| 5.8 Model merging process | 29 |
| 5.9 CIM XML document/distribution validity..... | 32 |
| 5.10 Naming Convention..... | 33 |
| 6 CGMES governance | 36 |
| 6.1 General..... | 36 |
| 6.2 Versions of the CGMES and the profiles | 37 |
| 6.3 Conformity assessment..... | 38 |
| 6.4 Implementation process | 38 |
| Annex A (xxxx) | 39 |
| Annex B (normative) File header guidelines | 40 |
| B.1 General..... | 40 |
| B.2 Exchange scenarios..... | 40 |
| B.3 Examples..... | 41 |
| B.3.1 Example 1: File header of full model..... | 41 |
| B.3.2 Example 2: File header of full model that is depending on another model | 42 |
| B.3.3 Example 3: File header of full model that is depending on a model and supersedes another model..... | 43 |

| | | |
|-------|---|----|
| B.3.4 | Example 4: File header of difference model that is depending on a full model and supersedes another full model..... | 44 |
| B.3.5 | Example 5: File header of difference model that is depending on a difference model and supersedes another difference model..... | 45 |
| | Bibliography..... | 47 |
| | Figure 1 – CGMES instance file dependency | 20 |
| | Figure 2 – Boundary point placed on a tie-line | 27 |
| | Figure 3 – Boundary point placed in a substation | 27 |
| | Figure 4 – HVDC as interconnection or internal line | 28 |
| | Figure 5 – HVDC grid..... | 28 |
| | Figure 6 – Merge process | 31 |
| | Figure B.1 – Example workflow events..... | 40 |
| | Table 1 – IdentifiedObject attributes | 36 |
| | Table 2 – IdentifiedObject attributes in EQBD profile | 36 |

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

[IEC 61970-600-1:2021](https://standards.iteh.ai/catalog/standards/sist/dba0f200-4196-40b4-8808-c227412e4905/iec-61970-600-1-2021)

<https://standards.iteh.ai/catalog/standards/sist/dba0f200-4196-40b4-8808-c227412e4905/iec-61970-600-1-2021>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ENERGY MANAGEMENT SYSTEM APPLICATION
PROGRAM INTERFACE (EMS-API) –****Part 600-1: Common Grid Model Exchange Standard (CGMES) –
Structure and rules**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61970-600-1 has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

This first edition cancels and replaces IEC TS 61970-600-1 published in 2017. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to IEC TS 61970-600-1:2017:

- Terms and definitions were updated.
- The “Type” column in all tables was deleted to increase readability of the document as all the rules are considered required, hence categorisation is not necessary.
- Requirement HGEN4 was added to define additional rules to the file header compared to IEC 61970-552:2016.

- Annex B on “Summary of specific rules for naming conventions” is deleted as the information was either integrated in the UML or considered outdated.
- Annex D referring to the PST modelling is deleted as it will be fully integrated in IEC 61970-301:2020+AMD11.
- Annex E “Implementation guide” is deleted as all rules and implementation guidance is or will be integrated in either Clause 5 of this document or IEC 61970-301:2020 (and its future Amendment 1) or IEC 61970-452 or IEC 61970-456 as referenced by this document. Note that former Subclause E.11.2 on ConformLoadGroup and NonConformLoadGroup was implemented differently due to another issue, please refer to IEC 61970-600-2:2020.
- Rules GENC17, GENC18, GENC19, EQ__4, EQ__5, SV__4, BPPL12, BPPL13, MVAL5, EXCH9, TP__4 and MARP12 were added.
- Rules GENC3, GENC6, PROF2, PROF4, PROF5, PROF8, PROF9, EXCH5, EXCH6, EXCH7, MAS_4, MAS_6, MAS_9, MAS_10, MAS_11, MAS_13, EQ__1, HREF2, HREF3, HREF5, MVAL3, TPBD1, TPBD2, BPPL10, NAMC12 and NAMC13 are deleted as they are considered not relevant due to other changes.
- The following rules were modified: GENC1, GENC2, GENC4, GENC5, GENC7, GENC8, GENC9, GENC10, GENC16, EQBD2, BPPL11, EXCH2, EXCH3, EXCH8, FBOD3, FBOD5, PROF10, PROF11, MAS_1, MAS_8, HGEN3, HREF1, EEXT1, EQ__2, TP__1, TP__2, TP__3, MARP10, MARP11, NAMC1, NAMC4, NAMC11, NAMC14, BPPL1, BPPL2 and BPPL3.
- Explicit equipment boundary profile definition (EQBD) has been deprecated (refer to Subclause 4.6.5 of IEC 61970-301:2020 and future Amendment 1 for details on deprecations) in this edition in favour of using its full profile counterpart (EQ) for exchange of boundary datasets. The topology boundary profile (TPBD) is not included in the CGMES as TP is considered output and therefore it is no need to exchange Topology information part of the boundary model authority set.
- Annex F has been deleted.

<https://standards.iech.ai/catalog/standards/sist/dba0f200-4196-40b4-8808-c227412c4905/iec-61970-600-1-2021>

The text of this International Standard is based on the following documents:

| FDIS | Report on voting |
|--------------|------------------|
| 57/2366/FDIS | 57/2382/RVD |

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

A list of all parts in the IEC 61970 series, published under the general title *Energy management system application program interface (EMS-API)*, can be found on the IEC website.

¹ An amendment to IEC 61970-301:2020 is currently under consideration.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[IEC 61970-600-1:2021](#)

<https://standards.iteh.ai/catalog/standards/sist/dba0f200-4196-40b4-8808-c227412e4905/iec-61970-600-1-2021>

INTRODUCTION

The purpose of this document is to define the Common Grid Model Exchange Standard (CGMES) based on Common Information Model (CIM) standards defined in IEC 61970-series, IEC 61968-series and IEC 62325-series and to address requirements defined by the European legislation. However, the document is not limited to the European legislation requirements and business processes, it is created to support data exchange between applications that support power system model management and analysis. The data exchange can be between internal applications or between applications at System Operators (SO) and Regional Coordination Centre (RCC). This covers DSO-DSO, DSO-TSO, TSO-TSO, TSO-RCC/ISO/RTO and RCC-RCC interfaces, but not limited to these.

The CGMES is created to address the information exchange requirements provided in Common Grid Model methodologies (CGMm) in accordance with the legal requirements stated in various European network codes guidelines. The CGMES applies to applications dealing with power system data management, as well as applications supporting the following analyses:

- power flow and contingency analyses,
- short circuit calculations,
- market information and transparency,
- capacity calculation for capacity allocation and congestion management, and
- dynamic security assessment.

The conformity of applications used for system operation and system development data exchanges with the CGMES is crucial for the needed interoperability of these applications. This document provides the grouping of all principle requirements for the CGMES Conformity Assessment Framework and the guiding principles for assessing applications' CGMES conformity. The description of the CGMES Conformity Assessment Process is currently not part of the IEC 61970-600-series, but it is planned to be included as an international standard in order to validate that the CGMES is correctly implemented by suppliers of the applications used by system operators (ISO/TSO/DSO etc) and for Regional Coordination Centres (RCCs).

ENERGY MANAGEMENT SYSTEM APPLICATION PROGRAM INTERFACE (EMS-API) –

Part 600-1: Common Grid Model Exchange Standard (CGMES) – Structure and rules

1 Scope

This part of IEC 61970, which covers the definition of Common Grid Model Exchange Standard (CGMES), defines the main rules and application's requirements to meet business requirements for assembled and merged model to fit relevant business services. This document does not define the business requirements, business processes nor how applications are implemented. This document defines how relevant Common Information Model (CIM) standards work together so that specific business requirements can be resolved.

It also includes extensions to the Common Information Model (CIM). The current extensions are defined in IEC 61970-301:2020 and will be covered in its future Amendment 1, but additional extensions can be defined in other standards in the IEC 61970-600-series. The extensions can be used to define additional profiles or to expand IEC 61970-450-series or IEC 61968-13 profiles. However, primary CGMES includes additional constraints on existing profiles and validation of assembled and merged models that is based on existing profiles. This can be done by making optional attributes and associations mandatory (required).

In addition, this document includes the specification of the serialisation that must be supported by referring to an existing standard defined in IEC 61970-550-series, e.g., IEC 61970-552, and making relevant constraints related to it.

The goal is to achieve interoperability between applications using CGMES in a high-performance environment with combined minimum effort so that relevant business processes are satisfied.

An overview of IEC 61970-600 series is provided in the following table, which also presents identified needs that are not yet addressed.

| Part | Description | Scope |
|---------------------|---|---|
| 61970-600-1 | Structure and rules. This part defines the structure of the series of standard and the rules that needs to be applied on the assembled and merged models that are defined by the different profile standards. | In the scope |
| 61970-600-2 | Exchange profiles specification. This part defines the IEC 61970-450-series and IEC 61968-13 related profiles that are included in CGMES. It includes the references to published standards and additional constraints defined to the relevant standard. If the relevant edition of a standard is not published, it also includes the profile definition and the standard's constraints. | In the scope |
| to be defined (TBD) | Information extension. This part defines additional information model that is not included in the relevant edition of IEC 61970-301, IEC 61970-302 or IEC 61968-11 that is needed to meet business requirement. | Identified as a need and not yet addressed neither in this document nor in IEC 61970-600 series |
| to be defined (TBD) | Extended exchange profiles specification. This part defines additional profiles that is not included in IEC 61970-450-series and IEC 61968-13 that is needed to meet business requirement. | |
| to be defined (TBD) | Conformity Assessment Scheme (CAS). This part defines the Conformity Assessment Scheme (CAS) including test use cases and references to test configurations to evaluate if an application tool conforms to the CGMES. | |

IEC 61970-600-1:2021

Clause 4, Data exchange context, describes the context the CGMES is developed to support.

Clause 5, Specifications and functionalities, defines the rules that shall be applied for validating a model part, an assembled and a merged model. When the rule is defined in the relevant profile it will include a refence to the rule.

Clause 6, CGMES governance, defines the governance of CGMES and the version strategy.

Annex A is left blank.

Annex B (normative), File header guidelines, explains the usage of the file header that is defined in IEC 61970-552.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61970-552:2016, *Energy management system application program interface (EMS-API) – Part 552: CIMXML Model exchange format*

IEC 61970-301:2020, *Energy management system application program interface (EMS-API) – Part 301: Common information model (CIM) base*

IEC 61970-302:2018, *Energy management system application program interface (EMS-API) – Part 302: Common information model (CIM) dynamics*

3 Terms, definitions and abbreviated terms

For the purposes of this document, the following terms, definitions and abbreviated terms apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

NOTE For definitions which are not specified in the CGMES the definitions in the IEC 61970 standard series shall be applied.

3.1 Terms and definitions

3.1.1

assembled model

model of a Model Authority Set with internal references resolved

3.1.2

boundary point

BP

connection point between two Model Authority Sets, that has been agreed on by both relevant Model Authority

iTeh STANDARD PREVIEW
(standards.iteh.ai)

3.1.3

boundary set

set containing all boundary points necessary for a merge model

[IEC 61970-600-1:2021](https://standards.iteh.ai/catalog/standards/sist/dba0f200-4196-40b4-8808-227412e4905/iec-61970-600-1-2021)

3.1.4

CIM XML document/distribution

instance file which is serialised according to IEC 61970-552

<https://standards.iteh.ai/catalog/standards/sist/dba0f200-4196-40b4-8808-227412e4905/iec-61970-600-1-2021>

3.1.5

distribution

specific representation of a dataset. A dataset might be available in multiple serializations that may differ in various ways, including natural language, media-type or format, schematic organization, temporal and spatial resolution. The level of detail in the distribution is defined by one or more profiles that the dataset conforms to

3.1.6

Common Grid Model Exchange Standard

CGMES

collection of standards defined in IEC 61970-600 series that support the exchange of power system models (e.g. individual grid model or common grid model) between model authorities (TSOs, DSOs, etc.) for the purpose of coordinated set of services to be performed on the same model according to legislation or general data exchanges in the frame of system operation, system development or utilities' projects

3.1.7

European extensions

collection of classes, attributes and associations, which either extend or are defined in the standard IEC CIM model (IEC 61970-300 series, IEC 91968-11 and IEC 62325-300 series). The European extensions aim at satisfying requirements by the European legislation hence not necessarily applicable to other continents. The worldwide adoption of these extensions may not be exactly the same as the defined extension

3.1.8**external references resolved**

no dangling references are present across the models of Model Authority Sets

3.1.9**header references resolved**

references defined in model header are resolved

3.1.10**internal references resolved**

no dangling references are present within the model of a Model Authority Set

3.1.11**merged model**

model that is a union of different assembled models with external and header references resolved

3.1.12**profile**

data model to describe instance file for exchange of CIM data. A profile is a subset of classes, associations and attributes needed to accomplish a specific type of interface and based upon a CIM data model. Profiles may impose stricter rules on original classes and associations. A profile is usually converted to schema (XSD, RDF, OWL, etc.) that can be used to create, read and validate instance files for data exchange

Note 1 to entry: This term may be used to define either the semantic model for an instance data payload or the syntactic schema for an instance data payload. A profile may be expressed in XSD, RDF, and/or OWL files. An instance data conforming to a profile can be tested in exchanges between applications. A profile is necessary in order to “use” the canonical model.

[IEC 61970-600-1:2021](https://standards.iteh.ai/catalog/standards/sist/dba0f200-4196-40b4-8808-c227412e4905/iec-61970-600-1-2021)

3.1.13**solved model**

model containing instance of State Variables (SV)

3.2 Abbreviated terms

| | |
|---------|--|
| BP | Boundary point |
| CIM | Common Information Model (electricity) |
| CGMES | Common Grid Model Exchange Standard |
| DL | Diagram Layout profile |
| DSO | Distribution System Operator |
| DY | Dynamics profile |
| ENTSO-E | European Network of Transmission System Operators for Electricity |
| EQ | Core Equipment profile |
| EQBD | Equipment Boundary profile |
| GL | Geographical Location profile |
| HVDC | High Voltage Direct Current |
| IEC | The International Electrotechnical Commission, headquartered in Geneva |
| IOP | Interoperability Test |
| ISO | Independent System Operator |
| MAS | Model Authority Set |
| mRID | CIM Master Resource Identifier |
| OCL | Object Constraint Language |

| | |
|-------|---------------------------------|
| OP | Operation profile |
| OWL | Web Ontology Language |
| RCC | Regional Coordination Centres |
| RDF | Resource Description Framework |
| RDFS | RDF Schema |
| SC | Short-Circuit profile |
| SHACL | Shapes Constraint Language |
| SSH | Steady State Hypothesis profile |
| SV | State Variables profile |
| TP | Topology profile |
| TSO | Transmission System Operator |
| URI | Uniform Resource Identifier |
| UUID | Universally Unique Identifier |
| XML | Extensible Markup Language |
| XSD | XML Schema Definition |

4 Data exchange context

There are various levels at which an exchange of power system data/models is necessary. A pan-European model exchange level covers the territory of all system operators (TSOs and DSOs). Regional model exchanges can be realised between different TSOs in one or more synchronous areas. A model exchange on the national level includes interfaces between TSOs (in case there are multiple TSOs on a national level) as well as between different DSOs.

<https://standards.iec.ch/catalog/standards/sist/dba0f200-4196-40b4-8808-277412e4915/iec-61970-600-1-2021>

The purpose of model exchanges is not only to exchange the data from one authority to another but also to satisfy the ultimate goal, namely, to perform common studies using shared data. All parties involved in the process should be able to perform the same types of studies and share project tasks between different parties which are using different power system analysis applications. Indeed, the interoperability between different applications used in the exchange process is therefore crucial in both reaching seamless data exchange and obtaining comparable study results when using this data.

The CGMES covers these European and system operators (TSOs and DSOs) business processes by defining the following main types of exchanges valid for a particular study or process:

- Exchange of boundary set: An exchange of a boundary Set is necessary to prepare an exchange of an internal system operator model and to merge a common grid model. E.g. the ENTSO-E Network Modelling Database (NMD) is used to maintain the Boundary Set covering the pan-European area where all TSOs negotiate and agree on the boundary information.

- Exchange of an internal TSO model, i.e. individual grid model (IGM²): A number of business processes require each TSO to provide models of its internal territory. To describe its internal territory in a single stand-alone exchange, a TSO is treated as a single model authority set and shall be able to exchange datasets complying with profiles defined in the CGMES. The TSO prepares its internal model in such a way that it is easily and unambiguously combined with other TSO internal models to make up complete models for analytical purposes. This type of exchange can also be applied for the interface between a TSO and a DSO, where models covering transmission or distribution parts of the power system can be exchanged based on a mutual agreement between the TSOs and the DSOs. In this case, and if a TSO requests a DSO model, the DSO would provide its model in accordance with CGMES definitions.
- Exchange of a common grid model: A common grid model refers to the concept of having one model which can be used for multiple purposes. The specification describes what is needed to create a merge model of multiple TSOs' Individual Grid Models (IGM) of their responsible territory into a regional or pan-European model. Various business processes will require specific implementation of the profiles part of the CGMES and the exchange of respective instance files to meet interoperability inside the business process. The Common Grid Model meta-model description will ensure interoperability across the business process.

Business processes (e.g. system development planning, protection planning, operational planning, operation, fault study/simulation, market operation, etc.) are, of course, more complex than these operations, but what is important to note is that all processes are supported using only these basic kinds of interoperation. In addition, business processes shall define or precise, where necessary, the content of the data exchange within the scope of the defined profiles. For instance, OperationalLimitSet can be used to constraint any conducting equipment. It is up to the business process to define if any equipment is mandatory to have operational limits.

Note that each power system model normally consists of multiple datasets (distribution) as defined in CIM standards and further specified by CGMES.

The CGMES supports node-breaker (NB) and bus-branch (BB) model exchanges.

NOTE 1 A network model representation including the connectivity details of all the switching equipment and bays in substations and other equipment containers. Switching equipment is normally not retained, except for those carrying power flow that needs to be monitored, e.g. coupler bays. In order to be used in steady-state analysis calculations, this model representation usually requires topology processing, to produce a BB representation.

NOTE 2 A network model using a simplified representation of a network, typically resulting from topology processing (where the detailed switching equipment and bays get reduced to typically single bus per voltage level in a substation). The only switching equipment used shall be flagged as retained. This model representation is ultimately used in steady-state analysis calculations.

Moving forward the procedures of the model exchanges using the CGMES, it is expected that equipment and steady state hypothesis data (EQ and SSH distribution) will be the input source data for all processes. This type of model should be the fully detailed model with all disconnectors/breakers, etc. Any configuration changes will be made by changing switch statuses.

² IGM: EU Regulation 2015/1222 Article 2
<https://eur-lex.europa.eu/legal-content/EN/TXT/?uri=CELEX%3A32015R1222>.