



IEEE

IEC/IEEE 62582-1

Edition 2.0 2024-09

INTERNATIONAL STANDARD

**Nuclear power plants – Instrumentation and control important to safety –
Electrical equipment condition monitoring methods –
Part 1: General**

(<https://standards.iteh.ai>)

Document Preview

[IEC/IEEE 62582-1:2024](https://standards.iteh.ai/catalog/standards/iec/1dcb727a-931b-4bc4-a9be-9aa5a22573c7/iec-ieee-62582-1-2024)

<https://standards.iteh.ai/catalog/standards/iec/1dcb727a-931b-4bc4-a9be-9aa5a22573c7/iec-ieee-62582-1-2024>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2024 IEC, Geneva, Switzerland
Copyright © 2024 IEEE

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing being secured. Requests for permission to reproduce should be addressed to either IEC at the address below or IEC's member National Committee in the country of the requester or from IEEE.

IEC Secretariat
3, rue de Varembé
CH-1211 Geneva 20
Switzerland
Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue
New York, NY 10016-5997
United States of America
stds.ipr@ieee.org
www.ieee.org

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

[IEC/IEEE 62582-1:2024](https://standards.itec.ai/catalog/standards/iec/1deb727a-931b-4bc4-a9bc-9aa5a22573c7/iec-ieee-62582-1-2024)

<https://standards.itec.ai/catalog/standards/iec/1deb727a-931b-4bc4-a9bc-9aa5a22573c7/iec-ieee-62582-1-2024>



IEEE

IEC/IEEE 62582-1

Edition 2.0 2024-09

INTERNATIONAL STANDARD

**Nuclear power plants – Instrumentation and control important to safety –
Electrical equipment condition monitoring methods –
Part 1: General**

Document Preview

[IEC/IEEE 62582-1:2024](https://standards.iteh.ai/standards/iec/1dcb727a-931b-4bc4-a9be-9aa5a22573c7/iec-ieee-62582-1-2024)

<https://standards.iteh.ai/catalog/standards/iec/1dcb727a-931b-4bc4-a9be-9aa5a22573c7/iec-ieee-62582-1-2024>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 27.120.20

ISBN 978-2-8322-9581-6

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	9
4 Condition indicators.....	11
4.1 General.....	11
4.2 Chemical indicators	12
4.3 Physical indicators.....	12
4.4 Electrical indicators.....	12
4.5 Other indicators	12
4.6 Visual and tactile observation	12
5 Applicability of condition indicators to different types of polymeric materials.....	12
6 Destructive and non-destructive condition monitoring	13
7 Application of condition monitoring in equipment qualification and management of ageing	13
7.1 General.....	13
7.2 Use of condition monitoring in the establishment of qualified life.....	13
7.2.1 Establishment of qualified life	13
7.2.2 Determination of the acceleration factor in accelerated thermal ageing.....	14
7.3 Use of condition monitoring in the extension of qualified life	15
7.4 Use of condition monitoring in the establishment and assessment of qualified condition.....	15
7.5 Use of baseline data	17
Annex A (informative) Diffusion limited oxidation (DLO).....	18
A.1 General.....	18
A.2 Importance of DLO in thermal ageing.....	18
A.3 Methods for profiling DLO effects.....	19
A.4 Theoretical approach to DLO	19
Bibliography.....	21
Figure 1 – Example of an Arrhenius diagram.....	14
Figure 2 – Influence of activation energy on qualified life, determined from accelerated thermal ageing for 42 days at 110 °C, followed by a simulated design basis event.....	15
Figure 3 – Illustration of the principle of condition-based qualification	16
Figure A.1 – Indenter modulus profiles for EPDM seal aged at 170 °C (left) and 110 °C (right) [1].....	19

INTERNATIONAL ELECTROTECHNICAL COMMISSION

NUCLEAR POWER PLANTS – INSTRUMENTATION AND CONTROL IMPORTANT TO SAFETY – ELECTRICAL EQUIPMENT CONDITION MONITORING METHODS –

Part 1: General

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC document(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation.

IEEE Standards documents are developed within IEEE Societies and Standards Coordinating Committees of the IEEE Standards Association (IEEE SA) Standards Board. IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of IEEE and serve without compensation. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards. Use of IEEE Standards documents is wholly voluntary. *IEEE documents are made available for use subject to important notices and legal disclaimers (see <https://standards.ieee.org/ipr/disclaimers.html> for more information).*

IEC collaborates closely with IEEE in accordance with conditions determined by agreement between the two organizations. This Dual Logo International Standard was jointly developed by the IEC and IEEE under the terms of that agreement.

- 2) The formal decisions of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees. The formal decisions of IEEE on technical matters, once consensus within IEEE Societies and Standards Coordinating Committees has been reached, is determined by a balanced ballot of materially interested parties who indicate interest in reviewing the proposed standard. Final approval of the IEEE standards document is given by the IEEE Standards Association (IEEE SA) Standards Board.
- 3) IEC/IEEE Publications have the form of recommendations for international use and are accepted by IEC National Committees/IEEE Societies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC/IEEE Publications is accurate, IEC or IEEE cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications (including IEC/IEEE Publications) transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC/IEEE Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC and IEEE do not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC and IEEE are not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or IEEE or their directors, employees, servants or agents including individual experts and members of technical committees and IEC National Committees, or volunteers of IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE SA) Standards Board, for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC/IEEE Publication or any other IEC or IEEE Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.

9) Attention is drawn to the possibility that implementation of this IEC/IEEE Publication may require use of material covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. IEC or IEEE shall not be held responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patent Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

IEC/IEEE 62582-1 was prepared by subcommittee 45A: Instrumentation and control of nuclear facilities, of IEC technical committee 45: Nuclear instrumentation, in cooperation with Nuclear Power Engineering Committee of the IEEE Power & Energy Society¹, under the IEC/IEEE Dual Logo Agreement between IEC and IEEE. It is an International Standard.

This document is published as an IEC/IEEE Dual Logo standard.

This second edition cancels and replaces the first edition published in 2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Integration of experience from the work with IAEA-TECDOC-1825:2017 “Benchmark analysis for condition monitoring test techniques of low voltage cables in nuclear power plants. Final results of a Coordinated Research Project”.
- b) Referral to IEC/IEEE 60780-323 instead of IEC 60780 and IEEE 323.

The text of this International Standard is based on the following IEC documents:

Draft	Report on voting
45A/1510/CDV	45A/1537/RVC

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with the rules given in the ISO/IEC Directives, Part 2, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications/.

A list of all parts of IEC/IEEE 62582 series, under the general title *Nuclear power plants – Instrumentation and control important to safety – Electrical equipment condition monitoring methods*, can be found on the IEC website.

The IEC Technical Committee and IEEE Technical Committee have decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

¹ A list of IEEE participants can be found at the following URL: http://standards.ieee.org/downloads/62582-1/62582-1-2011/62582-1-2011_wg-participants.pdf.

INTRODUCTION

a) Technical background, main issues and organisation of this document

This part of this IEC/IEEE 62582 series focuses on methods for condition monitoring for management of ageing of electrical equipment installed in nuclear power plants and for application of the concept of qualified condition.

IEC/IEEE 6258-1 is the first part of the IEC/IEEE 62582 series of standards, containing background and guidelines for the application of methods for condition monitoring of electrical equipment important to safety of nuclear power plants. The detailed descriptions of the methods are given in the other parts, one part for each method. This document also includes some elements which are common to all methods.

IEC/IEEE 62582 series is issued with a joint logo which makes it applicable to the management of ageing of electrical equipment qualified to IEEE as well as IEC Standards.

Condition monitoring is a developing field and more methods will be added to the IEC/IEEE 62582 series when they are considered widely applied and a good reproducibility of the condition monitoring method can be demonstrated.

IEC/IEEE 60780-323 defined condition-based qualification which is an adjunct to type testing. The qualified condition is established by condition indicator(s) prior to the start of accident conditions for which the equipment was demonstrated to meet the design requirements for the specified service conditions. IEC/IEEE 60780-323 defined condition indicator.

Significant research has been performed on condition monitoring techniques and the use of these techniques in equipment qualification as noted in NUREG/CR-6704, Vol. 2 (BNL -NUREG-52610) [1],² JNES-SS-0903, 2009 [2] and IAEA-TECDOC-1825:2017 [3].

It is intended that this IEC/IEEE document be used by operators of nuclear power plants, systems evaluators and by licensors.

b) Situation of the current standard in the structure of the IEC SC 45A standard series

IEC/IEEE 62582-1 is the third level IEC SC 45A document tackling the issue of application of condition monitoring in equipment qualification and management of ageing of electrical I&C equipment in nuclear power plants.

IEC/IEEE 62582-1 is to be read in association with IEC/IEEE 60780-323, which provides general requirements for qualification of I&C systems and equipment that are used to perform functions important to safety in NPPs and nuclear facilities.

For more details on the structure of the IEC SC 45A standard series, see item d) of this introduction.

c) Recommendations and limitations regarding the application of this document

It is important to note that this document establishes no additional functional requirements for safety systems.

This document discusses the general measurement technique for current condition monitoring methods and is not meant to cover any specific technologies.

² Numbers in square brackets refer to the Bibliography.

d) Description of the structure of the IEC SC 45A standard series and relationships with other IEC documents and other bodies documents (IAEA, ISO)

The IEC SC 45A standard series comprises a hierarchy of four levels. The top-level documents of the IEC SC 45A standard series are IEC 61513 and IEC 63046.

IEC 61513 provides general requirements for instrumentation and control (I&C) systems and equipment that are used to perform functions important to safety in nuclear power plants (NPPs). IEC 63046 provides general requirements for electrical power systems of NPPs; it covers power supply systems including the supply systems of the I&C systems.

IEC 61513 and IEC 63046 are to be considered in conjunction and at the same level. IEC 61513 and IEC 63046 structure the IEC SC 45A standard series and shape a complete framework establishing general requirements for instrumentation, control and electrical power systems for nuclear power plants.

IEC 61513 and IEC 63046 refer directly to other IEC SC 45A standards for general requirements for specific topics, such as categorization of functions and classification of systems, qualification, separation, defence against common cause failure, control room design, electromagnetic compatibility, human factors engineering, cybersecurity, software and hardware aspects for programmable digital systems, coordination of safety and security requirements and management of ageing. The standards referenced directly at this second level should be considered together with IEC 61513 and IEC 63046 as a consistent document set.

At a third level, IEC SC 45A standards not directly referenced by IEC 61513 or by IEC 63046 are standards related to specific requirements for specific equipment, technical methods, or activities. Usually these documents, which make reference to second-level documents for general requirements, can be used on their own.

A fourth level extending the IEC SC 45 standard series, corresponds to the Technical Reports which are not normative.

[IEC/IEEE 62582-1:2024](https://www.iec.ch/standards/iec-ieee-62582-1-2024)

The IEC SC 45A standards series consistently implements and details the safety and security principles and basic aspects provided in the relevant IAEA safety standards and in the relevant documents of the IAEA nuclear security series (NSS). In particular this includes the IAEA requirements SSR-2/1, establishing safety requirements related to the design of nuclear power plants (NPPs), the IAEA safety guide SSG-30 dealing with the safety classification of structures, systems and components in NPPs, the IAEA safety guide SSG-39 dealing with the design of instrumentation and control systems for NPPs, the IAEA safety guide SSG-34 dealing with the design of electrical power systems for NPPs, the IAEA safety guide SSG-51 dealing with human factors engineering in the design of NPPs and the implementing guide NSS42-G for computer security at nuclear facilities. The safety and security terminology and definitions used by the SC 45A standards are consistent with those used by the IAEA.

IEC 61513 and IEC 63046 have adopted a presentation format similar to the basic safety publication IEC 61508 with an overall life-cycle framework and a system life-cycle framework. Regarding nuclear safety, IEC 61513 and IEC 63046 provide the interpretation of the general requirements of IEC 61508-1, IEC 61508-2 and IEC 61508-4, for the nuclear application sector. In this framework, IEC 60880, IEC 62138 and IEC 62566 correspond to IEC 61508-3 for the nuclear application sector.

IEC 61513 and IEC 63046 refer to ISO 9001 as well as to IAEA GSR part 2 and IAEA GS-G-3.1 and IAEA GS-G-3.5 for topics related to quality assurance (QA).

At level 2, regarding nuclear security, IEC 62645 is the entry document for the IEC/SC 45A security standards. It builds upon the valid high level principles and main concepts of the generic security standards, in particular ISO/IEC 27001 and ISO/IEC 27002; it adapts them and completes them to fit the nuclear context and coordinates with the IEC 62443 series. At level 2, IEC 60964 is the entry document for the IEC SC 45A control rooms standards, IEC 63351 is the entry document for the human factors engineering standards and IEC 62342 is the entry document for the ageing management standards.

NOTE 1 It is assumed that for the design of I&C systems in NPPs that implement conventional safety functions (e.g. to address worker safety, asset protection, chemical hazards, process energy hazards) international or national standards would be applied.

NOTE 2 IEC TR 63400 provides a more comprehensive description of the overall structure of the IEC SC 45A standards series and of its relationship with other standards bodies and standards.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC/IEEE 62582-1:2024](https://standards.iteh.ai/catalog/standards/iec/1dcb727a-931b-4bc4-a9bc-9aa5a22573c7/iec-ieee-62582-1-2024)

<https://standards.iteh.ai/catalog/standards/iec/1dcb727a-931b-4bc4-a9bc-9aa5a22573c7/iec-ieee-62582-1-2024>

NUCLEAR POWER PLANTS – INSTRUMENTATION AND CONTROL IMPORTANT TO SAFETY – ELECTRICAL EQUIPMENT CONDITION MONITORING METHODS –

Part 1: General

1 Scope

This part of the IEC/IEEE 62582 series contains requirements for application of the other parts of IEC/IEEE 62582 related to specific methods for condition monitoring in electrical equipment important to safety of nuclear power plants. It also includes requirements which are common to all methods. The procedures defined in IEC/IEEE 62582 are intended for detailed condition monitoring.

IEC/IEEE 62582 specifies condition monitoring methods in sufficient detail to enhance the accuracy and repeatability, and provide standard formats for reporting the results. The methods specified are applicable to electrical equipment containing polymeric materials. Some methods are especially designed for the measurement of condition of a limited range of equipment whilst others can be applied to all types of equipment for which the polymeric parts are accessible.

Although the scope of IEC/IEEE 62582 is limited to the application of instrumentation and control systems important to safety, the condition monitoring methods can also be applicable to other components which include polymeric materials.

The different parts of IEC/IEEE 62582 are measurement standards, primarily for use in the management of ageing in initial qualification and after installation. For the technical background of condition monitoring methods, reference is made to other IEC standards, e.g. IEC 60544-5 [1]. Information on the role of condition monitoring in qualification of electrical equipment important to safety is found in IEC/IEEE 60780-323. General information on management of ageing can be found in IEC 62342 [5] and IEEE 1205 [6].

NOTE A simplified version of the procedures can be appropriate for preliminary assessment of the need for detailed measurements.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC/IEEE 60780-323, *Nuclear facilities – Electrical equipment important to safety – Qualification*

IEC/IEEE 62582 (all parts), *Nuclear power plants – Instrumentation and control important to safety – Electrical equipment condition monitoring methods*