INTERNATIONAL ELECTROTECHNICAL COMMISSION

- 1 -


IEC 60079-29-1 Edition 2.0 2016-07

EXPLOSIVE ATMOSPHERES -

Part 29-1: Gas detectors – Performance requirements of detectors for flammable gases

INTERPRETATION SHEET 1

This interpretation sheet has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.



The text of this interpretation sheet is based on the following documents:

ttps _{Dish} stant	Report on voting	1
31/1456/DISH	31/1462/RVDISH	

Full information on the voting for the approval of this interpretation sheet can be found in the report on voting indicated in the above table.

nttps://standards.iteh.ai/catalog/standards/iec/2a7f4365-8c77-4cfc-b4f0-43ae187acc6a/iec-60079-29-1-2016-ish1-2019

In accordance with Administrative Circular AC/42/2004: New procedures for interpretation of standards, Annex 2: New text for ISO/IEC Directives (IEC Supplement), there has been a request for formal interpretation of the Air Velocity test acceptance criterion in the performance standard IEC 60079-29-1:2016.

Question:

Is the acceptance criteria for the Air Velocity test to be assessed based upon variation from the 0 m/s reading?

Interpretation:

Some of the performance tests are intended to be an accuracy based assessment from the applied gas concentration (eg. Short Term Stability and Calibration Curve). Other performance tests are intended to be a variation based assessment from a known baseline (eg. Baseline at 20 °C for Temperature test and baseline at 100 kPa for Pressure test).