

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



**Composite hollow core station post insulators with a.c. voltage greater than 1 000 V and d.c. voltage greater than 1 500 V – Definitions, test methods and acceptance criteria**

**Isolateurs supports composites creux présentant une tension alternative supérieure à 1 000 V et une tension continue supérieure à 1 500 V – Définitions, méthodes d'essai et critères d'acceptation**

<https://standards.iteh.ai/catalog/standards/sist/15f65fa4-7bb5-45da-a2f7-9b591ecb2ecc/iec-62772-2023>





## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2023 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

#### IEC publications search - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

#### IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [sales@iec.ch](mailto:sales@iec.ch).

#### IEC Products & Services Portal - [products.iec.ch](http://products.iec.ch)

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

### A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

#### Recherche de publications IEC -

[webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

#### Service Clients - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: [sales@iec.ch](mailto:sales@iec.ch).

#### IEC Products & Services Portal - [products.iec.ch](http://products.iec.ch)

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



**Composite hollow core station post insulators with a.c. voltage greater than 1 000 V and d.c. voltage greater than 1 500 V – Definitions, test methods and acceptance criteria**

**Isolateurs supports composites creux présentant une tension alternative supérieure à 1 000 V et une tension continue supérieure à 1 500 V – Définitions, méthodes d'essai et critères d'acceptation**

<https://standards.iteh.ai/catalog/standards/sist/15f65fa4-7bb5-45da-a2f7-9b591ecb2ecc/iec-62772-2023>

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

ICS 29.080.10

ISBN 978-2-8322-7404-0

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references .....	7
3 Terms and definitions .....	8
4 Identification and marking.....	12
5 Environmental conditions.....	13
6 Information on transport, storage and installation .....	13
7 Classification of tests.....	13
7.1 General.....	13
7.2 Design tests.....	13
7.3 Type tests .....	15
7.4 Sample tests.....	16
7.5 Routine tests.....	16
8 Design tests .....	16
8.1 General.....	16
8.2 Tests on interfaces and connections of end fittings .....	16
8.2.1 General .....	16
8.2.2 Test specimens .....	17
8.2.3 Reference disruptive- discharge dry power frequency voltage test.....	17
8.2.4 Thermal mechanical pre-stressing test.....	17
8.2.5 Water immersion pre-stressing test.....	17
8.2.6 Verification tests.....	17
8.3 Assembled core load tests .....	17
8.3.1 Test for the verification of the maximum design cantilever load (MDCL).....	17
8.3.2 Test for the verification of the maximum design torsion load (MDToL) .....	18
8.3.3 Verification of the specified tension load (STL) .....	19
8.4 Tests on shed and housing material.....	19
8.4.1 Hardness test .....	19
8.4.2 Accelerated weathering test.....	20
8.4.3 Tracking and erosion – 1 000 h salt fog AC voltage test.....	20
8.4.4 Flammability test .....	20
8.4.5 Hydrophobicity transfer test.....	20
8.5 Tests on the tube material .....	20
8.5.1 General .....	20
8.5.2 Porosity test (Dye penetration test).....	20
8.5.3 Water diffusion test.....	20
8.6 Water diffusion test on core with housing .....	20
9 Type tests .....	20
9.1 Internal pressure test.....	20
9.2 Bending test.....	20
9.3 Specified tension load test, compression and buckling withstand load test.....	20
9.4 Electrical tests .....	21
9.4.1 General .....	21
9.4.2 Mounting arrangements for electrical tests.....	21
9.4.3 Dry lightning impulse withstand voltage test.....	21

9.4.4	Dry or wet switching impulse withstand voltage test.....	21
9.4.5	Dry power-frequency withstand voltage test.....	21
9.4.6	Wet power-frequency withstand voltage test.....	21
10	Sample tests .....	21
11	Routine tests .....	22
11.1	General.....	22
11.2	Routine seal leak rate test .....	22
11.2.1	General .....	22
11.2.2	Test procedure .....	22
11.2.3	Acceptance criteria .....	22
12	Documentation .....	23
Annex A (informative)	Qualification of fillers.....	24
A.1	General.....	24
A.2	Dye penetration test with solid filler .....	24
A.3	Water diffusion test with solid filler.....	24
A.4	Tests on interfaces and connections of end fittings with filler .....	24
Annex B (informative)	Load definitions, relationship of loads.....	26
Annex C (informative)	Principle sketch of hollow insulators design assembly.....	29
Bibliography.....		31
Figure A.1	– Example of sample preparation for water diffusion test .....	25
Figure B.1	– Definitions according to IEC 62231 .....	26
Figure B.2	– Definitions according to IEC 61462 .....	27
Figure B.3	– Comparison of definitions IEC 61462 vs. IEC 62231 .....	28
Figure C.1	– Interface description for insulator with housing made by modular assembly .....	29
Figure C.2	– Interface description for insulator with housing made by injection moulding and overmold end fitting.....	30
Table 1	– Required design and type tests .....	14

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**COMPOSITE HOLLOW CORE STATION POST  
INSULATORS WITH AC VOLTAGE GREATER THAN  
1 000 V AND DC VOLTAGE GREATER THAN 1 500 V –  
DEFINITIONS, TEST METHODS AND ACCEPTANCE CRITERIA****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62772 has been prepared by IEC technical committee 36: Insulators. It is an International Standard.

This second edition cancels and replaces the first edition published in 2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) modifications of terms and definitions;
- b) modifications of tests procedures included in IEC TR 62039 and IEC 62217 (Hydrophobicity transfer test; Water diffusion test on the core with housing);
- c) harmonization of Table 1 (Required design and type tests) with other product standards;
- d) update of Annex A (Qualification of fillers);
- e) addition of a new informative Annex B (Load definitions, relationship of loads).

The text of this International Standard is based on the following documents:

Draft	Report on voting
36/569/FDIS	36/587/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/publications](http://www.iec.ch/publications).

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

Composite hollow core station post insulators consist of an insulating hollow core (tube), bearing the mechanical load protected by a polymeric housing, the load being transmitted to the core by end fittings. The hollow core is filled entirely with an insulating material. The core is made of resin impregnated fibres.

Composite hollow core station post insulators are typically applied as post insulators in substations. In order to perform the design tests, IEC 62217 is to be applied for materials and interfaces of the insulator. Some tests have been grouped together as "design tests", to be performed only once on insulators which satisfy the same design conditions. For all design tests on composite hollow core station post insulators, the common clauses defined in IEC 62217 are applied. As far as practical, the influence of time on the electrical and mechanical properties of the components (core material, housing, interfaces etc.) and of the complete composite hollow core station post insulator has been considered in specifying the design tests to ensure a satisfactory life-time under normally known stress conditions in service.

This document relates to IEC 61462, *Composite hollow insulators – Pressurized and unpressurized insulators for use in electrical equipment with rated voltage greater than 1 000 V – Definitions, test methods, acceptance criteria and design recommendations*, as well as IEC 62231, *Composite station post insulators for substations with AC voltages greater than 1 000 V up to 245 kV – Definitions, test methods and acceptance criteria*. Tests and requirements described in IEC 62231 can be used despite the intended operating voltage limit for substations.

The use of polymeric housing materials that show hydrophobicity and hydrophobicity transfer mechanism (HTM) is preferred for composite hollow core station post insulators. This is due to the fact that the influence of diameter can be significant for hydrophilic surfaces (see also IEC 60815-3). For instance silicone rubber is recognized as successful countermeasure against severe polluted service conditions. For the time being, the 1 000 h AC tracking and erosion test of IEC 62217 is used to establish a minimum requirement for the tracking and erosion resistance, for both AC and DC.

Composite hollow core station post insulators are used in both AC and DC applications. Before the appropriate standard for DC applications will be issued, the majority of tests listed in this standard can also be applied to DC insulators. In spite of this, a specific tracking and erosion test procedure for DC applications as a design test is still being considered to be developed. Some information about the difference of AC and DC material erosion test can be found in the CIGRE Technical Brochure 611 [8]<sup>1</sup>. For the time being, the 1 000 h AC tracking and erosion test of IEC 62217 is used to establish a minimum requirement for the tracking and erosion resistance.

---

<sup>1</sup> Numbers in square brackets refer to the Bibliography.



# COMPOSITE HOLLOW CORE STATION POST INSULATORS WITH AC VOLTAGE GREATER THAN 1 000 V AND DC VOLTAGE GREATER THAN 1 500 V – DEFINITIONS, TEST METHODS AND ACCEPTANCE CRITERIA

## 1 Scope

This document, which is an International Standard, applies to composite hollow core station post insulators consisting of a load-bearing insulating tube (core) made of resin impregnated fibres, insulating filler material (solid, liquid, gaseous – pressurized or unpressurized), a housing (outside the insulating tube) made of polymeric material (for example silicone or ethylene-propylene) and fixing devices at the ends of the insulating tube. Composite hollow core station post insulators as defined in this standard are intended for general use in substations in both, outdoor and indoor environments, operating with a rated AC voltage greater than 1 000 V and a frequency not greater than 100 Hz or for use in direct current systems with a rated voltage greater than 1 500 V DC.

The object of this document is:

- to define the terms used;
- to specify test methods;
- to specify acceptance criteria.

All the tests in this document, apart from the thermal-mechanical test, are performed at normal ambient temperature. This document does not specify tests that are characteristic of the apparatus of which the composite hollow core station post insulator ultimately may form a part (e.g. disconnect switch, reactor support, HVDC valves).

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60168, *Tests on indoor and outdoor post insulators of ceramic material or glass for systems with nominal voltages greater than 1000 V*

IEC 61109, *Insulators for overhead lines – Composite suspension and tension insulators for AC systems with a nominal voltage greater than 1 000 V – Definitions, test methods and acceptance criteria*

IEC 61462, *Composite hollow insulators – Pressurized and unpressurized insulators for use in electrical equipment with rated voltage greater than 1 000 V – Definitions, test methods, acceptance criteria and design recommendations*

IEC 62217, *Polymeric HV insulators for indoor and outdoor use – General definitions, test methods and acceptance criteria*

IEC 62231:2006, *Composite station post insulators for substations with AC voltages greater than 1 000 V up to 245 kV – Definitions, test methods and acceptance criteria*

IEC TR 62039, *Selection guidelines for polymeric materials for outdoor use under HV stress*

### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

#### 3.1

##### **composite hollow core station post insulator**

post insulator, consisting of at least three insulating parts, namely a tube, a housing with or without sheds, and an internal filler

Note 1 to entry: End fittings are attached to the insulating tube. The housing, with or without sheds, may be omitted in case of specific environmental conditions (e.g. indoor).

Note 2 to entry: A hollow insulator can be made from one or more permanently assembled insulating elements

#### 3.2

##### **post insulator**

insulator intended to give rigid support to a live part which is to be insulated from earth or from another live part

Note 1 to entry: A post insulator may be an assembly of a number of post insulator units (stack).

Note 2 to entry: Post insulators for substations are also known as station post insulators.

[SOURCE: IEC 60050-471:2007, 471-04-01, modified – addition of "(stack)" in Note 1 to entry]

#### 3.3

##### **tube (core)**

central internal insulating part of a composite hollow core station post insulator which provides the mechanical characteristics

Note 1 to entry: The housing, insulating filler material and sheds are not part of the core.

Note 2 to entry: Resin impregnated fibres are structured in such a manner as to achieve sufficient mechanical strength. Layers of different fibres may be used to fulfil special requirements.

#### 3.4

##### **filler**

insulating material filling the entire internal space (solid, liquid, gaseous – pressurized or unpressurized) of the hollow core station post insulator

#### 3.5

##### **fixing device (end fitting)**

integral component or formed part of an insulator intended to connect it to a supporting structure, or to a conductor, or to an item of equipment, or to another insulator

Note 1 to entry: Where the end fitting is metallic, the term "metal fitting" is normally used.

[SOURCE: IEC 60050-471:2007, 471-01-06, modified – addition of "fixing device" in term]

#### 3.6

##### **coupling**

part of the end fitting which transmits the load to the accessories external to the insulator

[SOURCE: IEC 62217:2012, 3.14]

### 3.7 connection zone

zone where the mechanical load is transmitted between the insulating body and the end fitting

[SOURCE: IEC 62217:2012, 3.13]

### 3.8 housing

external insulating part of composite hollow core station post insulator providing necessary creepage distance and protecting the tube from the environment

Note 1 to entry: If an intermediate sheath is used it forms a part of the housing.

[SOURCE: IEC 62217:2012, 3.7]

### 3.9 shed

insulating part, projecting from the insulator trunk, intended to increase the creepage distance

Note 1 to entry: The shed can be with or without ribs.

[SOURCE: IEC 60050-471:2007, 471-01-15]

### 3.10 insulator trunk

central insulating part of an insulator from which the sheds project

Note 1 to entry: Also known as shank on smaller insulators.

[SOURCE: IEC 60050-471:2007, 471-01-11]

### 3.11 creepage distance

shortest distance or the sum of the shortest distances along the surface of an insulator between two conductive parts which normally have the operating voltage between them

Note 1 to entry: The surface of any non-insulating jointing material is not considered as forming part of the creepage distance.

[SOURCE: IEC 60050-471:2007, 471-01-04, modified – removal of Note 2 to entry]

### 3.12 arcing distance

shortest distance in the air external to the insulator between the metallic parts which normally have the operating voltage between them

[SOURCE: IEC 60050-471:2007, 471-01-01]

### 3.13 interface

contact surface between the different materials

Note 1 to entry: Various interfaces occur in most composite insulators (cf. Annex C), e.g.

- between housing and end fittings,
- between various parts of the housing; e.g. between sheds, or between sheath and sheds,
- between tube and housing
- between tube and filler.

[SOURCE: IEC 62217:2012, 3.11, modified – addition of "contact"]

### **3.14 damage limit of the tube under mechanical stress**

limit below which mechanical loads can be applied, at normal ambient temperature, without micro damage to the composite tube

Note 1 to entry: Applying such loads means that the tube is in a reversible elastic phase. If the damage limit of the tube is exceeded, the tube is in an irreversible plastic phase, which means permanent damage to the tube which may not be visible at a macroscopic level (for a quantitative definition see Annex C of IEC 61462).

### **3.15 maximum mechanical load MML**

highest cantilever bending load which is expected to be applied to the composite hollow core station post insulators in accordance with IEC 61462

Note 1 to entry: The MML of the composite hollow core station post insulator is specified by the insulator manufacturer.

### **3.16 specified mechanical load SML**

cantilever bending load specified by the manufacturer that is used in the mechanical tests, and which is verified during a type test at normal ambient temperature

Note 1 to entry: The SML forms the basis of the selection of composite hollow station post insulators with regard to external loads.

### **3.17 specified cantilever load SCL**

cantilever load to be withstood by the insulator when tested under the specified conditions in accordance with IEC 62231

### **3.18 maximum design cantilever load MDCL**

load level above which damage to the insulator begins to occur and that should not be exceeded in service in accordance with IEC 62231

Note 1 to entry: For more information to load philosophies and relationships, see Annex B.

### **3.19 specified torsion load SToL**

torsion load level which can be withstood by the insulator when tested under the specified conditions in accordance with IEC 62231

### **3.20 maximum design torsion load MDToL**

load level above which damage to the insulator begins to occur and that should not be exceeded in service in accordance with IEC 62231

### **3.21 specified tension load STL**

tension load which can be withstood by the insulator when tested under the specified conditions in accordance with IEC 62231

**3.22**  
**maximum design tension load**  
**MDTL**

load level above which damage to the insulator begins to occur and that should not be exceeded in service in accordance with IEC 62231

**3.23**  
**specified compression load**  
**SCoL**

compression load to be withstood by the insulator when tested under the specified conditions in accordance with IEC 62231

**3.24**  
**buckling load**

compression load that induces buckling of the insulator core in accordance with IEC 62231

**3.25**  
**maximum design compression load**  
**MDCoL**

load level above which damage to the insulator begins to occur and that should not be exceeded in service in accordance with IEC 62231

**3.26**  
**failing load of a composite hollow core station post insulator**

load at ultimate failure of the insulator, maximum load that can be reached when the insulator is tested under the specified conditions (valid for bending or pressure tests)

Note 1 to entry: Damage to the tube is likely to occur at loads lower than the insulator failing load.

**3.27**  
**deflection under cantilever load**

displacement of a point on an insulator, measured perpendicularly to its axis, under the effect of a load applied perpendicularly to this axis [2772:2023](https://standards.iteh.ai/catalog/standards/sist/15f65fa4-7bb5-45da-a2f7-9b591ecb2ecc/iec-62772-2023)

Note 1 to entry: Deflection/load relationships are determined by the manufacturer.

**3.28**  
**residual deflection**

difference between the initial deflection of a composite hollow core station post insulator prior to bending load application, and the final deflection after release of the load

**3.29**  
**residual angular displacement**

difference between the initial angular displacement, if any, of one of the insulator end fitting with respect to the other insulator end fitting measured prior to the application of the torsion load and the final angular displacement measured after torsion load release

Note 1 to entry: The residual angular displacement may depend on the duration of application of the torsion load and on the time duration between the torsion load release and the measurement of the displacement.

**3.30**  
**overpressure**

pressure above ambient pressure within a pressurized enclosure

[SOURCE: IEC 60050-426:2020, 426-09-16]

**3.31**  
**maximum service pressure**  
**MSP**

maximum overpressure in service which is specified by the equipment manufacturer

**3.32**  
**specified internal pressure**  
**SIP**

internal overpressure specified by the manufacturer which is verified during a type test at normal ambient temperature

Note 1 to entry: The SIP is specified as the short-time withstand design limit, under which the insulator structure stays intact, but damages may already occur. It can be higher than  $4 \times \text{MSP}$ .

**3.33**  
**pressurized insulator**

insulator permanently filled with gas or liquid whose maximum service pressure is greater than 0,05 MPa overpressure

**3.34**  
**unpressurized insulator**

insulator is an insulator permanently filled with gas or liquid whose maximum service pressure is smaller than or equal to 0,05 MPa overpressure

**3.35**  
**specified temperatures**

highest and lowest temperature permissible for the composite hollow core station post insulator

Note 1 to entry: The specified temperatures are specified by the manufacturer.

**3.36**  
**manufacturer**

individual or organization producing the composite hollow core station post insulator

**3.37**  
**equipment manufacturer**

individual or organization producing the electrical equipment utilizing the composite hollow core station post insulator

[IEC 62772:2023](https://standards.iteh.ai/catalog/standards/sist/15f65fa4-7bb5-45da-a2f7-9b591ecb2ecc/iec-62772-2023)

**3.38**  
**lot**

group of insulators offered for acceptance from the same manufacturer, of the same design and manufactured under similar conditions of production

Note 1 to entry: One or more lots may be offered together for acceptance: the lot(s) offered may consist of the whole, or part, of the quantity ordered.

[SOURCE: IEC 62155:2003, 3.22, modified – removal of "hollow", removal of "or hollow insulator bodies"]

## **4 Identification and marking**

The manufacturer's drawing shall show the relevant dimensions and values necessary for identifying and testing the insulator in accordance with this document. The drawing shall also show applicable manufacturing tolerances. In addition, the relevant IEC designation, when available, shall be stated on the drawing.

Each composite hollow core station post insulator shall be marked with the name or trade mark of the manufacturer and the year of manufacture. In addition, each hollow core station post composite insulator shall be marked with the type reference and serial numbers in order to allow identification. In addition, each insulator shall be marked with at least the maximum design mechanical load, for example: MDCL: 4 kN. This marking shall be legible and indelible.