



Standard Test Method for Evaluating Thermal EMF Properties of Base-Metal Thermocouple Connectors¹

This standard is issued under the fixed designation E2820; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This standard describes a thermal emf test method for base-metal thermocouple connectors including Types E, J, K, N, and T. Standard connectors such as found in Specifications E1129/E1129M and E1684/E1684M as well as non-standard connector configurations and connector components can be evaluated using this method.

1.2 The measured emf is reported as an equivalent temperature deviation or error relative to a reference thermocouple of the same type. This method can be used to verify deviations introduced by the connector greater than or equal to 1°C.

1.3 The connector is tested with thermocouple contacts axially aligned with a temperature gradient using a specified thermal boundary condition. The actual temperature difference developed across the connector and corresponding error will depend on the connector design.

1.4 Connector contacts are often fabricated from raw materials having temperature-emf relationships in accordance with Specification E230/E230M. However, verifying Specification E230/E230M tolerances is not within the scope of this method.

1.5 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.6 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.7 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

¹ This test method is under the jurisdiction of ASTM Committee E20 on Temperature Measurement and is the direct responsibility of Subcommittee E20.13 on Thermocouples - Materials and Accessories Specifications.

Current edition approved May 1, 2019. Published May 2019. Originally approved in 2011. Last previous edition approved in 2013 as E2820 – 13. DOI: 10.1520/E2820-13R19.

2. Referenced Documents

2.1 ASTM Standards:²

- E220 Test Method for Calibration of Thermocouples By Comparison Techniques
- E230/E230M Specification for Temperature-Electromotive Force (emf) Tables for Standardized Thermocouples
- E344 Terminology Relating to Thermometry and Hydrometry
- E563 Practice for Preparation and Use of an Ice-Point Bath as a Reference Temperature
- E1129/E1129M Specification for Thermocouple Connectors
- E1684/E1684M Specification for Miniature Thermocouple Connectors
- E2488 Guide for the Preparation and Evaluation of Liquid Baths Used for Temperature Calibration by Comparison

3. Terminology

3.1 *Definitions*—The definitions given in Terminology E344 apply to the terms used in this standard.

4. Summary of Test Method

4.1 The connector is tested as part of a thermocouple circuit and compared to a reference thermocouple of the same type and material lot.

4.2 Measurements are made while the connector is subjected to a temperature gradient established by a specified boundary condition.

4.3 Performance is evaluated at a fixed position within a dry-well furnace or stirred liquid bath (Method 1 or 2A respectively) or variable position within a stirred liquid bath (Method 2B). The latter method can be used to survey the connector to identify a position within the thermal gradient that produces a maximum output deviation.

4.4 Results are interpreted relative to the properties of the reference thermocouple.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

5. Significance and Use

5.1 A thermocouple connector, exposed to a temperature difference, contributes to the output of a thermocouple circuit. The output uncertainty allocated to the connector depends on the connector design and temperature gradient.

5.2 Connector performance can be classified based on the results of this method and used as part of a component specification.

5.3 The method can be used as an engineering tool for evaluating different connector designs tested under similar thermal conditions.

6. Apparatus

6.1 The apparatus includes a temperature source, thermocouple readout device or voltmeter and ice-bath as shown in Fig. 1 and Fig. 2. An ice-bath is needed only if the readout does not provide cold junction compensation.

6.2 The thermocouple readout device or voltmeter shall have two or more channels and have equivalent temperature resolution of at least 0.1°C. The difference between channels shall not exceed the equivalent of 0.1°C when supplied with the same voltage input.

6.3 The temperature source heats the measuring junctions and produces a temperature gradient across the connector. The source is either a dry-well furnace or stirred liquid bath depending on the specified method.

6.3.1 *Method 1*—a temperature controlled dry-well furnace with an immersion depth of at least 100 mm and the capability of maintaining the specified test temperature within 1°C.

6.3.2 *Method 2*—a temperature controlled stirred liquid bath of non-conductive fluid with an immersion depth of at least 150 mm and the capability of maintaining the specified temperature within 1°C. Comparison calibration baths as described in Guide E2488 are suitable for this test.

7. Hazards

7.1 Review the Material Safety Data Sheet (MSDS) before using a fluid in a temperature-controlled bath. Temperature limits, flammability, vapor pressure, toxicity and chemical stability are important factors in determining a suitable fluid.

8. Preparation of Apparatus

8.1 The apparatus requires a dual thermocouple circuit with a common measuring junction. The circuit shall be fabricated from the same spool of wire. Except for the connector under test, the length of wire shall be continuous without splices or other connections between the measuring junction and the readout device.

8.2 The thermocouple wire shall carry the same letter designation (for example, Type K) as the connector under test. The wire shall conform to the special tolerance in Specification E230/E230M over the range of 0°C to the maximum specified connector test temperature. The wire size shall be 24 gage (0.5 mm) unless specified otherwise.

8.3 The test connector shall be installed approximately 70 mm from the measuring junction. When testing in a dry-well furnace in accordance with Method 1, a thermally and electrically insulating gasket shall be used to seal the furnace entrance, accentuating the temperature gradient across the




FIG. 1 Test Schematic Using a Readout Device with Cold Junction Compensation, Providing Temperature Indications of the Test Thermocouple T_{test} and Reference Thermocouple T_{ref}




FIG. 2 Test Schematic Using a Voltmeter and Reference Junctions at 0°C

connector. Placing the gasket between the plug and jack is generally the easiest way to control the position of the connector within the temperature gradient (Fig. 3-a).

8.4 When testing in accordance with Method 2 in a liquid bath, the connector and a portion of the thermocouple shall be attached to an insulating rod to support the sample during the test (Fig. 3-b).

8.5 The 0°C reference junctions (if needed) shall be prepared using the same approach used for thermocouple calibration in accordance with Test Method E220. The copper wires shall be thermocouple type TP in accordance with Specification E230/E230M and shall all be cut from the same spool.

8.6 The 0°C ice-bath (if needed) shall be prepared in accordance Practice E563.

9. Procedure

9.1 Set up the temperature source for the specified test condition (Table 1).

9.2 Connect both thermocouple circuits to the readout device or meter. With the common measuring junction and connector at room temperature, verify the difference between circuits is within the equivalent of 0.1°C. For voltage outputs, the difference expressed in °C is determined as follows.