

---

# International Standard



# 4411

---

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION • МЕЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ • ORGANISATION INTERNATIONALE DE NORMALISATION

---

## Hydraulic fluid power — Valves — Determination of pressure differential/flow characteristics

*Transmissions hydrauliques — Appareils de distribution — Détermination des caractéristiques pression différentielle/débit*

First edition — 1986-08-15

ITeH STANDARD PREVIEW  
(standards.iteh.ai)

[ISO 4411:1986](https://standards.iteh.ai/catalog/standards/sist/f63fd3d-b12e-45a3-a9dd-2438ebef11ec/iso-4411-1986)

<https://standards.iteh.ai/catalog/standards/sist/f63fd3d-b12e-45a3-a9dd-2438ebef11ec/iso-4411-1986>

---

UDC 621.646

Ref. No. ISO 4411-1986 (E)

**Descriptors :** hydraulic fluid power, hydraulic equipment, valves, hydraulic valves, tests, determination, differential pressure.

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work.

Draft International Standards adopted by the technical committees are circulated to the member bodies for approval before their acceptance as International Standards by the ISO Council. They are approved in accordance with ISO procedures requiring at least 75 % approval by the member bodies voting.

International Standard ISO 4411 was prepared by Technical Committee ISO/TC 131  
*Fluid power systems.*

Users should note that all International Standards undergo revision from time to time and that any reference made herein to any other International Standard implies its latest edition, unless otherwise stated.

## Contents

	Page
<b>0</b> Introduction .....	1
<b>1</b> Scope and field of application .....	1
<b>2</b> Reference .....	1
<b>3</b> Definitions .....	1
<b>4</b> Symbols and units .....	2
<b>5</b> Test installations .....	2
<b>5.1</b> Test circuits .....	2
<b>5.2</b> Pressure-tapping points .....	3
<b>5.3</b> Filtration .....	3
<b>6</b> Test procedures .....	3
<b>6.1</b> Test fluid .....	3
<b>6.2</b> Temperatures .....	3
<b>6.3</b> Steady-state conditions .....	3
<b>6.4</b> Performance .....	4
<b>6.5</b> Pressure differential .....	4
<b>6.6</b> Presentation of test results .....	4
<b>7</b> Identification statement .....	4
 <b>Annexes</b>	
<b>A</b> Errors and classes of measurement .....	7
<b>B</b> Pipe loss .....	8
<b>C</b> Use of practical units .....	10
<b>D</b> Pre-test checklist .....	11

iTeh STANDARD PREVIEW  
(standards.iteh.ai)  
ISO 4411:1986  
<https://standards.iteh.ai/catalog/standards/sist/f63fd3d-b12e-45a3-a9dd-2024-4411-1986>

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

This page intentionally left blank

[ISO 4411:1986](#)

<https://standards.iteh.ai/catalog/standards/sist/f63fd3d-b12e-45a3-a9dd-2438ebef11ec/iso-4411-1986>

# Hydraulic fluid power — Valves — Determination of pressure differential/flow characteristics

## 0 Introduction

In hydraulic fluid power systems, power is transmitted and controlled through a liquid under pressure within an enclosed circuit. Hydraulic valves control the direction, pressure or flow rate of the fluid in the system.

When the fluid flows through a valve it encounters some resistance which results in a loss of pressure called "pressure differential".

This International Standard is intended to unify testing methods for hydraulic fluid power valves to enable the pressure differential/flow characteristics of different valves to be compared.

## 1 Scope and field of application

This International Standard specifies methods for determining, under steady-state conditions, the pressure differential caused by the flow through any given path in a hydraulic fluid power valve. Requirements for test installations, procedures and presentation of results are specified.

This International Standard may also be applied to other fluid power components where similar conditions apply.

Accuracy of measurement is divided into three classes (A, B and C) which are explained in annex A. Guidance as to the use of practical units for the presentation of results is given in annex C. Annex D provides a pre-test checklist of those items where agreement is recommended between the parties concerned.

## 2 Reference

ISO 1219, *Fluid power systems and components — Graphic symbols*.

## 3 Definitions

For the purposes of this International Standard, the following definitions apply.

**3.1 nominal diameter of valve,  $D$ :** The manufacturer's values for the nominal diameter of the valve.

**3.2 flow rate,  $q_V$ :** The volume rate of flow at the point of measurement, see 5.1.11.

**3.3 valve-related fluid velocity,  $u$ :** The mean velocity of the fluid based upon the flow rate  $q_V$  and the valve diameter  $D$ .

**3.4 pipe-related fluid velocity,  $v$ :** The mean velocity of the fluid based upon the flow rate  $q_V$  and the pipe internal diameter  $d$ .

**3.5 Reynolds number,  $Re$ :** A dimensionless quantity defined by the expressions

$$Re = \frac{uD}{\nu} \quad (\text{valve-related}) \text{ and}$$

$$Re = \frac{vd}{\nu} \quad (\text{pipe-related})$$

**3.6 pressure differential,  $\Delta p$ :** The pressure loss attributed to the valve (see 6.5).

**3.7 loss coefficient,  $k$ :** A coefficient used in non-dimensional presentation of valve loss. It is defined by the expression

$$k = \frac{2\Delta p}{\rho u^2}$$

**3.8 pipe length,  $l$ :** The sum of the pipe lengths between the upstream and downstream pressure-tapping points.

**3.9 friction factor,  $\mu$ :** A coefficient used in non-dimensional presentation of pipe loss, see annex B.

**4 Symbols and units**

**4.1** The symbols and units used throughout this International Standard are as shown in table 1.

**4.2** The graphical symbols used in figures 1 to 3 are in accordance with ISO 1219.

**5 Test installations**

**5.1 Test circuits**

**5.1.1** A circuit suitable for testing valves as shown in figure 1 shall be used.

NOTE — Figure 1 illustrates a basic circuit which does not incorporate all the safety devices necessary to protect against damage in the event of component failure. It is important that those responsible for carrying out the test give due consideration to safeguarding both personnel and equipment.

**5.1.2** A fluid supply with controllable flow shall be used.

**5.1.3** A pressure-relief valve shall be installed in the supply line to protect the circuit from excess pressures.

**5.1.4** To establish a steady flow pattern at the upstream pressure tapping, the length of pipe upstream of that tapping shall conform with the following requirements:

- a) for class A measurement accuracy, a visibly straight, uniform bore pipe length of  $50d$  shall be used;
- b) for class B or C measurement accuracy, a visibly straight, uniform bore pipe length of at least  $10d$  shall be used.

**5.1.5** For all classes of accuracy of measurement, a visibly straight, uniform bore pipe length of  $5d$  shall be used between the upstream pressure tapping and the valve.

**5.1.6** To ensure adequate pressure recovery, a visibly straight, uniform bore pipe length of  $10d$  shall be used between the valve and the downstream pressure tapping.

**5.1.7** A visibly straight, uniform bore pipe length of  $5d$  shall be used between the downstream pressure tapping and the temperature-measuring point.

ISO 4411:1986  
<https://standards.itech.ai/catalog/standards/sist/f63fd3d-b12e-45a3-a9dd-438c13811166/iso-4411-1986>  
**Table 1 Symbols and units**

Reference clause	Quantity	Symbol	Dimension <sup>1)</sup>	Unit <sup>2)</sup>
3.1	Nominal diameter of valve	$D$	L	m
3.2	Volume flow rate	$q_V$	$L^3 T^{-1}$	$m^3/s$
3.3	Fluid velocity — valve-related	$u$	$LT^{-1}$	m/s
3.4	Fluid velocity — pipe-related	$v$	$LT^{-1}$	m/s
3.5	Reynolds number	$Re$	pure number	
3.6	Pressure differential	$\Delta p$	$ML^{-1} T^{-2}$	$Pa^3)$
3.7	Coefficient — valve loss	$k$	pure number	
3.8	Pipe length	$l$	L	m
3.9	Friction factor — pipe	$\mu$	pure number	
—	Inside diameter of pipe	$d$	L	m
—	Temperature	$\theta$	$\Theta$	K
—	Kinematic viscosity	$\nu$	$L^2 T^{-1}$	$m^2/s$
—	Mass density	$\rho$	$ML^{-3}$	$kg/m^3$

1) M = mass; L = length; T = time;  $\Theta$  = temperature  
 2) The use of practical units for the presentation of results is described in annex C.  
 3) 1 Pa = 1 N/m<sup>2</sup>

**5.1.8** A visibly straight, uniform bore pipe length of  $5d$  shall be used downstream of the temperature-measuring point.

**5.1.9** Pipes and fittings consistent with the nominal diameter of the valve shall be used.

**5.1.10** All pipes shall be mounted in the horizontal plane; if this is not possible, a correction factor shall be applied to the measured pressures.

**5.1.11** A flowmeter shall be installed to measure the flow rate at a point downstream of the pipe length described in 5.1.8.

## 5.2 Pressure-tapping points

**5.2.1** For class A measurement accuracy, static pressure-measuring connections shall be used which consist of a piezometer ring having

- a) two equally spaced tappings, if the pipe inside diameter,  $d$ , is equal to or less than 6 mm;
- b) three or more equally spaced tappings, if the pipe inside diameter,  $d$ , is greater than 6 mm.

The tappings and the measuring device shall be connected with one lead.

**5.2.2** For classes B and C measurement accuracy, single pressure-tappings may be used.

**5.2.3** The centreline of the tappings shall intersect the pipe centreline and be normal to it.

**5.2.4** No tapping shall be installed on the lowest point of the pipe.

**5.2.5** Pressure-tappings having identical diameters which are equal to or less than  $0,1d$ , but not less than 1 mm nor greater than 6 mm, shall be used.

**5.2.6** The length of a pressure-tapping hole shall not be less than twice its diameter.

**5.2.7** The connecting lead to the pressure-measuring device shall have a cross-sectional area of not less than half the total area of the tapping holes.

## 5.3 Filtration

**5.3.1** A filter shall be installed which provides a standard of filtration approved by the valve manufacturer.

**5.3.2** The position and specific description of each filter used in the test circuit shall be stated.

## 6 Test procedures

### 6.1 Test fluid

**6.1.1** A test fluid approved by the manufacturer of the valve shall be used when carrying out the tests. Information concerning the fluid shall be recorded.

**6.1.2** For classes A and B measurement accuracy, the mass density,  $\rho$ , and the kinematic viscosity,  $\nu$ , from fluid samples taken from the test installation shall be measured immediately before the test.

**6.1.3** For class C measurement accuracy, it is permissible to use density and viscosity data obtained from the fluid supplier.

**6.1.4** The kinematic viscosity,  $\nu$ , and the mass density of the fluid,  $\rho$ , for the range of temperatures used in the test shall be stated.

### 6.2 Temperatures

**6.2.1** When a dimensional presentation is required (see 6.6.3) and the test is to be carried out with one stated fluid at one temperature, the temperature shall be controlled during the test within the limits specified in table 2.

**Table 2 — Permissible variation in indicated fluid temperature**

Class of measurement accuracy (see annex A)	A	B	C
Variation in temperature indication, K	$\pm 1,0$	$\pm 2,0$	$\pm 4,0$

**6.2.2** When a non-dimensional presentation is required (see 6.6.2), there is no requirement for the complete test to be carried out at one controlled temperature, but for each test condition the temperature is required to be stable within the limits specified in table 2.

**6.2.3** The tests shall be carried out within the range of fluid temperatures recommended by the valve manufacturer for the intended application of the valve.

### 6.3 Steady-state conditions

**6.3.1** All readings shall only be recorded after steady-state conditions have been reached.

**6.3.2** When steady-state test conditions are reached for a specific test condition, only one set of readings of individual quantities shall be taken over concurrent common time periods. Each reading shall be recorded as the mean value of each quantity being measured.

## 6.4 Performance

The number of sets of readings to be taken and their distribution over the range shall be selected to give a representative indication of the performance of the valve over the full range of flow selected for the test.

## 6.5 Pressure differential

Calculate the valve pressure loss,  $\Delta p$ , by subtracting the pipe loss (see annex B) from the total measured loss.

For this purpose, the connecting fittings shall be considered as being part of the valve.

## 6.6 Presentation of the test results

### 6.6.1 General

All test measurements and the results of calculations therefrom shall be tabulated by the testing agency and preferably also presented graphically as described in 6.6.2, 6.6.3 and 6.6.4.

### 6.6.2 Non-dimensional presentation

**6.6.2.1** For valves which have a fixed internal geometry, a non-dimensional graphical presentation as shown in figure 2<sup>1)</sup> shall be used. The flow is represented by the valve-related Reynolds number (see 3.5) and the pressure differential by a loss coefficient  $k$  (see 3.7).

**6.6.2.2** Calculate the values for  $Re$  and  $k$  (see 3.5 and 3.7), using known values of kinematic viscosity,  $\nu$ , and mass density,  $\rho$ , at each controlled temperature and plot  $k$  against  $Re$  on log-log scales.

NOTE — The results of a series of tests with different fluid kinematic viscosities and mass densities will produce one curve when the flow aperture dimensions of the valve are unaffected by changes in the rate of flow or pressure.

### 6.6.3 Dimensional presentation

When required for specific applications, the test results shall be presented dimensionally as a graph of pressure differential,  $\Delta p$ , against the flow rate,  $q_V$ . The kinematic viscosity and mass density at the controlled fluid temperature shall also be stated. An example is shown in figure 3<sup>1)</sup>.

NOTE — A dimensional presentation can be produced from the results of non-dimensional presentation by calculating the valve-related Reynolds numbers for given flow, finding the value of  $k$  from the  $k-Re$  curve and calculating the pressure differential by transposing the equation given in 3.7 as follows:

$$\Delta p = k \rho \frac{u^2}{2}$$

### 6.6.4 Valves with variable internal geometry

Where valves have an internal geometry which is variable as a function of flow or pressure, the procedure for a non-dimensional presentation, as described in 6.2.2 and 6.6.2, will not result in one curve; a dimensional presentation, as described in 6.2.1 and 6.6.3, is therefore implied.

A typical example of curves for a spring-loaded non-return valve is given in figure 4<sup>1)</sup>. When the valve is maintained in the fully open condition, a value for the loss coefficient,  $k$ , can be determined.


## 7 Identification statement (Reference to this International Standard)

Use the following statement in test reports, catalogues and sales literature when electing to comply with this International Standard:

"Test for the determination of pressure differential flow characteristics conforms to ISO 4411, *Hydraulic fluid power — Valves — Determination of pressure differential/flow characteristics*".

1) The graphical results shown in figures 2 to 4 are shown for style of presentation only; no specific or related values are intended.





- 1 Controllable flow supply
- 2 Relief valve (circuit protection)
- 3 Stop valve (normally fully open)
- 4 Pressure differential measuring device
- 5 Test valve
- 6 Temperature at outlet of valve
- 7 Flowmeter

**iTeh STANDARD PREVIEW**  
(standards.iteh.ai)

Figure 1 — Test circuit diagram




Figure 2 — Non-dimensional presentation of directional control valve

1) 50d for class A measurement accuracy; > 10d for classes B and C measurement accuracy.