

INTERNATIONAL STANDARD



**Nuclear ~~power plants~~ facilities – Instrumentation systems important to safety –
Radiation monitoring for accident and post-accident conditions –
Part 1: General requirements**

Document Preview

[IEC 60951-1:2022](#)

<https://standards.iteh.ai/catalog/standards/iec/6f02dfc9-f4bf-4d6d-95c5-2d8e57cab3bb/iec-60951-1-2022>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2022 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

International Standards
standards.iteh.ai)
Document Preview

[IEC 60951-1:2022](https://standards.iteh.ai/catalog/standards/iec/6f02dfc9-f4bf-4d6d-95c5-2d8e57cab3bb/iec-60951-1-2022)

<https://standards.iteh.ai/catalog/standards/iec/6f02dfc9-f4bf-4d6d-95c5-2d8e57cab3bb/iec-60951-1-2022>



IEC 60951-1

Edition 3.0 2022-11
REDLINE VERSION

INTERNATIONAL STANDARD



**Nuclear ~~power plants~~ facilities – Instrumentation systems important to safety –
Radiation monitoring for accident and post-accident conditions –
Part 1: General requirements**

Document Preview

[IEC 60951-1:2022](#)

<https://standards.iteh.ai/catalog/standards/iec/6f02dfc9-f4bf-4d6d-95c5-2d8e57cab3bb/iec-60951-1-2022>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 27.120.20

ISBN 978-2-8322-6146-0

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	4
INTRODUCTION	6
1 Scope	11
2 Normative references	11
3 Terms and definitions	13
4 Design principles	18
4.1 General	18
4.2 Basic requirements related to functions	19
4.3 Measurement range	21
4.4 Energy response	21
4.5 Minimum detectable activity (or limit of detection)	21
4.6 Precision (or repeatability)	21
4.7 Accuracy (or relative error) Linearity	21
4.8 Measurement time	22
4.9 Response time	22
4.10 Overload performance	22
4.11 Ambient background shielding or compensation devices	22
4.12 Requirements related to accident conditions	23
4.13 Reliability	23
4.14 User interface	24
4.14.1 General	24
4.14.2 Display of measured value	24
4.14.3 Alarms	24
4.14.4 Status indication	25
4.14.5 Local indications	25
4.15 System testing, maintenance facilities and ease of decontamination	25
4.15.1 System testing	25
4.15.2 Maintenance facilities	26
4.15.3 Ease of decontamination	26
4.16 Electromagnetic interference	26
4.17 Power supplies	26
4.18 Interfaces	27
4.19 Sampling assembly	27
4.20 Quality	28
4.21 Type test report and certificate	28
5 Functional testing	29
5.1 General	29
5.2 General test procedures	30
5.2.1 General	30
5.2.2 Tests performed under standard test conditions	30
5.2.3 Tests performed with variation of influence quantities	30
5.2.4 Calculations and/or numerical simulations	33
5.2.5 Reference sources	34
5.2.6 Statistical fluctuations	35
5.3 Performance Radiation characteristics	35
5.3.1 Reference response	35

5.3.2	Sensitivity and relative response for solid sources	35
5.3.3	Accuracy (relative error) Linearity	36
5.3.4	Response to other artificial radionuclides	37
5.3.5	Response to background radiation	37
5.3.6	Precision (or repeatability)	38
5.3.7	Stability of the indication	38
5.3.8	Response time	39
5.3.9	Overload test characteristics	39
5.4	Electrical performance tests characteristics	40
5.4.1	Alarm trip range	40
5.4.2	Alarm trip stability	40
5.4.3	Fault alarm	41
5.4.4	Status indication and fault alarm tests	41
5.4.5	Warm-up time — Detection and measuring assembly	41
5.4.6	Influence of supply variations	41
5.4.7	Short circuit withstand tests	42
5.5	Environmental performance test characteristics	43
5.5.1	Stability of performance after storage	43
5.5.2	Mechanical tests characteristics	43
5.5.3	Stability of performance with variation of temperature and humidity	45
5.5.4	Electromagnetic compatibility	46
Bibliography		49
Table 1 – Overview of the standards covering the domain of radiation monitoring in nuclear facilities		7
Table 2 – Reference conditions and standard test conditions		31
Table 3 – Tests performed under standard test conditions		32
Table 4 – Tests performed with variation of influence quantities		33

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**NUCLEAR ~~POWER PLANTS~~ FACILITIES – INSTRUMENTATION SYSTEMS
IMPORTANT TO SAFETY – RADIATION MONITORING FOR
ACCIDENT AND POST-ACCIDENT CONDITIONS –****Part 1: General requirements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 60951-1:2009. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC 60951-1 has been prepared by subcommittee 45A: Instrumentation, control and electrical power systems of nuclear facilities, of IEC technical committee 45: Nuclear instrumentation. It is an International Standard.

This third edition cancels and replaces the second edition published in 2009. This edition constitutes a technical revision.

The main technical changes with regard to the previous edition are as follows.

- Title modified.
- To be consistent with the categorization of the accident condition.
- To update the references to new standards published since the second edition.
- To update the terms and definitions.

The text of this standard is based on the following documents:

Draft	Report on voting
45A/1440/FDIS	45A/1449/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

A list of all parts of IEC 60951 series, under the general title *Nuclear facilities – Instrumentation systems important to safety – Radiation monitoring for accident and post-accident conditions*, can be found on the IEC website.

Future documents in this series will carry the new general title as cited above. Titles of existing documents in this series will be updated at the time of the next edition.

<https://standards.iteh.ai/catalog/standards/iec/6102dfc9-14bf-4d6d-95c5-2d8e57cab3bb/iec-60951-1-2022>

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

a) Technical background, main issues and organisation of the standard

This IEC standard specifically focuses on radiation monitoring systems (RMSs) used for ~~accident and post~~-accident operations.

According to the lessons learned from the Fukushima-Daiichi accident, it re-acknowledges a need to provide operators with reliable radiation monitoring data to allow them to understand the plant state during and after the accident conditions. To support the design of such instrumentation, it is necessary to provide general guidance on the design principles and performance criteria for radiation monitoring instrumentation applied during and after the accident conditions. In addition, the scope of IEC 63147 which provides criteria for accident monitoring instrumentation for nuclear power generating stations has evolved to include severe accident (SA) to accident conditions.

Thus, to address the specific lessons learned from the Fukushima-Daiichi accident, this standard categorizes accident condition into design basis accidents (DBA) and design extension conditions (DEC), including severe accident (SA).

This standard is intended for use by purchasers in developing specifications for their plant-specific radiation monitoring systems and by manufacturers to identify needed ~~product~~ equipment characteristics when developing systems for accident monitoring conditions. Some specific instrument characteristics such as measurement range, ~~required~~ energy response, and ~~ambient environment requirements~~ environmental withstanding conditions will depend on the specific application. In such cases, guidance is provided on determining the specific requirements, but specific requirements themselves are not stated.

This standard is one in a series of standards ~~covering post-accident radiation monitors important to safety~~ applicable to equipment for continuous monitoring of radiation level important to safety intended for use during design basis accidents (DBA) and design extension conditions (DEC) including severe accident (SA), and post-accident conditions. The full series is comprised of the following standards.

- IEC 60951-1 – General requirements
- IEC 60951-2 – Equipment for continuous off-line monitoring of radioactivity in gaseous effluents and ventilation air
- IEC 60951-3 – Equipment for continuous high range area gamma monitoring
- IEC 60951-4 – Equipment for continuous in-line or on-line monitoring of radioactivity in process streams.

b) Situation of the current standard in the structure of the IEC SC 45A standard series

The IEC 60951 series of standards are at the third level in the hierarchy of SC 45A standards. They provide guidance on ~~specification~~, design and testing of radiation monitoring equipment used for accident and post-accident conditions.

Other standards developed by SC 45A and SC 45B provide guidance on instruments used for monitoring radiation as part of normal operations. The IEC 60761 series provides requirements for equipment for continuous off-line monitoring of radioactivity in gaseous effluents in normal conditions. IEC 60861 provides requirements for equipment for continuous off-line monitoring of radioactivity in liquid effluents in normal conditions. IEC 60768 provides requirements for equipment for continuous in-line and on-line monitoring of radioactivity in process streams in normal and incident conditions. Finally, ISO 2889 gives guidance on gas and particulate sampling. ~~The relationship between these various radiation monitoring standards is given in Table 1.~~ In addition, IEC 62705 provides guidance on the application of existing IEC/ISO standards covering design and qualification of RMS. An overview of the standards covering the radiation monitoring in nuclear facilities is given in Table 1.

IEC 63147/IEEE Std 497™ provides general guidance for accident monitoring instrumentation. IEEE Std 497™ was directly adopted as a joint logo standard and a technical report, IEC TR 63123, was prepared to discuss the application of the joint standard within the IEC context.

The structure of this standard is adapted from the structure of IEC 63147/IEEE Std 497™, and the technical requirements of this standard are consistent with the requirements given in IEC 63147/IEEE Std 497™ together with the application guidance given in IEC TR 63123.

Table 1 – Overview of the standards covering the domain of radiation monitoring in nuclear facilities

Developer	ISO	SC 45A—Process and safety monitoring		SC 45B—Radiation protection and effluents monitoring
Scope	Sampling circuits and methods	Accident and post-accident conditions	Normal and incident conditions	
Gas, particulate and iodine with sampling (OFF-LINE)	ISO 2889	IEC 60951-1 and IEC 60951-2	IEC 60761 series and IEC 62302 (noble gases only)	
Liquid with sampling (OFF-LINE)	N/A	N/A	IEC 60861	
Process streams (gaseous effluents, steam or liquid) without sampling (ON or IN-LINE)	N/A	IEC 60951-1 and IEC 60951-4	IEC 60768	N/A
Area monitoring	N/A	IEC 60951-1 and IEC 60951-3	IEC 60532	
Central system	N/A	IEC 61504		IEC 61559 series

[IEC 60951-1:2022](https://standards.iteh.ai/catalog/standards/iec/6f02dfc9-f4bf-4d6d-95c5-2d8e57cab3bb/iec-60951-1-2022)

<https://standards.iteh.ai/catalog/standards/iec/6f02dfc9-f4bf-4d6d-95c5-2d8e57cab3bb/iec-60951-1-2022>

Developer	ISO		IEC			
			SC45A			SC45B
Scope	Sampling (Normal operation)	Calibration (Normal operation)	Normal operation, AOO	DBA	DEC	Normal operation
Radioactive noble gas off-line monitoring	ISO 2889	ISO 4037-1, ISO 4037-3	N/A	IEC 60951-1, IEC 60951-2	N/A	IEC 62302, IEC 60761-1, IEC 60761-3
Radioactive aerosol off-line monitoring	ISO 2889	ISO 4037-1, ISO 4037-3	N/A	IEC 60951-1, IEC 60951-2	N/A	IEC 60761-1, IEC 60761-2
Radioactive iodine off-line monitoring	ISO 2889	ISO 4037-1, ISO 4037-3	N/A	IEC 60951-1, IEC 60951-2	N/A	IEC 60761-1, IEC 60761-4
Liquid off-line monitoring	N/A	N/A	N/A	N/A	N/A	IEC 60861
Tritium off-line monitoring	N/A	N/A	N/A	N/A	N/A	IEC 62303, IEC 60761-1, IEC 60761-5
On-line or in-line monitoring	N/A	ISO 4037-1, ISO 4037-3	IEC 60768	IEC 60951-1, IEC 60951-4	N/A	N/A
Area monitoring	N/A	ISO 4037-1, ISO 4037-3	IEC 61031	IEC 60951-1, IEC 60951-3		IEC 60532
Centralized system	N/A	N/A	IEC 61504, IEC 60960		N/A	IEC 61559-1
Classification/basic requirements	N/A	N/A	IEC 61513, IEC 60880, IEC 60987, IEC 61226, IEC 62138, IEC 62566, IEC 62566-2, IEC 62645, IEC 61250		N/A	N/A
Qualification	N/A	N/A	IEC/IEEE 60780-323, IEC/IEEE 60980-344, IEC 62003		N/A	IEC 62706

For more details on the structure of the IEC SC 45A standard series, see the item d) of this introduction.

c) Recommendations and limitations regarding the application of this standard

It is important to note that this standard establishes no additional functional requirements for **safety** systems important to safety.

d) Description of the structure of the IEC SC 45A standard series and relationships with other IEC documents and other bodies documents (IAEA, ISO)

~~The top-level document of the IEC SC 45A standard series is IEC 61513. It provides general requirements for I&C systems and equipment that are used to perform functions important to safety in NPPs. IEC 61513 structures the IEC SC 45A standard series.~~

~~IEC 61513 refers directly to other IEC SC 45A standards for general topics related to categorization of functions and classification of systems, qualification, separation of systems, defence against common cause failure, software aspects of computer based systems, hardware aspects of computer based systems, and control room design. The standards referenced directly at this second level should be considered together with IEC 61513 as a consistent document set.~~

~~At a third level, IEC SC 45A standards not directly referenced by IEC 61513 are standards related to specific equipment, technical methods, or specific activities. Usually these documents, which make reference to second-level documents for general topics, can be used on their own.~~

~~A fourth level extending the IEC SC 45A standard series, corresponds to the Technical Reports which are not normative.~~

~~IEC 61513 has adopted a presentation format similar to the basic safety publication IEC 61508 with an overall safety life-cycle framework and a system life-cycle framework and provides an interpretation of the general requirements of IEC 61508-1, IEC 61508-2 and IEC 61508-4, for the nuclear application sector. Compliance with IEC 61513 will facilitate consistency with the requirements of IEC 61508 as they have been interpreted for the nuclear industry. In this framework IEC 60880 and IEC 62138 correspond to IEC 61508-3 for the nuclear application sector.~~

~~IEC 61513 refers to ISO standards as well as to IAEA 50-C-QA (now replaced by IAEA GS-R-3) for topics related to quality assurance (QA).~~

~~The IEC SC 45A standards series consistently implements and details the principles and basic safety aspects provided in the IAEA code on the safety of NPPs and in the IAEA safety series, in particular the Requirements NS-R-1, establishing safety requirements related to the design of Nuclear Power Plants, and the Safety Guide NS-G-1.3 dealing with instrumentation and control systems important to safety in Nuclear Power Plants. The terminology and definitions used by SC 45A standards are consistent with those used by the IAEA.~~

The IEC SC 45A standard series comprises a hierarchy of four levels. The top-level documents of the IEC SC 45A standard series are IEC 61513 and IEC 63046.

IEC 61513 provides general requirements for instrumentation and control (I&C) systems and equipment that are used to perform functions important to safety in nuclear power plants (NPPs). IEC 63046 provides general requirements for electrical power systems of NPPs; it covers power supply systems including the supply systems of the I&C systems.

IEC 61513 and IEC 63046 are to be considered in conjunction and at the same level. IEC 61513 and IEC 63046 structure the IEC SC 45A standard series and shape a complete framework establishing general requirements for instrumentation, control and electrical power systems for nuclear power plants.

IEC 61513 and IEC 63046 refer directly to other IEC SC 45A standards for general requirements for specific topics, such as categorization of functions and classification of systems, qualification, separation, defence against common cause failure, control room design, electromagnetic compatibility, human factors engineering, cybersecurity, software and hardware aspects for programmable digital systems, coordination of safety and security requirements and management of ageing. The standards referenced directly at this second level should be considered together with IEC 61513 and IEC 63046 as a consistent document set.

At a third level, IEC SC 45A standards not directly referenced by IEC 61513 or by IEC 63046 are standards related to specific requirements for specific equipment, technical methods, or activities. Usually these documents, which make reference to second-level documents for general requirements, can be used on their own.

A fourth level extending the IEC SC 45 standard series, corresponds to the Technical Reports which are not normative.

The IEC SC 45A standards series consistently implements and details the safety and security principles and basic aspects provided in the relevant IAEA safety standards and in the relevant documents of the IAEA nuclear security series (NSS). In particular this includes the IAEA

requirements SSR-2/1, establishing safety requirements related to the design of nuclear power plants (NPPs), the IAEA safety guide SSG-30 dealing with the safety classification of structures, systems and components in NPPs, the IAEA safety guide SSG-39 dealing with the design of instrumentation and control systems for NPPs, the IAEA safety guide SSG-34 dealing with the design of electrical power systems for NPPs, the IAEA safety guide SSG-51 dealing with human factors engineering in the design of NPPs and the implementing guide NSS17 for computer security at nuclear facilities. The safety and security terminology and definitions used by the SC 45A standards are consistent with those used by the IAEA.

IEC 61513 and IEC 63046 have adopted a presentation format similar to the basic safety publication IEC 61508 with an overall life-cycle framework and a system life-cycle framework. Regarding nuclear safety, IEC 61513 and IEC 63046 provide the interpretation of the general requirements of IEC 61508-1, IEC 61508-2 and IEC 61508-4, for the nuclear application sector. In this framework, IEC 60880, IEC 62138 and IEC 62566 correspond to IEC 61508-3 for the nuclear application sector.

IEC 61513 and IEC 63046 refer to ISO 9001 as well as to IAEA GSR part 2 and IAEA GS-G-3.1 and IAEA GS-G-3.5 for topics related to quality assurance (QA).

At level 2, regarding nuclear security, IEC 62645 is the entry document for the IEC/SC 45A security standards. It builds upon the valid high level principles and main concepts of the generic security standards, in particular ISO/IEC 27001 and ISO/IEC 27002; it adapts them and completes them to fit the nuclear context and coordinates with the IEC 62443 series. At level 2, IEC 60964 is the entry document for the IEC/SC 45A control rooms standards, IEC 63351 is the entry document for the human factors engineering standards and IEC 62342 is the entry document for the ageing management standards.

NOTE 1 It is assumed that for the design of I&C systems in NPPs that implement conventional safety functions (e.g. to address worker safety, asset protection, chemical hazards, process energy hazards) international or national standards would be applied.

NOTE 2 IEC TR 64000 provides a more comprehensive description of the overall structure of the IEC SC 45A standards series and of its relationship with other standards bodies and standards.

[IEC 60951-1:2022](https://standards.iteh.ai/catalog/standards/iec/6f02dfc9-f4bf-4d6d-95c5-2d8e57cab3bb/iec-60951-1-2022)

<https://standards.iteh.ai/catalog/standards/iec/6f02dfc9-f4bf-4d6d-95c5-2d8e57cab3bb/iec-60951-1-2022>

NUCLEAR ~~POWER PLANTS~~ FACILITIES – INSTRUMENTATION SYSTEMS IMPORTANT TO SAFETY – RADIATION MONITORING FOR ACCIDENT AND POST-ACCIDENT CONDITIONS –

Part 1: General requirements

1 Scope

This part of IEC 60951 provides general guidance on the design principles and performance criteria for equipment to measure radiation and fluid (gaseous effluents or liquids) radioactivity levels at nuclear ~~power plants~~ facilities during and after ~~an accident~~ design basis accidents (DBA) and design extension conditions (DEC), including severe accident (SA). This document is limited to equipment for continuous monitoring of radioactivity in design basis accidents (DBA), design extension conditions (DEC), including severe accident (SA) and post-accident conditions.

The purpose of this document is to lay down ~~mandatory~~ general requirements and give examples of acceptable methods for equipment for continuous monitoring of radioactivity within the ~~plant~~ facility during and after ~~accident conditions in nuclear power plants using light water reactors~~ design basis accidents (DBA), design extension conditions (DEC), including severe accident (SA) in nuclear facilities.

It specifies, for the equipment described above, the general characteristics, general test procedures, radiation, electrical, safety and environmental characteristics and the identification and certification of the equipment. If this equipment is part of a centralized system for continuous radiation monitoring in a nuclear facility, there may be additional requirements from other standards related to this system.

Sample extraction and laboratory analysis, which are essential to a complete programme of effluent monitoring, are not within the scope of this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038: ~~2002~~2009, *IEC standard voltages*

IEC 60068-2-1:2007, *Environmental testing – Part 2-1: Tests – Test A: Cold*

IEC 60068-2-2:2007, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-6:2007, *Environmental testing – Part 2-6: Tests – Test Fc: Vibration (sinusoidal)*

IEC 60068-2-14:2009, *Environmental testing – Part 2-14: Tests – Test N: Change of temperature*

IEC 60068-2-30:2005, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60068-2-78:~~2004~~2012, *Environmental testing – Part 2-78: Tests – Test Cab: Damp heat, steady state*

IEC 60529, *Degrees of protections provided by enclosures (IP code)*

~~IEC 60780, Nuclear power plants – Electrical equipment of the safety system – Qualification~~

IEC/IEEE 60780-323:2016, *Nuclear facilities – Electrical equipment important to safety – Qualification*

IEC 60880, *Nuclear power plants – Instrumentation and control systems important to safety – Software aspects for computer-based systems performing category A functions*

~~IEC 60980, Recommended practices for Seismic qualification of electrical equipment of the safety system for nuclear generating stations~~

IEC/IEEE 60980-344, *Nuclear facilities – Equipment important to safety – Seismic qualification*

IEC 60987, *Nuclear power plants – Instrumentation and control important to safety – Hardware ~~design~~ requirements ~~for computer-based systems~~*

IEC 61000-4-2:2008, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3:~~2006~~2020, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*

IEC 61000-4-4:~~2004~~2012, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-5:~~2005~~2014, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

IEC 61000-4-6:~~2008~~2013, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

IEC 61000-4-8:~~2004~~2009, *Electromagnetic compatibility (EMC) – Part 4-8: Testing and measurement techniques – Power frequency magnetic field immunity test*

IEC 61000-4-12:~~2006~~2017, *Electromagnetic compatibility (EMC) – Part 4-12: Testing and measurement techniques – Ring wave immunity test*

IEC 61000-4-18:2019, *Electromagnetic compatibility (EMC) – Part 4-18: Testing and measurement techniques – Damped oscillatory wave immunity test*

IEC 61000-6-4:~~2006~~2018, *Electromagnetic compatibility (EMC) – Part 6-4: Generic standards – Emission standard for industrial environments*

IEC 61069-1:~~1994~~2016, *Industrial-process measurement, control and automation – Evaluation of system properties for the purpose of system assessment – Part 1: ~~General considerations and methodology~~ Terminology and basic concepts*

IEC 61226, *Nuclear power plants – Instrumentation, control and electrical power systems important to safety – ~~Classification of instrumentation and control functions~~ Categorization of functions and classification of systems*