

INTERNATIONAL STANDARD

Industrial communication networks – Fieldbus specifications –
Part 6-21: Application layer protocol specification – Type 21 elements
(standards.iteh.ai)

[IEC 61158-6-21:2019](https://standards.iteh.ai/catalog/standards/sist/39078629-f9cc-446f-a13b-83f44748e39d/iec-61158-6-21-2019)

<https://standards.iteh.ai/catalog/standards/sist/39078629-f9cc-446f-a13b-83f44748e39d/iec-61158-6-21-2019>





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

[IEC 61158-6-21:2019](https://standards.iteh.ai/catalog/standards/sist/39078629-9cc-446f-a13b-83f44748e39d/iec-61158-6-21-2019)

<https://standards.iteh.ai/catalog/standards/sist/39078629-9cc-446f-a13b-83f44748e39d/iec-61158-6-21-2019>

INTERNATIONAL STANDARD

**Industrial communication networks – Fieldbus specifications –
Part 6-21: Application layer protocol specification – Type 21 elements**

[IEC 61158-6-21:2019](https://standards.iteh.ai/catalog/standards/sist/39078629-f9cc-446f-a13b-83f44748e39d/iec-61158-6-21-2019)

<https://standards.iteh.ai/catalog/standards/sist/39078629-f9cc-446f-a13b-83f44748e39d/iec-61158-6-21-2019>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 25.040.40; 35.100.70; 35.110

ISBN 978-2-8322-7013-4

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
1.1 General.....	9
1.2 Overview.....	9
1.3 Specifications	9
1.4 Conformance	10
2 Normative references	10
3 Terms, definitions, symbols, abbreviations and conventions	10
3.1 Terms and definitions from other ISO/IEC standards.....	11
3.1.1 ISO/IEC 7498-1 terms.....	11
3.1.2 ISO/IEC 8822 terms.....	11
3.1.3 ISO/IEC 8824-1 terms.....	11
3.1.4 ISO/IEC 9545 terms.....	11
3.2 Other terms and definitions	11
3.3 Abbreviations and symbols	17
3.4 Conventions.....	18
3.4.1 General conventions	18
3.4.2 Convention for the encoding of reserved bits and octets	18
3.4.3 Conventions for the common coding of specific field octets.....	18
3.4.4 Conventions for APDU abstract syntax definitions	19
3.4.5 Conventions for APDU transfer syntax definitions	19
3.4.6 Conventions for AE state machine definitions.....	20
4 FAL syntax description	21
4.1 General.....	21
4.2 FAL-AR PDU abstract syntax	21
4.2.1 Top level definition	21
4.2.2 Confirmed send service	21
4.2.3 Unconfirmed send service	21
4.2.4 FalArHeader	21
4.2.5 InvokeID	21
4.2.6 ServiceType	21
4.3 Abstract syntax of PDU body	22
4.3.1 ConfirmedServiceRequest PDUs	22
4.3.2 ConfirmedServiceResponse PDUs.....	22
4.3.3 UnconfirmedServiceRequest PDUs.....	22
4.3.4 Error information.....	22
4.4 Protocol data units (PDUs) for application service elements (ASEs).....	23
4.4.1 PDUs for Application process ASE.....	23
4.4.2 PDUs for Service data object ASE	25
4.4.3 PDUs for Process data object ASE	28
5 Transfer Syntax	28
5.1 Overview of encoding.....	28
5.2 APDU header encoding.....	29
5.2.1 Encoding of FalArHeader field	29
5.2.2 Encoding of InvokeID Field	29

5.2.3	Encoding of Type field	29
5.3	APDU body encoding	30
5.3.1	General	30
5.4	Encoding of Data types	30
5.4.1	General description of data types and encoding rules	30
5.4.2	Transfer syntax for bit sequences	30
5.4.3	Encoding of a Boolean value	31
5.4.4	Encoding of an unsigned integer value	31
5.4.5	Encoding of a signed integer	31
5.4.6	Encoding of a floating point value	32
5.4.7	Encoding of an octet string value	32
5.4.8	Encoding of a visible string value	33
5.4.9	Encoding of a Unicode string value	33
5.4.10	Encoding of a time of day value	33
5.4.11	Encoding of a Time Difference value	33
6	FAL protocol state machines	34
7	AP context state machine	36
8	FAL service protocol machine	36
8.1	General	36
8.2	Common parameters of the primitives	36
8.3	AP ASE protocol machine	36
8.3.1	Primitive definitions	36
8.3.2	State machine	38
8.4	Service data object ASE protocol machine (SDOM)	40
8.4.1	Primitive definitions	40
8.4.2	State machine	41
8.5	Process data object ASE protocol machine (PDOM)	44
8.5.1	Primitive definitions	44
8.5.2	State machine	44
9	AR protocol machine	45
9.1	General	45
9.2	Point-to-point user-triggered confirmed client/server AREP (PTC-AR) ARPM	46
9.2.1	PTC-AR Primitive definitions	46
9.2.2	DLL mapping of PTC-AREP class	46
9.2.3	PTC-ARPM state machine	47
9.3	Multipoint network-scheduled unconfirmed publisher/subscriber AREP (MSU-AR) ARPM	48
9.3.1	MSU-AR primitive definitions	48
9.3.2	DLL mapping of MSU-AR class	49
9.3.3	MSU-ARPM state machine	49
9.4	Multipoint user-triggered unconfirmed publisher/subscriber AREP (MTU-AR) ARPM	51
9.4.1	MTU-AR primitive definitions	51
9.4.2	DLL mapping of MTU-AR class	51
9.4.3	MTU-ARPM state machine	52
10	DLL mapping protocol machine	53
10.1	Primitive definitions	53
10.1.1	Primitives exchanged between DMPM and ARPM	53
10.1.2	Parameters of ARPM/DMPM primitives	53

10.1.3	Primitives exchanged between DLL and DMPM	53
10.1.4	Parameters of DMPM/DLL primitives	54
10.2	DMPM state machine	54
10.2.1	DMPM states	54
10.2.2	DMPM state table	54
10.2.3	Functions used by DMPM	54
	Bibliography.....	55
Figure 1	– Common structure of specific fields.....	19
Figure 2	– APDU overview	29
Figure 3	– Type field	30
Figure 4	– Encoding of Time of Day value.....	33
Figure 5	– Encoding of Time Difference value.....	34
Figure 6	– Primitives exchanged between protocol machines.....	35
Figure 7	– State transition diagram of APAM.....	38
Figure 8	– State transition diagram of SDOM.....	41
Figure 9	– State transition diagram of PDOM.....	44
Figure 10	– State transition diagram of PTC-ARPM	47
Figure 11	– State transition diagram of MSU-ARPM.....	50
Figure 12	– State transition diagram of MTU-ARPM.....	52
Figure 13	– State transition diagram of DMPM	54
Table 1	– Conventions used for AE state machine definitions.....	20
Table 2	– Status code for the confirmed response primitive	23
Table 3	– Encoding of FalArHeader field.....	29
Table 4	– Transfer Syntax for bit sequences	30
Table 5	– Transfer syntax for data type UNSIGNEDn.....	31
Table 6	– Transfer syntax for data type INTEGERn.....	32
Table 7	– Primitives exchanged between FAL-user and APAM.....	37
Table 8	– Parameters used with primitives exchanged FAL-user and APAM	38
Table 9	– APAM state table – Sender transitions	38
Table 10	– APAM state table – Receiver transitions	39
Table 11	– Functions used by the APAM.....	39
Table 12	– Primitives exchanged between FAL-user and SDOM	40
Table 13	– Parameters used with primitives exchanged FAL-user and SDOM.....	41
Table 14	– SDOM state table – Sender transitions	42
Table 15	– SDOM state table – Receiver transitions	43
Table 16	– Functions used by the SDOM	43
Table 17	– Primitives exchanged between FAL-user and PDOM	44
Table 18	– Parameters used with primitives exchanged between FAL-user and PDOM.....	44
Table 19	– PDOM state table – Sender transitions	45
Table 20	– PDOM state table – Receiver transitions	45
Table 21	– Functions used by the SDOM	45
Table 22	– Primitives issued by user to PTC-ARPM	46

ITEH STANDARD PREVIEW
(standards.iteh.ai)

IEC 61158-6-21:2019

https://standards.iteh.ai/catalog/standards/sis/9078029-4cc-446f-a13b-89f14748e39d/iec-61158-6-21-2019

Table 23 – Primitives issued by PTC-ARPM to user	46
Table 24 – PTC-ARPM state table – sender transactions	47
Table 25 – PTC-ARPM state table – receiver transactions	48
Table 26 – Function BuildFAL-PDU.....	48
Table 27 – Primitives issued by user to ARPM	48
Table 28 – Primitives issued by ARPM to user	48
Table 29 – MSU-ARPM state table – sender transactions	50
Table 30 – MSU-ARPM state table – receiver transactions	50
Table 31 – Function BuildFAL-PDU.....	50
Table 32 – Primitives issued by user to ARPM	51
Table 33 – Primitives issued by ARPM to user	51
Table 34 – MTU-ARPM state table – sender transactions.....	52
Table 35 – MTU-ARPM state table – receiver transactions.....	52
Table 36 – Function BuildFAL-PDU.....	53
Table 37 – Primitives issued by ARPM to DMPM	53
Table 38 – Primitives issued by DMPM to ARPM	53
Table 39 – Primitives issued by DMPM to DLL	53
Table 40 – Primitives issued by DLL to DMPM.....	53
Table 41 – DMPM state table – sender transactions.....	54
Table 42 – DMPM state table – receiver transactions.....	54

[IEC 61158-6-21:2019](https://standards.iteh.ai/catalog/standards/sist/39078629-f9cc-446f-a13b-83f44748e39d/iec-61158-6-21-2019)

<https://standards.iteh.ai/catalog/standards/sist/39078629-f9cc-446f-a13b-83f44748e39d/iec-61158-6-21-2019>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
FIELD BUS SPECIFICATIONS –****Part 6-21: Application layer protocol specification –
Type 21 elements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-6-21 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial process measurement, control and automation.

This second edition cancels and replaces the first edition published in 2010. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- added WriteAndRead service;
- miscellaneous editorial corrections.

The text of this International standard is based on the following documents:

FDIS	Report on voting
65C/948/FDIS	65C/956/RVD

Full information on the voting for the approval of this International standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be:

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 61158-6-21:2019](https://standards.iteh.ai/catalog/standards/sist/39078629-f9cc-446f-a13b-6514474839d/iec-61158-6-21-2019)

A bilingual version of this publication may be issued at a later date.

INTRODUCTION

This document is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158–1.

The application protocol provides the application service by making use of the services available from the data-link or other immediately lower layer. The primary aim of this document is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer application entities (AEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- as a guide for implementers and designers;
- for use in the testing and procurement of equipment;
- as part of an agreement for the admission of systems into the open systems environment;
- as a refinement to the understanding of time-critical communications within OSI.

This document is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this document together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

[IEC 61158-6-21:2019](#)

<https://standards.iteh.ai/catalog/standards/sist/39078629-f9cc-446f-a13b-83f44748e39d/iec-61158-6-21-2019>

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 6-21: Application layer protocol specification – Type 21 elements

1 Scope

1.1 General

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the three-layer fieldbus reference model described in IEC 61158-1.

This International Standard contains material specific to the Type 21 communication protocol.

1.2 Overview

The Fieldbus Application Layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a window between corresponding application programs.

This document provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment, as well as material specific to Type 21. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions must be completed with some defined level of certainty. Failure to complete specified actions within the required time risks the failure of the applications requesting the actions, with attendant risk to equipment, plant, and possibly human life.

This document defines interactions between remote applications. It also defines the externally visible behavior provided by the Type 21 application layer in terms of:

- a) the formal abstract syntax defining the application layer protocol data units (APDUs) conveyed between communicating application entities;
- b) the transfer syntax defining encoding rules that are applied to the APDUs;
- c) the application context state machine defining the application service behavior visible between communicating application entities;
- d) the application relationship state machines defining the communication behavior visible between communicating application entities.

The purpose of this document is to:

- a) describe the wire-representation of the service primitives defined in IEC 61158-5-21;
- b) describe the externally visible behavior associated with their transfer.

This document defines the protocol of the Type 21 application layer in conformance with the OSI Basic Reference Model (ISO/IEC 7498) and the OSI application layer structure (ISO/IEC 9545).

1.3 Specifications

The principal objective of this document is to specify the syntax and behavior of the application layer protocol that conveys the Type 21 application layer services.

A secondary objective is to provide migration paths from previously existing industrial communications protocols.

1.4 Conformance

This document does not restrict individual implementations or products, nor does it constrain the implementations of application layer entities in industrial automation systems. Conformance is achieved through implementation of this application layer protocol specification.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE All parts of the IEC 61158 series, as well as IEC 61784-1 and IEC 61784-2 are maintained simultaneously. Cross-references to these documents within the text therefore refer to the editions as dated in this list of normative references.

IEC 61158-3-21:2019, *Industrial communication networks – Fieldbus specifications – Part 3-21: Data-link layer service definition – Type 21 elements*

IEC 61158-4-21:2019, *Industrial communication networks – Fieldbus specifications – Part 4-21: Data-link layer protocol specification – Type 21 elements*

IEC 61158-5-21:2019, *Industrial communication networks – Fieldbus specifications – Part 5-21: Application layer service definition – Type 21 elements*

<https://standards.iteh.ai/catalog/standards/sist/39078629-f9cc-446f-a13b-177109c39c0e/iec-61158-5-21-2019>

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC/IEEE 8802-3, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Standard for Ethernet*

ISO/IEC 8822, *Information technology – Open Systems Interconnection – Presentation service definition*

ISO/IEC 8824-1, *Information technology – Abstract Syntax Notation One (ASN.1): Specification of basic notation*

ISO/IEC 9545, *Information technology – Open Systems Interconnection – Application layer structure*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

ISO/IEC 9899, *Information technology – Programming Languages – C*

IEEE 754-2008, *IEEE Standard for Binary Floating-Point Arithmetic*

3 Terms, definitions, symbols, abbreviations and conventions

For the purposes of this document, the following terms, definitions, symbols, abbreviations and conventions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1 Terms and definitions from other ISO/IEC standards

3.1.1 ISO/IEC 7498-1 terms

For the purposes of this document, the following terms as defined in ISO/IEC 7498-1 apply:

- a) application entity
- b) application process
- c) application protocol data unit
- d) application service element
- e) application entity invocation
- f) application process invocation
- g) application transaction
- h) real open system
- i) transfer syntax

3.1.2 ISO/IEC 8822 terms

For the purposes of this document, the following terms as defined in ISO/IEC 8822 apply:

- a) abstract syntax
- b) presentation context

[IEC 61158-6-21:2019](http://standards.iteh.ai/catalog/standards/sist/39078629-9cc-446f-a13b-83f44748e39d/iec-61158-6-21-2019)

<http://standards.iteh.ai/catalog/standards/sist/39078629-9cc-446f-a13b-83f44748e39d/iec-61158-6-21-2019>

3.1.3 ISO/IEC 8824-1 terms

For the purposes of this document, the following terms as defined in ISO/IEC 8824-1 apply:

- a) object identifier
- b) type

3.1.4 ISO/IEC 9545 terms

For the purposes of this document, the following terms as defined in ISO/IEC 9545 apply:

- a) application-association
- b) application-context
- c) application context name
- d) application-entity-invocation
- e) application-entity-type
- f) application-process-invocation
- g) application-process-type
- h) application-service-element
- i) application control service element

3.2 Other terms and definitions

3.2.1

application

function or data structure for which data are consumed or produced

3.2.2**application objects**

multiple object classes that manage and provide a runtime exchange of messages across the network and within the network device

3.2.3**application process**

part of a distributed application on a network, which is located on one device and addressed unambiguously

3.2.4**application process object**

component of an application process that is identifiable and accessible through an FAL application relationship

Note 1 to entry: Application process object definitions are composed of a set of values for the attributes of their class (see the definition for “application process object class”). Application process object definitions may be accessed remotely using the services of the FAL Object Management ASE. FAL Object Management services can be used to load or update object definitions, to read object definitions, and to create and delete application objects and their corresponding definitions dynamically.

3.2.5**application process object class**

class of application process objects defined in terms of the set of their network-accessible attributes and services

iTeh STANDARD PREVIEW

3.2.6**application relationship**

cooperative association between two or more application-entity-invocations for the purpose of exchange of information and coordination of their joint operation

Note 1 to entry: This relationship is activated either by the exchange of application-protocol-data-units or as a result of preconfiguration activities.

3.2.7**application relationship application service element**

application-service-element that provides the exclusive means for establishing and terminating all application relationships

3.2.8**application relationship endpoint**

context and behavior of an application relationship as seen and maintained by one of the application processes involved in the application relationship

Note 1 to entry: Each application process involved in the application relationship maintains its own application relationship endpoint.

3.2.9**attribute**

description of an externally visible characteristic or feature of an object

Note 1 to entry: The attributes of an object contain information about variable portions of an object. Typically, they provide status information or govern the operation of an object. Attributes may also affect the behavior of an object. Attributes are divided into class attributes and instance attributes.

3.2.10**behavior**

indication of how an object responds to particular events

3.2.11**channel**

single physical or logical link of an input or output application object of a server to the process

3.2.12**class**

set of objects, all of which represent the same type of system component

Note 1 to entry: A class is a generalization of an object, a template for defining variables and methods. All objects in a class are identical in form and behavior, but usually contain different data in their attributes.

3.2.13**class attributes**

attribute shared by all objects within the same class

3.2.14**class code**

unique identifier assigned to each object class

3.2.15**class-specific service**

service defined by a particular object class to perform a required function that is not performed by a common service

Note 1 to entry: A class-specific object is unique to the object class that defines it.

3.2.16**client**

- a) object that uses the services of another (server) object to perform a task
- b) initiator of a message to which a server reacts

3.2.17**consume**

act of receiving data from a producer [IEC 61158-6-21:2019](#)

<https://standards.iteh.ai/catalog/standards/sist/39078629-f9cc-446f-a13b-83f44748e39d/iec-61158-6-21-2019>

3.2.18**consumer**

node or sink that receives data from a producer

3.2.19**consuming application**

application that consumes data

3.2.20**conveyance path**

unidirectional flow of APDUs across an application relationship

3.2.21**cyclic**

repetitive in a regular manner

3.2.22**data consistency**

means for coherent transmission and access of the input- or output-data object between and within client and server

3.2.23**device**

physical hardware connected to the link

Note 1 to entry: A device may contain more than one node.