

TECHNICAL SPECIFICATION



High voltage direct current (HVDC) grid systems and connected converter stations – Guideline and parameter lists for functional specifications – Part 1: Guideline

Document Preview

[IEC TS 63291-1:2023](https://standards.iteh.ai/catalog/standards/iec/903df0fd-6f24-4ece-bece-6a52db59f8e6/iec-ts-63291-1-2023)

<https://standards.iteh.ai/catalog/standards/iec/903df0fd-6f24-4ece-bece-6a52db59f8e6/iec-ts-63291-1-2023>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2023 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

International
Standards.iteh.ai)
Document Preview

[IEC TS 63291-1:2023](#)

<https://standards.iteh.ai/catalog/standards/iec/903df0fd-6f24-4ece-bece-6a52db59f8e6/iec-ts-63291-1-2023>

TECHNICAL SPECIFICATION



High voltage direct current (HVDC) grid systems and connected converter stations – Guideline and parameter lists for functional specifications – Part 1: Guideline

Document Preview

[IEC TS 63291-1:2023](https://standards.iteh.ai/catalog/standards/iec/903df0fd-6f24-4ece-bece-6a52db59f8e6/iec-ts-63291-1-2023)

<https://standards.iteh.ai/catalog/standards/iec/903df0fd-6f24-4ece-bece-6a52db59f8e6/iec-ts-63291-1-2023>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.200; 29.240.01

ISBN 978-2-8322-7571-9

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	7
INTRODUCTION.....	9
1 Scope.....	10
2 Normative references	10
3 Terms, definitions and abbreviated terms	11
3.1 Terms and definitions.....	11
3.2 Abbreviated terms.....	16
4 Coordination of HVDC grid and AC systems	16
4.1 About HVDC grids.....	16
4.2 HVDC grid structure.....	17
4.3 Purpose of the HVDC grid and power network diagram	18
4.4 AC/DC power flow optimisation	19
4.5 Converter operational functions	20
4.5.1 General	20
4.5.2 Basic operation functions – Converter normal operation state.....	20
4.5.3 Basic operation functions – Converter abnormal operation state	22
4.5.4 Ancillary services.....	23
5 HVDC grid characteristics.....	28
5.1 HVDC circuit topologies	28
5.1.1 Availability and reliability	28
5.1.2 Basic characteristics and nomenclature	28
5.1.3 Attributes of HVDC grids or HVDC grid subsystems	32
5.1.4 Attributes of an HVDC station	33
5.2 Connection modes	34
5.3 Grid operating states	34
5.3.1 General	34
5.3.2 Normal state	35
5.3.3 Alert state.....	35
5.3.4 Emergency state.....	35
5.3.5 Blackout state.....	35
5.3.6 Restoration.....	35
5.4 DC voltages	35
5.4.1 General	35
5.4.2 Nominal DC system voltage	35
5.4.3 Steady-state DC pole voltage	36
5.4.4 Temporary DC pole voltage	36
5.4.5 DC neutral bus voltage	37
5.5 Insulation coordination	39
5.6 Short-circuit characteristics.....	39
5.6.1 Calculation of short-circuit currents in HVDC grids.....	39
5.6.2 Short-circuit current design requirements	41
5.7 Steady-state voltage and current distortions	41
5.7.1 Emissions and impacts	41
5.7.2 Rights and obligations of a connectee	42
5.7.3 Similarities between HVDC grids and AC networks	43
5.7.4 Voltage and current distortion limits	44

5.7.5	Allocation of limits to individual connectees	45
5.7.6	Frequency-dependent DC system impedance	45
5.8	DC system restoration.....	46
5.8.1	General	46
5.8.2	Post-DC fault recovery.....	46
5.8.3	Restoration from blackout.....	46
6	HVDC grid control.....	47
6.1	Closed-loop control functions	47
6.1.1	General	47
6.1.2	Core control functions.....	47
6.1.3	Coordinating control functions	47
6.2	Controller hierarchy	48
6.2.1	General	48
6.2.2	Internal converter control.....	49
6.2.3	DC node voltage control	49
6.2.4	Coordinated HVDC grid control.....	50
6.2.5	AC/DC grid control.....	52
6.3	Propagation of information	53
6.4	Open-loop controls.....	55
6.4.1	Coordination of connection modes between HVDC stations and their PoC-DC	55
6.4.2	Operating sequences for HVDC grid installations.....	56
6.4.3	Post-DC fault recovery.....	56
7	HVDC grid protection.....	57
7.1	General.....	57
7.2	DC fault separation	58
7.3	Protection system related installations and equipment	58
7.3.1	AC/DC converter station	58
7.3.2	HVDC grid topology and equipment	59
7.4	HVDC grid protection zones	59
7.4.1	General	59
7.4.2	Permanent stop P	62
7.4.3	Permanent stop PQ	64
7.4.4	Temporary stop P	65
7.4.5	Temporary stop PQ	68
7.4.6	Continued operation	69
7.4.7	Example of a protection zone matrix	71
7.5	DC protection.....	72
7.5.1	General	72
7.5.2	DC converter protections	73
7.5.3	HVDC grid protections	73
7.5.4	HVDC grid protection communication.....	75
8	AC/DC converter stations	75
8.1	Purpose	75
8.2	AC/DC converter station types	75
8.2.1	General	75
8.2.2	AC/DC converter station type 1 (AC/DC type 1)	75
8.2.3	AC/DC converter station type 2 (AC/DC type 2)	75
8.2.4	AC/DC converter station type 3 (AC/DC type 3)	76

8.2.5	AC/DC converter station type 4 (AC/DC type 4)	76
8.2.6	AC/DC converter station type 5 (AC/DC type 5)	76
8.3	Overall requirements	76
8.3.1	Robustness of AC/DC converter stations	76
8.3.2	Availability and reliability	77
8.3.3	Active power reversal	77
8.4	Main circuit design	77
8.4.1	General characteristics	77
8.4.2	DC side	79
8.4.3	AC side	87
8.5	HVDC grid control and protection interface	88
8.6	Controls	88
8.6.1	General	88
8.6.2	Automated vs manual operation	88
8.6.3	Control modes and support of coordination	89
8.6.4	Limitation strategies	89
8.6.5	Operating sequences for AC/DC converter stations	89
8.6.6	Dynamic behaviour	91
8.7	Protection	92
8.7.1	General	92
8.7.2	Configuration requirements	92
8.7.3	Function requirements	93
8.7.4	Fault separation strategy for faults inside the AC/DC converter station	94
8.7.5	Coordination of the DC protection with the HVDC grid	95
8.7.6	Example for coordination of the DC protection with the HVDC grid	95
9	HVDC grid installations	97
9.1	General	97
9.2	DC switching station	100
9.2.1	Purpose	100
9.2.2	Overall requirements	100
9.2.3	Main circuit design	100
9.2.4	HVDC grid control and protection interface	111
9.2.5	Controls	112
9.2.6	Protection	113
9.3	HVDC transmission lines	115
9.3.1	Purpose	115
9.3.2	Overall requirements	115
9.3.3	Main circuit design	116
9.3.4	HVDC grid control and protection interface	119
9.3.5	Controls	119
9.3.6	Protection	119
9.4	DC/DC converter stations	120
10	Studies and associated models	121
10.1	General	121
10.2	Description of studies	121
10.2.1	General	121
10.2.2	HVDC grid planning studies	121
10.2.3	HVDC grid design studies	122
10.2.4	HVDC grid extension studies	122

10.2.5	Studies for HVDC grid installation refurbishments and other modifications	122
10.3	Models and interfaces	123
10.3.1	General	123
10.3.2	Model interfaces and integration compatibility	123
10.3.3	Model capability	123
10.3.4	Model format	124
10.3.5	Model maintenance and portability	124
10.3.6	Model aggregation	124
10.3.7	Model testing and validation	124
11	Testing	125
11.1	General	125
11.2	Off-site testing	125
11.2.1	General	125
11.2.2	Factory system tests	126
11.3	On-site testing	131
	Bibliography	132

Figure 1	– Definition of the point of connection-AC and the point of connection-DC at an AC/DC converter station	12
Note 2 to entry:	See Figure 2 – Rigid bipolar HVDC system	14
Figure 2	– Rigid bipolar HVDC system	15
Figure 3	– Schematic structure of an HVDC grid	18
Figure 4	– Example of a PQ-diagram showing the active vs reactive power exchange capability of an AC/DC converter station for a given AC voltage level	19
Figure 5	– Generic AC over- and under voltage ride through profile of an AC/DC converter station	23
Figure 6	– Example of an active power frequency response capability of an AC/DC converter station in frequency sensitive mode (FSM) with zero deadband and insensitivity with a positive active power setpoint; FSM in this figure shall be understood as FCR	24
Figure 7	– Example of an HVDC grid in 2DCe topology with different AC/DC converter station topologies	31
Figure 8	– Operating states	35
Figure 9	– Generic temporary DC pole to earth voltage profiles in HVDC grids	37
Figure 10	– Generic neutral bus voltage profile	39
Figure 11	– Standard approximation function	41
Figure 12	– Equivalent circuit, defining the relationship between voltage and current distortions	42
Figure 13	– Disturbance level	43
Figure 14	– Planning level and headroom	44
Figure 15	– General controller hierarchy with typical time ranges of operation	48
Figure 16	– Typical DC node voltage control modes (illustration in DC voltage/power plane)	50
Figure 17	– Generation of final converter schedules including converter control modes and its parameters	54
Figure 18	– Propagation of switching commands to individual HVDC stations	55

Figure 19 – Typical operating sequences for transitions between operating states of HVDC grid, HVDC grid subsystem or HVDC grid installation 56

Figure 20 – Example illustrating the concept of HVDC grid protection zones in HVDC grids 61

Figure 21 – Example of voltage and current traces in the event of "permanent stop" 63

Figure 22 – Example voltage and current traces in the event of "temporary stop P" 67

Figure 23 – Example voltage and current traces in the event of "continued operation" 70

Figure 24 – Example of an HVDC grid protection zone layout 72

Figure 25 – AC/DC converter station types in the *UII* diagram..... 76

Figure 26 – Example of a BRO AC/DC converter station with connected BRZ DC switching station. The AC/DC converter station is of bipolar topology. Its adjacent DC switching station connects two bipolar transmission circuits with DMR in this example 80

Figure 27 – Operating states and transitions for AC/DC converter stations 89

Figure 28 – Example illustrating the coordination of the DC protection of AC/DC converter station 1 with the HVDC grid 97

Figure 29 – Example of a BRZ DC switching station. The DC switching station connects two bipolar transmission circuits with DMR and an AC/DC converter station of bipolar topology 103

Figure 30 – Example test environment based on complete C&P equipment represented as hardware 127

Figure 31 – Example test environment partly based on C&P equipment as hardware and the remaining C&P equipment as functional software-in-the-loop model with two alternatives for representing the HVDC grid controller..... 128

Figure 32 – Example test environment based on complete C&P equipment represented as functional software-in-the-loop model 129

Figure 33 – Example test environment dedicated to test the HVDC grid controller, based on complete C&P equipment represented as functional software-in-the-loop model and HVDC grid controller as hardware..... 130

Table 1 – Nomenclature of HVDC circuit topologies 29

Table 2 – HVDC circuit topologies – HVDC grid characteristics..... 29

Table 3 – HVDC circuit topologies – HVDC station characteristics at a PoC..... 30

Table 4 – DC fault separation concepts of HVDC grids or parts thereof defined at a PoC-AC or PoC-DC respectively 61

Table 5 – HVDC grid protection zone matrix 71

Table 6 – DC Connection modes of an AC/DC converter station 81

Table 7 – DC circuit re-configuration requirements..... 82

Table 8 – Example protection coordination of AC/DC converter station 1 and HVDC grid (for main and backup concept including the separation concept and the FSD) 96

Table 9 – Functions changing operating states 98

Table 10 – Functions of grid operation 99

Table 11 – Protective functions 99

Table 12 – Connection modes of the bipolar DC SU of Figure 29 connecting a PoC-DC of an HVDC transmission line 105

Table 13 – Connection modes of the bipolar DC SU of Figure 29 connecting a PoC-DC of an AC/DC converter station ($x = 1$)..... 106

Table 14 – Normally used DC circuit reconfiguration time requirements for the DC SU example of Figure 29 (PoC-DC) 106

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH VOLTAGE DIRECT CURRENT (HVDC) GRID SYSTEMS AND CONNECTED CONVERTER STATIONS – GUIDELINE AND PARAMETER LISTS FOR FUNCTIONAL SPECIFICATIONS –

Part 1: Guideline

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 63291-1 has been prepared by IEC technical committee TC 115: High Voltage Direct Current (HVDC) transmission for DC voltages above 100 kV. It is a Technical Specification.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
115/319/DTS	115/328A/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This Technical Specification is to be used in conjunction with IEC TS 63291-2:2023.

A list of all parts in the IEC 63291 series, published under the general title *High voltage direct current (HVDC) grid systems and connected converter stations – Guideline and parameter lists for functional specifications*, can be found on the IEC website.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

iteh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC TS 63291-1:2023](https://standards.iteh.ai/catalog/standards/iec/903df0fd-6f24-4ece-bece-6a52db59f8e6/iec-ts-63291-1-2023)

<https://standards.iteh.ai/catalog/standards/iec/903df0fd-6f24-4ece-bece-6a52db59f8e6/iec-ts-63291-1-2023>

INTRODUCTION

In the preparation of this document, special care has been taken to, as far as possible, describe the requirements in a technologically independent way. In order to achieve that, a function of interest is described by a comprehensive set of parameters. The parameters are selected based on a systematic analysis of physical phenomena relevant to achieve the requested functionality.

Reflecting the early stage of technology, the technical parameters need comprehensive explanations and background information. This need is reflected in the dual character of the content, which is presented in the two corresponding parts:

- IEC TS 63291-1, Guideline containing the explanations and the background information in context with the parameter lists;
- IEC TS 63291-2, Parameter lists containing the essential lists of parameters and values describing properties of the AC respectively DC system (operating conditions) and parameters describing the performance of the newly installed component (performance requirements).

IEC TS 63291-1 and IEC TS 63291-2 have the same structure to aid the reader.

At the time of writing there is no real-life multi-national, multi-vendor HVDC grid project to which the guideline and parameter lists can be applied. Practical experiences in the near future are expected to provide input for developing these guideline and parameter lists further.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC TS 63291-1:2023](https://standards.iteh.ai/catalog/standards/iec/903df0fd-6f24-4ece-bece-6a52db59f8e6/iec-ts-63291-1-2023)

<https://standards.iteh.ai/catalog/standards/iec/903df0fd-6f24-4ece-bece-6a52db59f8e6/iec-ts-63291-1-2023>

HIGH VOLTAGE DIRECT CURRENT (HVDC) GRID SYSTEMS AND CONNECTED CONVERTER STATIONS – GUIDELINE AND PARAMETER LISTS FOR FUNCTIONAL SPECIFICATIONS –

Part 1: Guideline

1 Scope

This document contains guidelines on planning, specification, and execution of multi-vendor HVDC grid systems also referred to as HVDC grids. The terms "HVDC grid systems" or "HVDC grids" are used in this document to describe HVDC systems for power transmission having more than two HVDC stations connected to a common DC circuit. The DC circuit can be of radial or meshed topology or a combination thereof. In this document, the term "HVDC grids" is used.

While this document focuses on requirements specific for HVDC grids, some requirements are considered applicable to all HVDC systems in general, i.e., including point-to-point HVDC systems. Existing IEC (e.g. IEC TR 63363-1 [1]), Cigre or other relevant documents have been used for reference as far as possible.

Corresponding to electric power transmission applications, this document is applicable to high voltage systems, i.e. those having typically nominal DC voltages higher than 50 kV with respect to earth are considered in this document.

NOTE While the physical principles of DC networks are basically voltage independent, the technical options for designing equipment get much wider with lower DC voltage levels, e.g. in case of converters or switchgear.

This document covers technical aspects of:

- coordination of HVDC grid and AC systems,
- HVDC grid characteristics,
- HVDC grid control,
- HVDC grid protection,
- AC/DC converter stations,
- HVDC grid installations, including DC switching stations and HVDC transmission lines,
- studies and associated models,
- testing.

Beyond the scope of this document, the following content is proposed for future work:

- DC/DC converter stations.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60909 (all parts), *Short-circuit currents in three-phase AC systems*

IEC 61975:2010, *High-voltage direct current (HVDC) installations – System tests*
IEC 61975:2010/AMD1:2016
IEC 61975:2010/AMD2:2022

IEC 62271-100, *High-voltage switchgear and controlgear – Part 100: Alternating-current circuit-breakers*

IEC 62271-102, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

IEC 62747:2014, *Terminology for voltage-sourced converters (VSC) for high-voltage direct current (HVDC) systems*
IEC 62747:2014/AMD1:2019

IEC TS 63014-1, *High voltage direct current (HVDC) power transmission – System requirements for DC-side equipment – Part 1: Using line-commutated converters*

IEC TS 63291-2:2023, *High voltage direct current (HVDC) grid systems and connected converter stations – Guideline and parameter lists for functional specifications – Part 2: Parameter lists*

ISO/IEC 25010:2011, *Systems and software engineering – Systems and software Quality Requirements and Evaluation (SQuaRE) – System and software quality models*

3 Terms, definitions and abbreviated terms

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1 Terms and definitions

3.1.1

AC/DC converter unit

indivisible operative unit comprising all equipment between the PoC-AC and the PoC-DC, essentially one or more converters, together with interface transformers, control and protection equipment, essential protective and switching devices and auxiliaries, if any, used for conversion

Note 1 to entry: The term "converter transformer" is also used instead of "interface transformer".

[SOURCE: IEC 62747:2014, 7.5, modified – "AC/DC" has been added to the term; the definition has been neutralised with respect to technology (not only VSC converters) and uses the terms PoC-AC and PoC-DC as defined in 3.1.3 and 3.1.4 in this document.]

3.1.2

AC/DC converter station

part of an HVDC system which consists of one or more AC/DC converter units including DC switchgear, if any, DC fault current controlling devices, if any, installed in a single location together with buildings, reactors, filters, reactive power supply, control, monitoring, protective, measuring and auxiliary equipment

[SOURCE: IEC 62747:2014, 9.21, modified – "AC/DC" has been added to the term; the definition has been made specific with respect to AC/DC converter units, differentiating from

DC/DC converter units. Furthermore, only the term "AC/DC converter station" is used in this document; the note to entry has been deleted.]

3.1.3

PoC-DC

point of connection-DC

electrical interface point at DC voltage as shown in Figure 1

3.1.4

PoC-AC

point of connection-AC

electrical interface point at AC voltage as shown in Figure 1




Figure 1 – Definition of the point of connection-AC and the point of connection-DC at an AC/DC converter station

3.1.5

DC/DC converter unit

indivisible operative unit comprising all equipment between the points of connection to the HVDC grid having different nominal DC voltage, essentially one or more converters, together with interface transformers, if any, control equipment, essential protective and switching devices and auxiliaries, if any, used for conversion

Note 1 to entry: The term "converter transformer" is also used instead of "interface transformer".

3.1.6

DC/DC converter station

part of an HVDC grid which consists of one or more DC/DC converter units including DC switchgear, if any, DC fault current controlling devices, if any, installed in a single location together with buildings, reactors, filters, control, monitoring, protective, measuring and auxiliary equipment, if any

3.1.7

DC line power flow controller

device connected in series with a transmission line inserting a DC voltage for the primary purpose of controlling the power flow in a meshed HVDC grid

Note 1 to entry: Series connected devices can also be used to insert into or absorb power from a transmission line for the purpose of compensating the voltage drop along the line or connecting load or generation.

3.1.8

DC grid protection zone

physical part of an HVDC grid with a distinct DC fault handling sequence

3.1.9

DC switching unit

indivisible operative unit comprising all equipment between the DC busbars and the terminals (HV poles and neutral, if any) of one point of connection on the DC side, comprising, if any, one or more switches, control, monitoring, protective, measuring equipment and auxiliaries