

INTERNATIONAL STANDARD



Static VAR compensators (SVC) – Testing of thyristor valves

(<https://standards.iteh.ai>)
Document Preview

[IEC 61954:2021](https://standards.iteh.ai/catalog/standards/iec/1df0433b-0e7c-43c0-9171-ada3ca84dc76/iec-61954-2021)

<https://standards.iteh.ai/catalog/standards/iec/1df0433b-0e7c-43c0-9171-ada3ca84dc76/iec-61954-2021>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2021 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

International Standards
standards.iteh.ai
Document Preview

[IEC 61954:2021](https://standards.iteh.ai/catalog/standards/iec/1df0433b-0e7c-43c0-9171-ada3ca84dc76/iec-61954-2021)

<https://standards.iteh.ai/catalog/standards/iec/1df0433b-0e7c-43c0-9171-ada3ca84dc76/iec-61954-2021>



IEC 61954

Edition 3.0 2021-10
REDLINE VERSION

INTERNATIONAL STANDARD



Static VAR compensators (SVC) – Testing of thyristor valves

(<https://standards.iteh.ai>)
Document Preview

[IEC 61954:2021](https://standards.iteh.ai/catalog/standards/iec/1df0433b-0e7c-43c0-9171-ada3ca84dc76/iec-61954-2021)

<https://standards.iteh.ai/catalog/standards/iec/1df0433b-0e7c-43c0-9171-ada3ca84dc76/iec-61954-2021>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.240.99; 31.080.20

ISBN 978-2-8322-5023-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references.....	7
3 Terms and definitions	7
4 General requirements for type, production and optional tests.....	9
4.1 Summary of tests	9
4.2 Objectives of tests.....	10
4.2.1 General	10
4.2.2 Dielectric tests	10
4.2.3 Operational tests.....	10
4.2.4 Electromagnetic interference tests.....	11
4.2.5 Production tests	11
4.2.6 Optional tests.....	11
4.3 Guidelines for the performance of type and optional tests	11
4.4 Test conditions.....	12
4.4.1 General	12
4.4.2 Valve temperature at testing.....	13
4.4.3 Redundant thyristor levels.....	14
4.5 Permissible component failures during type testing	14
4.6 Documentation of test results	14
4.6.1 Test reports to be issued.....	14
4.6.2 Contents of a type test report	15
5 Type tests on TCR and TSR valves.....	16
5.1 Dielectric tests between valve terminals and earth	16
5.1.1 General	16
5.1.2 AC test	16
5.1.3 Lightning impulse test	17
5.2 Dielectric tests between valves (MVU only).....	17
5.2.1 General	17
5.2.2 AC test	17
5.2.3 Lightning impulse test	18
5.3 Dielectric tests between valve terminals.....	18
5.3.1 General	18
5.3.2 AC test	18
5.3.3 Switching impulse test.....	20
5.4 Operational tests.....	21
5.4.1 Periodic firing and extinction test.....	21
5.4.2 Minimum AC voltage test.....	23
5.4.3 Temperature rise test.....	23
6 Type tests on TSC valves	24
6.1 Dielectric tests between valve terminals and earth	24
6.1.1 General	24
6.1.2 AC-DC test	24
6.1.3 Lightning impulse test	26
6.2 Dielectric tests between valves (for MVU only).....	27
6.2.1 General	27

6.2.2	AC-DC test	27
6.2.3	Lightning impulse test	29
6.3	Dielectric tests between valve terminals.....	30
6.3.1	General	30
6.3.2	AC-DC test	30
6.3.3	Switching impulse test.....	33
6.4	Operational tests.....	34
6.4.1	Overcurrent tests	34
6.4.2	Minimum AC voltage test.....	37
6.4.3	Temperature rise test.....	38
7	Electromagnetic interference tests	38
7.1	Objectives.....	38
7.2	Test procedures	38
7.2.1	General	38
7.2.2	Switching impulse test.....	39
7.2.3	Non-periodic firing test.....	39
8	Production tests.....	39
8.1	General.....	39
8.2	Visual inspection.....	39
8.3	Connection check.....	39
8.4	Voltage-dividing/damping circuit check	40
8.5	Voltage withstand check.....	40
8.6	Check of auxiliaries	40
8.7	Firing check	40
8.8	Cooling system pressure test.....	40
8.9	Partial discharge tests.....	40
9	Optional tests on TCR and TSR valves.....	40
9.1	Overcurrent test	40
9.1.1	Overcurrent with subsequent blocking	40
9.1.2	Overcurrent without blocking	41
9.2	Positive voltage transient during recovery test	41
9.2.1	Objectives.....	41
9.2.2	Test values and waveshapes.....	41
9.2.3	Test procedures	42
9.3	Non-periodic firing test	42
9.3.1	Objectives.....	42
9.3.2	Test values and waveshapes.....	42
9.3.3	Test procedures	43
10	Optional tests on TSC valves	44
10.1	Positive voltage transient during recovery test	44
10.1.1	Test objective	44
10.1.2	Test values and waveshapes.....	44
10.1.3	Test procedures	44
10.2	Non-periodic firing test	44
10.2.1	Objectives.....	44
10.2.2	Test values and waveshapes.....	45
10.2.3	Test procedures	46

Figure 1 – TSC branch.....35
Figure 2 – One-loop overcurrent.....36
Figure 3 – Two-loop overcurrent.....37

Table 1 – List of tests9
Table 2 – Number of thyristor levels permitted to fail during type tests15

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 61954:2021](#)

<https://standards.iteh.ai/catalog/standards/iec/1df0433b-0e7c-43c0-9171-ada3ca84dc76/iec-61954-2021>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**STATIC VAR COMPENSATORS (SVC) –
TESTING OF THYRISTOR VALVES****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 61954:2011+AMD1:2013+AMD2:2017 CSV. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

International Standard IEC 61954 has been prepared by subcommittee 22F: Power electronics for electrical transmission and distribution systems, of IEC technical committee 22: Power electronic systems and equipment.

This third edition cancels and replaces the second edition published in 2011, Amendment 1:2013 and Amendment 2:2017. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition: important clarifications were made in 4.4.1.2, 5.1.2.2, 5.1.3.2, 5.2.3.2, 6.1.2.2, 6.1.2.4, 6.1.3.2, 6.2.2.2, 6.2.2.4, 6.3.2.2 and 9.3.2.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
22F/642/FDIS	22F/658/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

The contents of the corrigendum 1 (2024-06) have been included in this copy.

STATIC VAR COMPENSATORS (SVC) – TESTING OF THYRISTOR VALVES

1 Scope

This document defines type, production and optional tests on thyristor valves used in thyristor controlled reactors (TCR), thyristor switched reactors (TSR) and thyristor switched capacitors (TSC) forming part of static VAR compensators (SVC) for power system applications. The requirements of the document apply both to single valve units (one phase) and to multiple valve units (several phases).

Clauses 4 to 7 detail the type tests, i.e. tests which are carried out to verify that the valve design meets the requirements specified. Clause 8 covers the production tests, i.e. tests which are carried out to verify proper manufacturing. Clauses 9 and 10 detail optional tests, i.e. tests additional to the type and production tests.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060 (all parts), *High-voltage test techniques*

IEC 60060-1:2010, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60060-2, *High-voltage test techniques – Part 2: Measuring systems*

IEC 60071 (all parts), *Insulation co-ordination*

IEC 60071-1:2006/2019, *Insulation co-ordination – Part 1: Definitions, principles and rules*
~~IEC 60071-1:2006/AMD1:2010~~

IEC 60270, *High-voltage test techniques – Partial discharge measurements*

IEC 60700-1:2015, *Thyristor valves for high-voltage direct current (HVDC) power transmission – Part 1: Electrical testing*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1**thyristor level**

part of a thyristor valve comprising a thyristor, or thyristors connected in parallel or anti-parallel, together with their immediate auxiliaries and reactor, if any

3.2**thyristor (series) string**

series connected thyristors forming one direction of a thyristor valve

3.3**valve reactor**

reactor incorporated within some valves for limitation of stresses

Note 1 to entry: For testing purposes it is considered an integral part of the valve.

3.4**valve section**

electrical assembly, comprising a number of thyristors and other components, which exhibits pro-rated electrical properties of a complete thyristor valve, but only a portion of the full voltage blocking capability of the thyristor valve, and which can be used for tests

3.5**thyristor valve**

electrically and mechanically combined assembly of thyristor levels, complete with all connections, auxiliary components and mechanical structures, which can be connected in series with each phase of the reactor or capacitor of an SVC

3.6**valve structure**

physical structure which insulates the valves to the appropriate level above earth potential and from each other

3.7**valve base electronics****VBE**

electronic unit, at earth potential, which is the interface between the control system of the SVC and the thyristor valves

3.8**multiple valve unit****MVU**

assembly of several valves in the same physical structure which cannot be separated for test purposes (e.g. three-phase valves)

3.9**redundant thyristor levels**

maximum number of thyristor levels in the thyristor valve that may be short-circuited, externally or internally, during service without affecting the safe operation of the thyristor valve as demonstrated by type tests; and which if and when exceeded, would require either the shutdown of the thyristor valve to replace the failed thyristors, or the acceptance of increased risk of failures

3.10**voltage breakover (VBO) protection**

means of protecting the thyristors from excessive voltage by firing them at a predetermined voltage

4 General requirements for type, production and optional tests

4.1 Summary of tests

Table 1 lists the tests given in the following clauses and subclauses.

Table 1 – List of tests

Test	Subclause		Test object
	TCR/TSR	TSC	
Dielectric tests between valve terminals and earth (type tests)			
AC test	5.1.2		Valve
AC-DC test		6.1.2	Valve
Lightning impulse test	5.1.3	6.1.3	Valve
Dielectric tests between valves (MVU only) (type tests)			
AC test	5.2.2		MVU
AC-DC test		6.2.2	MVU
Lightning impulse test	5.2.3	6.2.3	MVU
Dielectric tests between valve terminals (type tests)			
AC test	5.3.2		Valve
AC-DC test		6.3.2	Valve
Switching impulse test	5.3.3	6.3.3	Valve
Operational tests (type tests)			
Periodic firing and extinction test	5.4.1		Valve or valve section
Overcurrent test		6.4.1	Valve or valve section
Minimum AC voltage test	5.4.2	6.4.2	Valve or valve section
Temperature rise test	5.4.3	6.4.3	Valve or valve section
Electromagnetic interference tests (type tests)			
Switching impulse test	7.2.2	7.2.2	Valve
Non-periodic firing test	7.2.3	7.2.3	Valve
Production tests			
Visual inspection	8.2	8.2	
Connection check	8.3	8.3	
Voltage dividing/damping circuit check	8.4	8.4	
Voltage withstand check	8.5	8.5	
Check of auxiliaries	8.6	8.6	
Firing check	8.7	8.7	
Cooling system pressure test	8.8	8.8	
Partial discharge tests	8.9	8.9	
Optional tests			
Overcurrent test	9.1		Valve or valve section
Positive voltage transient during recovery test	9.2	10.1	Valve or valve section
Non-periodic firing test	9.3	10.2	Valve or valve section

4.2 Objectives of tests

4.2.1 General

The tests described apply to the valve (or valve sections), the valve structure and those parts of the coolant distribution system and firing and monitoring circuits which are contained within the valve structure or connected between the valve structure and earth. Other equipment, such as valve control and protection and valve base electronics may be essential for demonstrating the correct function of the valve during the tests but are not in themselves the subject of the tests.

4.2.2 Dielectric tests

4.2.2.1 General

Tests for the following dielectric stresses are specified:

- AC voltage;
- combined AC and DC voltage (TSC only);
- impulse voltages.

In the interest of standardization with other equipment, lightning impulse tests between valve terminals and earth and between phases of an MVU are included. For tests between valve terminals, the only impulse test specified is a switching impulse.

4.2.2.2 Tests on valve structure

Tests are defined for the voltage withstand requirements between a valve (with its terminals short-circuited) and earth, and also between valves for MVU. The tests shall demonstrate that:

- sufficient clearances have been provided to prevent flashovers;
- there is no disruptive discharge in the insulation of the valve structure, cooling ducts, light guides and other insulation parts of the pulse transmission and distribution systems;
- partial discharge inception and extinction voltages under AC and DC conditions are above the maximum steady-state operating voltage appearing on the valve structure.

4.2.2.3 Tests between valve terminals

The purpose of these tests is to verify the design of the valve with respect to its capability to withstand overvoltages between its terminals. The tests shall demonstrate that:

- sufficient internal insulation has been provided to enable the valve to withstand specified voltages;
- partial discharge inception and extinction voltages under AC and DC conditions are above the maximum steady-state operating voltage appearing between valve terminals;
- the protective overvoltage firing system (if provided) works as intended;
- the thyristors have adequate du/dt capability for in-service conditions. (In most cases the specified tests are sufficient; however, in some exceptional cases additional tests may be required.)

4.2.3 Operational tests

The purpose of these tests is to verify the valve design for combined voltage and current stresses under normal and abnormal repetitive conditions as well as under transient fault conditions. They shall demonstrate that, under specified conditions:

- the valve functions properly;

- the turn-on and turn-off voltage and current stresses are within the capabilities of the thyristors and other internal circuits;
- the cooling provided is adequate and no component is overheated;
- the overcurrent withstand capability of the valve is adequate.

4.2.4 Electromagnetic interference tests

The principal objective of these tests is to demonstrate the immunity of the valve to electromagnetic interference from within the valve and from outside the valve. Generally, immunity to electromagnetic interference is demonstrated by monitoring of the valve during other tests.

4.2.5 Production tests

The objective of tests is to verify proper manufacture. The production tests shall demonstrate that:

- all materials, components and sub-assemblies used in the valve have been correctly installed;
- the valve equipment functions as intended, and predefined parameters are within prescribed acceptance limits;
- thyristor levels and valve or valve sections have the necessary voltage withstand capability;
- consistency and uniformity in production is achieved.

4.2.6 Optional tests

Optional tests are additional tests which may be performed, subject to agreement between the purchaser and the supplier. The objectives are the same as for the operational tests specified in 4.2.3. The test object is normally one valve or appropriate equivalent number of valve sections.

[IEC 61954:2021](https://standards.iteh.ai/catalog/standards/iec/1df0433b-0e7c-43c0-9171-ada3ca84dc76/iec-61954-2021)

<https://standards.iteh.ai/catalog/standards/iec/1df0433b-0e7c-43c0-9171-ada3ca84dc76/iec-61954-2021>

4.3 Guidelines for the performance of type and optional tests

The following principles shall apply:

- type tests shall be performed on at least one valve or on an appropriate number of valve sections, as indicated in Table 1 (see 4.1), to verify that the valve design meets the specified requirements. All type tests shall be performed on the same valve(s) or valve section(s);
- provided that the valve is demonstrably similar to one previously tested, the supplier may submit a certified report of any previous type test, at least equal to the requirements specified in the contract, in lieu of the type test;
- for type tests performed on valve sections, the total number of thyristor levels subjected to such type tests shall be at least equal to the number of thyristor levels in a valve;
- the valve or valve sections used for type tests shall first pass all production tests. On completion of the type test programme, the valve or valve sections shall be checked again for compliance with the production test criteria;
- material for the type tests shall be selected at random;
- the dielectric tests shall be performed in accordance with IEC 60060-1 and IEC 60060-2 where applicable;
- individual tests may be performed in any order.

NOTE Tests involving partial discharge measurement may provide added confidence if performed at the end of the dielectric type test programme.

4.4 Test conditions

4.4.1 General

4.4.1.1 Dielectric test objects

Dielectric tests shall be performed on completely assembled valves, whereas some operational tests may be performed on either complete valves or valve sections.

The valve shall be assembled with all auxiliary components except for the valve arrester, if used. Unless otherwise specified, the valve electronics shall be energized. The cooling and insulating fluids in particular shall be in a condition that represents service conditions such as conductivity, except for the flow rate and anti-freezing media content, which can be reduced. If any object or device external to the structure is necessary for proper representation of the stresses during the test, it shall also be present or simulated in the test. Metallic parts of the valve structure (or other valves in an MVU) which are not part of the test shall be shorted together and connected to earth in a manner appropriate to the test in question.

4.4.1.2 Atmospheric correction

~~When specified in the relevant clause,~~ Atmospheric correction shall be applied to the test voltages in accordance with IEC 60060-1, except when specifically excluded. ~~The reference conditions to which correction shall be made are the following~~ To calculate the test values applicable at standard reference atmosphere, the methods described in IEC 60060-1:2010,4.3.3.1 shall be used, considering the following conditions as input values for pressure p , temperature t and humidity h :

– pressure:

If the insulation coordination of the tested part of the thyristor valve is based on standard rated withstand voltages according to IEC 60071-1, correction factors are only applied for altitudes exceeding 1 000 m. Hence if the altitude of the site a_s at which the equipment will be installed is less than 1 000 m, then the standard atmospheric air pressure ($b_0 = 101,3$ kPa) shall be used with no correction for altitude. If $a_s > 1\ 000$ m, then the standard procedure according to IEC 60060-1 is used except that the reference atmospheric pressure b_0 is replaced by the atmospheric pressure corresponding to an altitude of 1 000 m ($b_{1\ 000\ m}$).

If the insulation coordination of the tested part of the thyristor valve is not based on standard rated withstand voltages according to IEC 60071-1, then the standard procedure according to IEC 60060-1 is used with the reference atmospheric pressure b_0 ($b_0 = 101,3$ kPa).

– temperature:

design maximum valve hall air temperature ($^{\circ}\text{C}$).

– humidity:

design minimum valve hall absolute humidity (g/m^3).

The values to be used shall be specified by the supplier.

In any of the afore mentioned cases, the correction of test values from standard reference atmosphere to test conditions shall be as per IEC 60060-1:2010,4.3.3.2.

Where non-standard test levels are defined by this document, a site air density correction factor k_d , defined below shall be applied where stated.

The value of k_d shall be determined from the following formula:

$$k_d = \frac{b_1}{b_2} \times \frac{273 + T_2}{273 + T_1} \quad (1)$$