

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Low-voltage electrical installations –
Part 8-82: Functional aspects – Prosumer’s low-voltage electrical installations**

**Installations électriques à basse tension –
Partie 8-82: Aspects fonctionnels – Installations électriques à basse tension du
prosommateur**

INTERNATIONAL STANDARD PREVIEW
(standards.iteh.ai)

[.iteh.ai/catalog/standards/sist/f5b75aee-ac1f-4582-a9b7-cfba064d5b55/iec-60364-8-82-2022](https://standards.iteh.ai/catalog/standards/sist/f5b75aee-ac1f-4582-a9b7-cfba064d5b55/iec-60364-8-82-2022)



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2022 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.



INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Low-voltage electrical installations –
Part 8-82: Functional aspects – Prosumer’s low-voltage electrical installations**

**Installations électriques à basse tension –
Partie 8-82: Aspects fonctionnels – Installations électriques à basse tension du
prosommateur**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 91.140.50

ISBN 978-2-8322-3942-1

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
82.1 Scope	8
82.2 Normative references.....	8
82.3 Terms and definitions.....	9
82.4 Integration of PEI in its environment	12
82.4.1 Main objectives.....	12
82.4.2 Safety.....	12
82.4.3 Proper functioning	12
82.5 PEI concept	13
82.6 Types of PEI	16
82.6.1 General	16
82.6.2 Operating modes	16
82.6.3 Interaction with the distribution network.....	17
82.7 Control and monitoring.....	24
82.7.1 General	24
82.7.2 Architecture of control and monitoring system	25
82.8 Protection of prosumer electrical installation	25
82.8.1 General	25
82.8.2 Protection against electric shock	25
82.8.3 Protection against thermal effect	41
82.8.4 Protection against overcurrent.....	41
82.8.5 Protection against transient overvoltages	45
82.9 Isolation and switching.....	46
82.9.1 Isolation	46
82.9.2 Emergency switching-off.....	46
82.10 Load and source management	46
82.10.1 Energy storage	46
82.10.2 Design for flexibility of load and generators (demand/response)	46
82.10.3 Electric vehicle	46
Annex A (informative) Operating modes of PEI	47
A.1 Direct feeding mode	47
A.2 Island mode.....	47
A.3 Reverse feeding mode.....	48
Annex B (informative) Interaction with the supply system.....	50
B.1 General	50
B.2 Active power and frequency control	50
B.3 Reactive power and voltage control	50
B.4 Load shedding programme	50
Annex C (informative) Architectures of PEI	51
C.1 General	51
C.2 Architecture of individual PEI.....	51
C.3 Architecture of collective PEI	52
C.4 Architecture of shared PEI	57
Annex D (normative) Single dwelling or similar application islandable PEI	61

D.1	General	61
D.2	Type of system earthing	61
D.3	Connection of the local source.....	64
D.4	Fire switching-off.....	64
D.5	Switching device for islanding and system referencing conductor switching device	64
D.6	Labelling.....	64
D.7	Upgrading an existing single dwelling installation in islandable PEI	65
D.8	Initial verification	68
Annex E (informative) List of notes concerning certain countries.....		69
Bibliography.....		70
Figure 1	– Example of prosumer's low-voltage electrical installation with AC electrical distribution within the PEI	14
Figure 2	– Example of prosumer's low-voltage electrical installation with AC and DC electrical distribution within the PEI	15
Figure 3	– Example of grid connected PEI architecture	18
Figure 4	– Example of islandable PEI architecture	19
Figure 5	– Example of architecture of PEI connected to LV DSO operating in TN-C-S in connected mode and becoming TN-S in island mode	28
Figure 6	– Example of architecture of PEI connected to LV DSO operating in TNC-S in connected mode and in island mode	29
Figure 7	– Example of architecture of PEI connected to LV DSO with disconnection of the neutral, operating in TT in connected mode and becoming TN in island mode.....	30
Figure 8	– Example of PEI installation with neutral earthing on the HV/LV transformer side: TT in connected mode, TN in island mode (as one unique earthing arrangement in the installation)	32
Figure 9	– Example of PEI installation in TN-S with neutral permanently earthed on PEI side.....	34
Figure 10	– Example of PEI installation in TN-S with neutral permanently earthed on PEI side with RCD on the system referencing conductor.....	37
Figure 11	– Example of PEI in IT system in island mode	39
Figure 12	– Example of PEI in IT system in island mode with automatic disconnection of supply.....	40
Figure 13	– Example of double short-circuit protection for the same circuit	43
Figure 14	– Example of selectivity with various power supplies	44
Figure 15	– Potential selectivity issue with overcurrent protections	45
Figure A.1	– Example of electrical design of PEI operating in direct feeding mode	47
Figure A.2	– Example of electrical design of PEI operating in island mode.....	48
Figure A.3	– Example of electrical design of individual PEI operating in reverse feeding mode.....	49
Figure C.1	– Example of electrical design of individual PEI	51
Figure C.2	– Example of type of architecture of individual PEI	52
Figure C.3	– Example of electrical design of collective PEI using DSO distribution system.....	53
Figure C.4	– Example of electrical design of collective PEI using a distribution system within PEI	54
Figure C.5	– Example of electrical design of collective PEI with distribution system within PEI in parallel with DSO distribution system.....	55

Figure C.6 – Example of type of architecture for collective PEI 56

Figure C.7 – Example of electrical design of shared PEI using DSO distribution system 57

Figure C.8 – Example of electrical design of shared PEI with distribution system within PEI 58

Figure C.9 – Example of electrical design of shared PEI with distribution system within PEI in parallel with DSO distribution system..... 59

Figure C.10 – Example of type of architecture for shared PEI 60

Figure D.1 – Example of single dwelling islandable PEI architecture in TN in connected mode and in island mode (with disconnection of the neutral – TN-S)..... 62

Figure D.2 – Example of single dwelling islandable PEI architecture in TT in connected mode becoming TN in island mode 63

Figure D.3 – Example of label..... 65

Figure D.4 – Example of single dwelling electrical installation before being upgraded to islandable PEI..... 66

Figure D.5 – Example of single dwelling electrical installation upgraded to islandable PEI..... 67

Table 1 – Combinations of possible types of system earthing in connected mode and island mode for PEIs and associated requirements for system referencing conductor switching device 27

ITEH STANDARD PREVIEW
(standards.iteh.ai)

[IEC 60364-8-82:2022](https://standards.iteh.ai/catalog/standards/sist/f5b75aee-ac1f-4582-a9b7-cfba064d5b55/iec-60364-8-82-2022)

<https://standards.iteh.ai/catalog/standards/sist/f5b75aee-ac1f-4582-a9b7-cfba064d5b55/iec-60364-8-82-2022>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –**Part 8-82: Functional aspects –
Prosumer's low-voltage electrical installations****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60364-8-82 has been prepared by IEC technical committee 64: Electrical installations and protection against electrical shock, IEC technical committee 8: System aspects of electrical energy supply and its subcommittee 8B: Decentralized electrical energy systems. It is an International Standard.

This first edition cancels and replaces IEC 60364-8-2 published in 2018. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to IEC 60364-8-2:2018:

- a) the vocabulary and concepts have been aligned as much as possible with those used by TC 8 and SC 8B, taking notably into account the IEC 62898 series and IEC TS 62786, still respecting the installers mindset (installers being the first users of the IEC 60364 series and being used to only refer to the IEC 60364 series);
- b) the type of system earthing and the change of type of system earthing (sequencing) when there is a change of mode of the prosuming installation, have been clarified;

- c) the conditions of connection and disconnection from the DSO network have also been described, both from the safety point of view and the proper functioning point of view;
- d) additional requirements have been introduced;
- e) the figures have been updated;
- f) a new normative Annex D on single dwelling or similar application islandable PEIs has been added;
- g) the numbering has also been reviewed to follow the updated numbering system of the IEC 60364 series, in line with the IEC Directives and compatible with Parts 7.

The text of this International Standard is based on the following documents:

Draft	Report on voting
64/2559/FDIS	64/2562/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

A list of all parts in the IEC 60364 series, published under the general title *Low-voltage electrical installations*, can be found on the IEC website.

The reader's attention is drawn to the fact that Annex E lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Historically, utilities were managing the public transmission and distribution network from the point of view of having a central production adapted to demand variation, a top-down energy flow, a production/consumption balance done by integrated utility companies and with rather passive users.

The following key factors are pushing the distribution network to change:

- the increasing number of electronic devices used daily and the growing needs as well as future needs (e.g. charging electric vehicles) will result in the structural growing of electricity consumption;
- the mediated pressure on climate change results in pressure on CO₂ emissions reduction;
- the electricity market is also quickly changing due mainly to its unbundling and deregulation, and to the greater number of intermittent renewable energy sources (global and local);
- users' expectations are also evolving as a result of an increasing need for better distribution networks reliability and quality, the search for better economic performance and the willingness to pro-actively manage their energy;
- technological evolution should also be considered as information and communication technology (ICT) is affordable and new energy storage solutions are emerging.

All stakeholders directly involved in the electricity generation, transmission, distribution and consumption have new expectations:

- customers are willing to reduce electrical energy costs in order to meet environment targets (renewable energy, energy efficiency) but also wish to benefit from the quality of electricity supply;
- suppliers wish to limit customer churn rate with price and service management;
- producers expect to maximize their yield of assets, to optimize their investments and to take profit from energy trading;
- the aggregator wants to create conditions suitable for new market emergence;
- the transmission system operator (TSO) aspires to a robust transmission network and to meet regulation objectives (price and level of services), while the distribution system operator (DSO) wants to meet regulation objectives (price and level of services), to reduce costs by productivity (including meter) and to have a flexible network;
- finally, governments and regulators are willing to create a competitive and sustainable energy market.

The objective of this document is to ensure that the low-voltage electrical installation is compatible with the current and future ways to deliver safely and functionally the electrical energy to current-using equipment wherever the electrical energy comes from the DSO or local generation. This document is not intended to influence all stakeholders of electricity supply on how the electrical energy should be sold and delivered.

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

Part 8-82: Functional aspects – Prosumer's low-voltage electrical installations

82.1 Scope

This part of IEC 60364 provides requirements and recommendations that apply to low-voltage electrical installations connected or not to a distribution network able to operate:

- with local power supplies, and/or
- with local storage units,

and that monitors and controls the energy from the locally connected sources delivering it to:

- current-using equipment, and/or
- local storage units, and/or
- distribution networks.

Such electrical installations are designated as prosumer's electrical installations (PEIs).

These requirements and recommendations apply to new installations and modifications of existing installations.

This document also provides requirements and recommendations for the safe, efficient and correct behaviour of these installations when integrated into a smart grid.

NOTE Requirements for electrical sources for safety services are given in IEC 60364-5-56.

Information related to grid interaction to ensure the stability of the electrical system for grid connected PEIs is given in Annex B.

This document covers the requirements related to stability of islanded and stand-alone PEIs.

82.2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60364 (all parts), *Low-voltage electrical installations*

IEC 60364-4-41:2005, *Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock*

IEC 60364-4-41/AMD1:2017

IEC 60364-4-42:2010, *Low-voltage electrical installations – Part 4-42: Protection for safety – Protection against thermal effects*

IEC 60364-4-43:2008, *Low-voltage electrical installations – Part 4-43: Protection for safety – Protection against overcurrent*

IEC 60364-5-51:2005, *Electrical installations of buildings – Part 5-51: Selection and erection of electrical equipment – Common rules*

IEC 60364-5-53:2019, *Low-voltage electrical installations – Part 5-53: Selection and erection of electrical equipment – Devices for protection for safety, isolation, switching, control and monitoring*

IEC 60364-5-53:2019/AMD1:2020

IEC 60364-5-54:2011, *Low-voltage electrical installations – Part 5-54: Selection and erection of electrical equipment – Earthing arrangements and protective conductors*

IEC 60364-5-55:2011, *Electrical installations of buildings – Part 5-55: Selection and erection of electrical equipment – Other equipment*

IEC 60364-5-55:2011/AMD1:2012

IEC 60364-5-55:2011/AMD2:2016

IEC 60364-5-57, *Low-voltage electrical installations – Part 5-57: Selection and erection of electrical equipment – Erection of stationary secondary batteries*

IEC 60364-6, *Low voltage electrical installations – Part 6: Verification*

IEC 60364-7-722, *Low-voltage electrical installations – Part 7-722: Requirements for special installations or locations – Supplies for electric vehicles*

IEC 60947-2:2016, *Low-voltage switchgear and controlgear – Part 2: Circuit-breakers*

IEC 60947-2:2016/AMD1:2019

[IEC 60364-8-82:2022](https://standards.iteh.ai/catalog/standards/sist/f5b75aee-ac1f-4582-a9b7-cfba064d5b55/iec-60364-8-82:2022)

[https://standards.iteh.ai/catalog/standards/sist/f5b75aee-ac1f-4582-a9b7-cfba064d5b55/iec-](https://standards.iteh.ai/catalog/standards/sist/f5b75aee-ac1f-4582-a9b7-cfba064d5b55/iec-61557-12:2018)

IEC 61557-12:2018, *Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures – Part 12: Power metering and monitoring devices (PMD)*

IEC 62423, *Type F and type B residual current operated circuit-breakers with and without integral overcurrent protection for household and similar uses*

IEC TS 62749, *Assessment of power quality – Characteristics of electricity supplied by public networks*

82.3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

82.3.1

smart grid

intelligent grid

electric power system that utilizes information exchange and control technologies, distributed computing and associated sensors and actuators, for purposes such as:

- to integrate the behaviour and actions of the network users and other stakeholders,

- to efficiently deliver sustainable, economic and secure electricity supplies

[SOURCE: IEC 60050-617:2011, 617-04-13]

82.3.2 distribution network

electric power network for the distribution of electric power from and to network users for which a distribution system operator (DSO) is responsible

[SOURCE: IEC TS 62786:2017, 3.4]

82.3.3 producer

<of electricity> entity or party generating electrical energy

[SOURCE: IEC 60050-617:2009, 617-02-01, modified – "entity or" has been added.]

82.3.4 consumer

<of electricity> entity or party which uses electricity

82.3.5 prosumer

<of electricity> entity or party which can be both a producer and a consumer of electrical energy

82.3.6 prosumer's electrical installation PEI

low-voltage electrical installation connected or not to a distribution network able to operate:

- with local power supplies, and/or
- with local storage units,

that monitors and controls the energy from the connected sources delivering it to:

- current-using equipment, and/or
- local storage units, and/or
- distribution networks

82.3.7 electrical energy management system EEMS

system monitoring, operating, controlling and managing energy resources and loads of the installation

Note 1 to entry: The EEMS can be a dedicated system or part of an integrated system, such as a home and building electronic system (HBES) or building management system (BMS or BACS) or other similar management system.

[SOURCE: IEC 60364-8-1:2019, 3.2.1, modified – Note 1 to entry has been added.]

82.3.8 operating mode

operation of an installation with respect to the different sources of electrical energy and to energy flow

82.3.9 direct feeding mode

operating mode in which the distribution network supplies the PEI

Note 1 to entry: Local storage units can supply current-using equipment or be charged by local power supplies and/or the distribution system.

82.3.10

reverse feeding mode

operating mode in which the PEI supplies the distribution network

Note 1 to entry: Local storage units can supply current-using equipment and/or the distribution system or be charged by local power supplies.

82.3.11

connected mode

operating mode in which the PEI is connected to the distribution network

EXAMPLE Direct feeding mode, reverse feeding mode or no feeding mode (i.e. without any energy exchange between the PEI and the distribution network).

82.3.12

island mode

operating mode in which the PEI is disconnected from the distribution network

Note 1 to entry: An island mode can be either the result of the action of automatic protections or the result of a deliberate action.

[SOURCE: IEC 60050-692:2017, 692-02-11, modified – The term "electric island" has been replaced with "island mode", the definition has been adapted to the PEI and Note 2 to entry has been deleted.]

82.3.13

grid connected PEI

PEI intended for operating only when connected to a distribution network

82.3.14

stand-alone PEI

PEI permanently not connected to a distribution network

Note 1 to entry: A stand-alone PEI is in a permanent island mode.

82.3.15

islandable PEI

PEI intended for operating either being connected to a distribution network or being disconnected from the distribution network

Note 1 to entry: An islandable PEI is in a connected mode or an intentionally island mode.

82.3.16

point of connection

POC

reference point where the prosumer's electrical installation is connected to the distribution network

Note 1 to entry: A PEI can have several points of connection for resilience.

Note 2 to entry: In IEC 60364 (all parts), the concept of origin of the installation is also used, origin of the installation meaning the point at which energy is delivered to the electrical installation. The POC is a specific origin of the installation, the one connected to the distribution network. Other origins of the installation can be the connection to the local power supply, to the storage system..

Note 3 to entry: Connection or disconnection of the prosumer electrical installation from the distribution network generally occurs at the POC.

[SOURCE: IEC 60050-617:2009, 617-04-01 modified – The definition has been adapted to the PEI and the notes to entry have been added.]

82.3.17**load shedding**

method(s) of optimizing demand by controlling the electrical loads for variable periods of time

[SOURCE: IEC 60364-8-1:2019, 3.2.2]

82.3.18**system referencing conductor**

conductor that connects one live conductor of the power system to an earthing arrangement

Note 1 to entry: The live conductor connected is the neutral or the mid-point if existing, or a line conductor when not existing.

82.3.19**electrical energy storage system****EES**

installation able to absorb electrical energy, to store it for a certain duration and to release it

[SOURCE: IEC 62933-1:2018, 3.2, modified – The definition has been adapted to the PEI and the notes to entry have been deleted.]

82.4 Integration of PEI in its environment**82.4.1 Main objectives**

Where a smart grid and an electrical installation interact a dynamic power demand/response concept should be implemented.

The smart grid has an impact on the electrical installations, thus:

- the consumer shall take into consideration the constraints of the electrical power system and can adapt its needs (e.g. through time) with the EEMS;
- the design and configuration of the installation may include load shedding and source selection by the EEMS.

As production of energy from the renewable sources such as PV or wind turbines is intermittent, a storage capacity may be installed within the PEI to ensure continuity of supply in all modes without being supplied by the grid, to support stability of the PEI and/or to maximize the self-consumption in connected mode.

82.4.2 Safety

The implementation of the requirements provided in this document shall not impair the safety of the PEI, as required by other parts of the IEC 60364 series. In case of change from any energy supply configuration (e.g. from distribution network supply to local power supplies) all protective measures shall continue to be operational or shall be automatically replaced by other standardized protective measures providing an equivalent level of safety.

82.4.3 Proper functioning

The power quality parameters are used to demonstrate reliable operation of the PEI and should not be outside the allowed operating range for all components in the PEI.

For a non stand-alone PEI, unless otherwise specified, the power quality levels at the point of connection (POC) shall be in the same range allowed in grid-connected and island mode.

When a PEI is connected to a distribution system, it shall not cause unacceptable disturbances to the other system users.

When operating in parallel with the distribution system the PEI shall not cause voltage fluctuation at the distribution system or result in flicker and rapid voltage changes outside the ranges defined in the IEC TS 62749.

NOTE See also IEC TS 60364-8-3:2020, Clause 11.

82.5 PEI concept

Any low-voltage PEI shall be considered as a set of electrical equipment having the following functions (see Figure 1):

- supply (e.g. connection to public power supply, local generator, photovoltaic systems, wind turbines, electrical energy storage system);
- distribution (e.g. distribution panel, wiring systems);
- consumption (e.g. motors, heating systems, lighting, lifts);
- energy management (e.g. load shedding equipment, monitoring device).

NOTE 1 An electrical energy storage system can be considered as a generator and as a load.

The electrical distribution within the PEI can be in alternating current (a.c), direct current (d.c), or a combination of both (see examples in Figure 1 and Figure 2), as every low voltage electrical installation covered by IEC 60364 (all parts).

The electrical installations shall consider both the requests from the DSO and the needs expressed by the prosumer. An EEMS shall be implemented to combine information and/or data, from/to the DSO, the availability of energy by the local sources and the prosumer's needs. The EEMS shall ensure the data security.

An uninterruptible power supply (UPS) shall not be considered as a prosumer when this UPS does not have a reverse feeding mode to supply energy to current-using equipment in the upstream part of the electrical installation and/or the distribution network, if any.