

INTERNATIONAL STANDARD

**Solderless connections –
Part 7: Spring clamp connections – General requirements, test methods and
practical guidance**

IEC 60352-7:2020
<https://standards.iteh.ai/catalog/standards/sist/3e48a6c9-27c0-4e11-a507-dc8effb6f493/iec-60352-7-2020>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2020 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

[IEC 60352-7:2020](https://standards.iec.ch/catalog/standards/sist/3c48a6c9-27c0-4e11-a507-dc8effb6f493/iec-60352-7-2020)

<https://standards.iec.ch/catalog/standards/sist/3c48a6c9-27c0-4e11-a507-dc8effb6f493/iec-60352-7-2020>

INTERNATIONAL STANDARD

**Solderless connections –
Part 7: Spring clamp connections – General requirements, test methods and
practical guidance**

STANDARD PREVIEW
(standards.iteh.ai)
<https://standards.iteh.ai/catalog/standards/sist/3e48a6c9-27c0-4e11-a507-dc8effb6f493/iec-60352-7-2020>
IEC 60352-7:2020

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 31.220.10

ISBN 978-2-8322-9181-8

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	4
INTRODUCTION	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	8
4 Requirements	10
4.1 Workmanship	10
4.2 Tools	10
5 Pre-requisites for basic test schedule	10
5.1 Spring clamp terminations	10
5.1.1 Materials	10
5.1.2 Surface finishes	11
5.1.3 Design features	11
5.1.4 Dimensions	11
5.2 Wires	11
5.2.1 General	11
5.2.2 Materials	11
5.2.3 Dimensions	11
5.2.4 Surface finishes	11
5.2.5 Wire insulation	12
5.3 Spring clamp connections	12
6 Testing	12
6.1 General	12
6.2 Standard conditions for testing	12
6.3 Preconditioning	12
6.4 Recovery	12
6.5 Mounting of specimen	12
7 Tests	13
7.1 General examination	13
7.2 Mechanical tests	13
7.2.1 Tensile strength	13
7.2.2 Wire deflection	13
7.2.3 Vibration	16
7.2.4 Repeated connections and disconnections	17
7.3 Electrical tests	18
7.3.1 Contact resistance	18
7.3.2 Electrical load and temperature	19
7.4 Climatic tests	19
7.4.1 General	19
7.4.2 Rapid change of temperature	19
7.4.3 Climatic sequence	19
7.4.4 Flowing mixed gas corrosion test	20
8 Test schedules	20
8.1 General	20
8.2 Basic test schedule	21

8.2.1	General	21
8.2.2	Initial examination.....	21
8.2.3	Testing of spring clamp connections with spring clamp terminations with and without a specified wire range	21
8.3	Full test schedule.....	22
8.3.1	General	22
8.3.2	Initial examination.....	22
8.3.3	Testing of spring clamp connections with and without a specified wire range	22
8.4	Flow charts	23
Annex A (informative)	Practical guidance	26
A.1	Current-carrying capacity	26
A.2	Tool information	26
A.3	Termination information	26
A.3.1	General	26
A.3.2	Design features	26
A.3.3	Materials	27
A.3.4	Surface finishes.....	27
A.4	Wire information.....	27
A.4.1	General	27
A.4.2	Materials	28
A.4.3	Surface finishes.....	28
A.4.4	Stripping information.....	28
A.5	Connection information	29
Bibliography.....	IEC 60352-7:2020 https://standards.iteh.ai/catalog/standards/sist/3e48a6c9-27c0-4e11-a507-4b8e8b68193/iec-60352-7-2020	30
Figure 1	– Examples of spring clamp connections.....	9
Figure 2	– Example of a spring clamp terminal.....	10
Figure 3	– Information for the wire deflection test.....	16
Figure 4	– Test arrangement, vibration	17
Figure 5	– Test arrangement, current method	18
Figure 6	– Basic test schedule (see 8.2)	24
Figure 7	– Full test schedule (see 8.3)	25
Figure A.1	– Correctly stripped wire	28
Figure A.2	– Examples of stripping faults	29
Table 1	– Values of tensile strength	13
Table 2	– Value of force for wire deflection test	15
Table 3	– Vibration, test severities	17
Table 4	– Rated current of the wires, initial and final contact resistance.....	19
Table 5	– Number of specimens required	21
Table 6	– Test group P1	21
Table 7	– Test group P2	22
Table 8	– Test group A	22
Table 9	– Test group B	23
Table 10	– Test group C	23
Table 11	– Test group D	23

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SOLDERLESS CONNECTIONS –**Part 7: Spring clamp connections – General requirements,
test methods and practical guidance****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60352-7 has been prepared by subcommittee SC 48B: Electrical connectors, of IEC technical committee 48: Electrical connectors and mechanical structures for electrical and electronic equipment.

This second edition cancels and replaces the first edition of IEC 60352-7, published in 2002. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) correction of the two flow charts in Figure 6 and Figure 7,
- b) split the content into more clauses for better separation between full test schedule and basic test schedule,
- c) relocating the content of former Clause 6 Practical guidance into an informative Annex A, as now common in the IEC 60352 series for solderless connections,

d) clarification on conductor types with reference to classes defined in IEC 60228.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
48B/2823/CDV	48B/2851/RVC

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

This document was drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60352 series, published under the general title *Solderless connections*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

ITEH STANDARD PREVIEW
(standards.iteh.ai)

IEC 60352-7:2020

<https://standards.iteh.ai/catalog/standards/sist/3e48a6c9-27c0-4e11-a507-dc8efb6f493/iec-60352-7-2020>

INTRODUCTION

This part of IEC 60352 covers spring clamp connections and includes requirements, tests and practical guidance information.

Two test schedules are provided.

- a) The basic test schedule applies to spring clamp connections which conform to all requirements of Clause 5. These requirements are derived from experience with successful applications of such spring clamp connections.
- b) The full test schedule applies to spring clamp connections which do not fully conform to all requirements of Clause 5, for example which are manufactured using materials or finishes not included in Clause 5.

This approach permits cost and time effective performance verification using a limited basic test schedule for established spring clamp connections and an expanded full test schedule for spring clamp connections requiring more extensive performance validation.

The values given in this document are minimum values, which are harmonized with other IEC documents. Other standards may specify other values.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

IEC 60352-7:2020

<https://standards.iteh.ai/catalog/standards/sist/3e48a6c9-27c0-4e11-a507-dc8effb6f493/iec-60352-7-2020>

SOLDERLESS CONNECTIONS –

Part 7: Spring clamp connections – General requirements, test methods and practical guidance

1 Scope

This part of IEC 60352 is applicable to spring clamp connections made with stripped wire without further preparation:

- solid conductors of 0,32 mm to 3,7 mm nominal diameter (0,08 mm² to 10 mm² cross-section), or
- stranded conductors of 0,08 mm² to 10 mm² cross-section, or
- flexible conductors of 0,08 mm² to 10 mm² cross-section,

according to IEC 60228 or IEC 60189-3 for use in electrical and electronic equipment and components.

Information on materials and data from industrial experience is included in addition to the test procedures to provide electrically stable connections under prescribed environmental conditions.

The object of this document is to determine the suitability of spring clamp connections under specified mechanical, electrical and atmospheric conditions.

NOTE IEC Guide 109 advocates the need to minimize the impact of a product on the natural environment throughout the product life cycle. It is understood that some of the materials permitted in this document can have a negative environmental impact. As technological advances lead to acceptable alternatives for these materials, they will be eliminated from this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-1:2013, *Environmental testing – Part 1: General and guidance*

IEC 60189-3:2007, *Low-frequency cables and wires with PVC insulation and PVC sheath – Part 3: Equipment wires with solid or stranded conductor wires, PVC insulated, in singles, pairs and triples*

IEC 60228:2004, *Conductors of insulated cables*

IEC 60512-1, *Connectors for electrical and electronic equipment – Tests and measurements – Part 1: Generic specification*

IEC 60512-1-1, *Connectors for electronic equipment – Tests and measurements – Part 1-1: General examination – Test 1a: Visual examination*

IEC 60512-1-2, *Connectors for electronic equipment – Tests and measurements – Part 1-2: General examination – Test 1b: Examination of dimension and mass*

IEC 60512-2-1, *Connectors for electronic equipment – Tests and measurements – Part 2-1: Electrical continuity and contact resistance tests – Test 2a: Contact resistance – Millivolt level method*

IEC 60512-2-2, *Connectors for electronic equipment – Tests and measurements – Part 2-2: Electrical continuity and contact resistance tests – Test 2b: Contact resistance – Specified test current method*

IEC 60512-2-5, *Connectors for electronic equipment – Tests and measurements – Part 2-5: Electrical continuity and contact resistance tests – Test 2e: Contact disturbance*

IEC 60512-6-4, *Connectors for electronic equipment – Tests and measurements – Part 6-4: Dynamic stress tests – Test 6d: Vibration (sinusoidal)*

IEC 60512-9-2, *Connectors for electronic equipment – Tests and measurements – Part 9-2: Endurance tests – Test 9b: Electrical load and temperature*

IEC 60512-11-1, *Connectors for electrical and electronic equipment – Tests and measurements – Part 11-1: Climatic tests – Test 11a – Climatic sequence*

IEC 60512-11-4, *Connectors for electronic equipment – Tests and measurements – Part 11-4: Climatic tests – Test 11d: Rapid change of temperature*

IEC 60512-11-7, *Connectors for electronic equipment – Tests and measurements – Part 11-7: Climatic tests – Test 11g: Flowing mixed gas corrosion test*

IEC 60512-16-20, *Electromechanical components for electronic equipment – Basic testing procedures and measuring methods – Part 16: Mechanical tests on contacts and terminations – Section 20: Test 16t: Mechanical strength (wired termination of solderless connections)*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

spring clamp termination

part of the contact or terminal to which one single conductor only is connected by means of a spring

3.1.1

universal spring clamp termination

spring clamp termination intended to accept solid, stranded and flexible unprepared conductors

Note 1 to entry: For the meaning of solid, stranded and flexible, see IEC 60228 where conductors are classified as class 1 (solid conductors), class 2 (stranded conductors), class 5 (flexible conductors) and class 6 (flexible conductors which are more flexible than class 5).

3.1.2

non-universal spring clamp termination

spring clamp termination intended to accept conductors of one class only, for example solid conductors only, or conductors of two classes only, for example solid and stranded but not flexible

Note 1 to entry: For the meaning of solid, stranded and flexible, see IEC 60228 where conductors are classified as class 1 (solid conductors), class 2 (stranded conductors), class 5 (flexible conductors) and class 6 (flexible conductors which are more flexible than class 5).

3.1.3

push-in spring clamp termination

non-universal spring clamp termination in which the connection is made by pushing in a solid or stranded conductor without the aid of a tool or of an actuating element

Note 1 to entry: For the meaning of solid and stranded, see IEC 60228 where solid conductors are classified as class 1, stranded conductors are classified as class 2.

3.2

spring clamp connection

solderless connection achieved by clamping a conductor with a spring clamp termination

SEE: Figure 1




Figure 1a – Spring clamp connection, operated without a tool




Figure 1b – Spring clamp connection, operated with a tool




Figure 1c – Spring clamp connection, operated with an actuating element




Figure 1d – Spring clamp connections, with a push-in spring clamp termination, with solid wires

Figure 1 – Examples of spring clamp connections

3.3

spring clamp terminal

terminal designed to accept a conductor for the purpose of establishing a spring clamp connection

SEE: Figure 2




Figure 2 – Example of a spring clamp terminal

3.4

spring clamp connecting device

device for the electrical connection of one or more conductors comprising one or more spring clamp terminations and, if necessary, insulation and/or auxiliary parts

3.5

actuating element

part of a spring clamp termination or terminal to which an external force is to be applied, and the resulting movement of which provides a means for activating or deactivating the spring

4 Requirements

4.1 Workmanship

The connection shall be processed in a careful and workmanlike manner, in accordance with good current practice. Annex A (informative) provides practical guidance and may constitute a benchmark for the assessment of workmanship.

NOTE Some industry sectors (e.g. automotive, aerospace, marine, nuclear, military) use workmanship standards which can be considered upon agreement between manufacturer and user.

4.2 Tools

Tools, if necessary, shall be used and inspected according to the instructions given by the manufacturer.

5 Pre-requisites for basic test schedule

5.1 Spring clamp terminations

5.1.1 Materials

- Materials for the current-carrying parts:
suitable grades of copper or copper alloy shall be used.