



Edition 1.0 2021-07

INTERNATIONAL STANDARD

Optical fibre cables Feh STANDARD PREVIEW Part 1-402: Generic specification – Basic optical cable test procedures – Electrical test methods – Lightning test (for OPGW, OPPC and OPAC), Method H2

<u>IEC 60794-1-402:2021</u> https://standards.iteh.ai/catalog/standards/sist/2900a02b-efe7-40af-bee2-90d5f75ee0b4/iec-60794-1-402-2021





THIS PUBLICATION IS COPYRIGHT PROTECTED Copyright © 2021 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office 3, rue de Varembé CH-1211 Geneva 20 Switzerland

Tel.: +41 22 919 02 11 info@iec.ch www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

> https://standards.iteh.ai/catalog/standards/sist/2900a02b-efe7-40af-bee2 90d5f75ee0b4/iec-60794-1-402-2021

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email. II en SIA

(IEV) online. IEC Customer Service Centre - webstore iec ch/csc If you wish to give us your feedback on this publication or ds.iteh.ai need further assistance, please contact the Customer Service Centre: sales@iec.ch. IEC 60794-1-402:2021

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary





Edition 1.0 2021-07

INTERNATIONAL STANDARD

Optical fibre cables - eh STANDARD PREVIEW

Part 1-402: Generic specification – Basic optical cable test procedures – Electrical test methods – Lightning test (for OPGW, OPPC and OPAC), Method H2

<u>IEC 60794-1-402:2021</u> https://standards.iteh.ai/catalog/standards/sist/2900a02b-efe7-40af-bee2-90d5f75ee0b4/iec-60794-1-402-2021

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ICS 33.180.10

ISBN 978-2-8322-1008-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	3
INTRODUCTION	5
1 Scope	6
2 Normative references	6
3 Terms, definitions and abbreviated terms	6
3.1 Terms and definitions	6
3.2 Abbreviated terms	6
4 General	6
5 Sample	7
6 Apparatus	7
7 Procedure	8
8 Requirements	8
9 Details to be specified	8
Bibliography	. 10
Figure 1 – Lightning test arrangement	7
iTeh STANDARD PREVIEW	
Table 1 – Test parameters	8

Table 2 – Details to be specifie	d for	each lightn	ning strike	6
----------------------------------	-------	-------------	-------------	---

<u>IEC 60794-1-402:2021</u> https://standards.iteh.ai/catalog/standards/sist/2900a02b-efe7-40af-bee2-90d5f75ee0b4/iec-60794-1-402-2021

INTERNATIONAL ELECTROTECHNICAL COMMISSION

OPTICAL FIBRE CABLES –

Part 1-402: Generic specification – Basic optical cable test procedures – Electrical test methods – Lightning test (for OPGW, OPPC and OPAC), Method H2

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 5) IEC itself does not provide any attestation of conformity, independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60794-1-402 has been prepared by subcommittee 86A: Fibres and cables, of IEC technical committee 86: Fibre optics. It is an International Standard.

This first edition cancels and replaces the first edition of IEC 60794-1-24 published in 2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) OPPC cables are included.

The text of this International Standard is based on the following documents:

Draft	Report on voting		
86A/2045/CDV	86A/2128/RVC		

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

A list of all the parts in the IEC 60794 series, published under the general title Optical fibre cables, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed, **iTeh STANDARD PREVIEW**
- withdrawn.
- replaced by a revised edition, or and ards.iteh.ai)
- amended.

IEC 60794-1-402:2021 https://standards.iteh.ai/catalog/standards/sist/2900a02b-efe7-40af-bee2-90d5f75ee0b4/iec-60794-1-402-2021

INTRODUCTION

The electrical tests contained in IEC 60794-1-24:2014 will now be individually numbered in the IEC 60794-1-4xx series. Each test method is now considered to be an individual document rather than part of a multi-test method compendium. Full cross-reference details are given in IEC 60794-1-2.

iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>IEC 60794-1-402:2021</u> https://standards.iteh.ai/catalog/standards/sist/2900a02b-efe7-40af-bee2-90d5f75ee0b4/iec-60794-1-402-2021

OPTICAL FIBRE CABLES –

- 6 -

Part 1-402: Generic specification – Basic optical cable test procedures – Electrical test methods – Lightning test (for OPGW, OPPC and OPAC), Method H2

1 Scope

This part of IEC 60794 applies to the test intended to evaluate the impact of a lightning strike on an optical ground wire (OPGW), optical phase conductor (OPPC) or optical attached cable (OPAC).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60793-1-46, Optical fibres – Part 1-46: Measurement methods and test procedures – Monitoring of changes in optical transmittance

IEC 60794-1-1, Optical fibre cables – Part 1-1: Generic specification – General IEC 60794-1-402:2021 https://standards.iteh.ai/catalog/standards/sist/2900a02b-efe7-40af-bee2-

3 Terms, definitions and abbreviated terms 1-402-2021

3.1 Terms and definitions

For the purposes of this document, the definitions given in IEC 60794-1-1 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

3.2 Abbreviated terms

EDS everyday stress

OPAC optical attached cable

OPGW optical ground wire

OPPC optical phase conductor

RTS rated tensile strength

4 General

The lightning test should be carried out only for comparison between different cable designs.

In the case of an OPAC, the cable shall be installed on the messenger in order to simulate as closely as possible a real installation, and the lightning test should be carried out to determine that the sheath is not severely damaged.

IEC 60794-1-402:2021 © IEC 2021 - 7 -

5 Sample

The test shall be performed on the mid-point of an OPGW sample, an OPPC sample or an OPAC sample attached to the agreed messenger.

The sample shall be at least 10 m long between the anchoring clamps.

Optical attenuation of monitored fibres shall be measured according IEC 60793-1-46. The test length of the optical fibre shall be longer than 100 m. In order to detect damage to any of fibre units (tubes) in the cable due to simulated lightning strike, the test loop shall preferably include at least 24 fibres (fibre concatenation shall be used), or all the fibres in the cable when their count is lower. If the OPGW/OPPC/OPAC under test comprises multiple units (tubes) with optical fibres, the measured fibres shall be taken from all units in equal numbers.

6 Apparatus

A typical test arrangement which can be used for the lightning test is shown in Figure 1.



Key

- 1 thermocouple
- 2 insulator
- 3 anchoring clamps
- 4 symmetric earthing connectors
- 5 electrode with plane surface preferably in Wolfram-Copper
- 6 metal fuse for ignition
- 7 tension meter
- 8 gap between electrode and cable surface = 6 cm
- A test sample (including OPAC messenger wire, if applicable)

Figure 1 – Lightning test arrangement

The electrode, consisting of a copper or iron rod, shall be positioned above the metallic cable. The electrode and metallic cable shall be connected between themselves by metal fuse. The applied tensile load on the metallic cable sample shall be everyday stress (EDS), 15 % \pm 5 % of the rated tensile stress (RTS). If mutually agreed between the customer and supplier, other tension loads may be applied.

When testing an OPAC, a metal fuse shall be connected as closely as possible to a point where the OPAC and, where applicable, the lashing binder is in contact with the messenger.

7 Procedure

The sample shall be subjected to a simulated lightning strike, which causes melting effects.

	Class 0	Class 1	Class 2	Class 3
Current (A)	100	200	300	400
Duration (s)	0,5	0,5	0,5	0,5
Charge transfer (C)	50	100	150	200

Table 1 – Test parameters

The test parameters are chosen between class 0 and class 3 according to Table 1 or can be agreed between the customer and the supplier, depending on the construction characteristics.

The initial temperature of the cable should be about +23 °C \pm 5 °C but other values may be used if mutually agreed between customer and supplier. The test shall be repeated 5 times under the same conditions on different samples or different sections of the same sample if wires are undamaged. The tolerance on the charge transference is \pm 10 %. A charge exceeding 110 % of the target value may also be acceptable. The average of the five (5) charge transfers shall exceed 95 % of the target. (standards.iteh.ai)

Requirements

8

IEC 60794-1-402:2021

https://standards.iteh.ai/catalog/standards/sist/2900a02b-efe7-40af-bee2-

On completion of the test, the following criteria shall be considered:

- a) Any permanent or temporary increase in optical attenuation greater than the specified value shall constitute a failure (OPGW/OPPC/OPAC).
- b) For OPGW or OPPC, the residual strength of the cable shall be calculated from the sum of the tensile strength of the individual wires of the cable sample submitted to the lightning strike. If the calculated residual strength is less than 75 % of the original declared RTS, then this shall constitute a failure.

9 Details to be specified

For details to be specified and reported in the test report, see Table 2.