

INTERNATIONAL STANDARD



**Digital addressable lighting interface –
Part 102: General requirements – Control gear**

Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 62386-102:2022](#)

<https://standards.iteh.ai/catalog/standards/iec/2c8c9930-2808-4ee2-8ba2-0a79d065c56d/iec-62386-102-2022>





THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2022 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

International Standards
standards.iteh.ai
Document Preview

[IEC 62386-102:2022](https://standards.iteh.ai/catalog/standards/iec/2c8c9930-2808-4ee2-8ba2-0a79d065c56d/iec-62386-102-2022)

<https://standards.iteh.ai/catalog/standards/iec/2c8c9930-2808-4ee2-8ba2-0a79d065c56d/iec-62386-102-2022>



IEC 62386-102

Edition 3.0 2022-11
COMMENTED VERSION

INTERNATIONAL STANDARD



**Digital addressable lighting interface –
Part 102: General requirements – Control gear**

iteh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 62386-102:2022](https://standards.iteh.ai/catalog/standards/iec/2c8c9930-2808-4ee2-8ba2-0a79d065c56d/iec-62386-102-2022)

<https://standards.iteh.ai/catalog/standards/iec/2c8c9930-2808-4ee2-8ba2-0a79d065c56d/iec-62386-102-2022>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.140.50; 29.140.99

ISBN 978-2-8322-6103-3

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	7
INTRODUCTION	10
1 Scope	12
2 Normative references	12
3 Terms and definitions	12
4 General	15
4.1 General	15
4.2 Version number	15
5 Electrical specification	16
6 Interface Bus power supply	16
7 Transmission protocol structure	16
7.1 General	16
7.2 16-bit forward frame encoding	16
7.2.1 General	16
7.2.2 Address byte	16
7.2.3 Opcode byte	17
8 Timing	17
9 Method of operation	17
9.1 General	17
9.2 Control gear	17
9.2.1 General	17
9.2.2 Control gear phases	17
9.3 Dimming curve	18
9.4 Calculating "targetLevel"	22
9.5 Fading	22
9.5.1 General	22
9.5.2 Fade time	23
9.5.3 Fade rate	25
9.5.4 Extended fade time	26
9.5.5 Using the fade time	28
9.5.6 Using the fade rate	28
9.5.7 System response to changes during a fade	29
9.5.8 System response to changes during standby and startup	29
9.5.9 Stopping a fade	29
9.6 Min and max level	29
9.7 Commands	30
9.7.1 General	30
9.7.2 Level instructions without fade	31
9.7.3 Level instructions initiating a fade	31
9.7.4 Configuration instructions	31
9.7.5 Queries	31
9.7.6 Special commands	31
9.7.7 Application extended commands	31

9.8	Command iterations.....	32
9.8.1	General.....	32
9.8.2	Command iteration of "UP" and "DOWN" commands.....	32
9.8.3	DAPC SEQUENCE (deprecated).....	32
9.9	Modes of operation.....	33
9.9.1	General.....	33
9.9.2	Operating mode 0x00: standard mode.....	33
9.9.3	Operating mode 0x01 to 0x7F: reserved.....	33
9.9.4	Operating mode 0x80 to 0xFF: manufacturer-specific modes.....	33
9.10	Memory banks.....	34
9.10.1	General.....	34
9.10.2	Memory map.....	34
9.10.3	Selecting a memory bank location.....	35
9.10.4	Protectable memory locations.....	35
9.10.5	Memory bank reading.....	36
9.10.6	Memory bank writing.....	37
9.10.7	Memory bank 0.....	38
9.10.8	Memory bank 1 (optional).....	41
9.10.9	Manufacturer-specific memory banks.....	43
9.10.10	Reserved memory banks.....	43
9.11	Reset.....	43
9.11.1	Reset operation.....	43
9.11.2	Reset memory bank operation.....	43
9.12	System failure.....	44
9.13	Power on.....	44
9.14	Assigning short addresses.....	45
9.14.1	General.....	45
9.14.2	Random address allocation.....	45
9.14.3	Identification of a device.....	46
9.14.4	Direct address allocation.....	47
9.15	Failure state behaviour.....	47
9.16	Status information.....	47
9.16.1	General.....	47
9.16.2	Bit 0: Control gear failure.....	48
9.16.3	Bit 1: lamp failure.....	48
9.16.4	Bit 2: lamp on.....	50
9.16.5	Bit 3: limit error.....	50
9.16.6	Bit 4: fade running.....	50
9.16.7	Bit 5: reset state.....	50
9.16.8	Bit 6: missing short address.....	50
9.16.9	Bit 7: power cycle seen.....	50
9.17	Non-volatile memory.....	50
9.18	Device types and features.....	51
9.19	Using scenes.....	51
9.20	Current bus unit configuration.....	52
10	Declaration of variables.....	53

11	Definition of commands	56
11.1	General	56
11.2	Overview sheets	56
11.3	Level instructions	61
11.3.1	DAPC (<i>level</i>)	61
11.3.2	OFF	61
11.3.3	UP	61
11.3.4	DOWN	61
11.3.5	STEP UP	62
11.3.6	STEP DOWN	62
11.3.7	RECALL MAX LEVEL	62
11.3.8	RECALL MIN LEVEL	63
11.3.9	STEP DOWN AND OFF	63
11.3.10	ON AND STEP UP	63
11.3.11	ENABLE DAPC SEQUENCE	64
11.3.12	GO TO LAST ACTIVE LEVEL	64
11.3.13	CONTINUOUS UP	64
11.3.14	CONTINUOUS DOWN	64
11.3.15	GO TO SCENE (<i>sceneNumber</i>)	64
11.4	Configuration instructions	64
11.4.1	General	64
11.4.2	RESET	65
11.4.3	STORE ACTUAL LEVEL IN DTR0	65
11.4.4	SAVE PERSISTENT VARIABLES	65
11.4.4	SET OPERATING MODE (<i>DTR0</i>)	65
11.4.5	RESET MEMORY BANK (<i>DTR0</i>)	65
11.4.6	IDENTIFY DEVICE	65
11.4.7	SET MAX LEVEL (<i>DTR0</i>)	66
11.4.8	SET MIN LEVEL (<i>DTR0</i>)	66
11.4.9	SET SYSTEM FAILURE LEVEL (<i>DTR0</i>)	66
11.4.10	SET POWER ON LEVEL (<i>DTR0</i>)	67
11.4.11	SET FADE TIME (<i>DTR0</i>)	67
11.4.12	SET FADE RATE (<i>DTR0</i>)	67
11.4.13	SET EXTENDED FADE TIME (<i>DTR0</i>)	67
11.4.14	SET SCENE (<i>DTR0, sceneX</i>)	68
11.4.15	REMOVE FROM SCENE (<i>sceneX</i>)	68
11.4.16	ADD TO GROUP (<i>group</i>)	68
11.4.17	REMOVE FROM GROUP (<i>group</i>)	68
11.4.18	SET SHORT ADDRESS (<i>DTR0</i>)	68
11.4.19	ENABLE WRITE MEMORY	69
11.5	Queries	69
11.5.1	General	69
11.5.2	QUERY STATUS	69
11.5.3	QUERY CONTROL GEAR PRESENT	69
11.5.4	QUERY CONTROL GEAR FAILURE	69
11.5.5	QUERY LAMP FAILURE	69
11.5.6	QUERY LAMP POWER ON	69

11.5.7	QUERY LIMIT ERROR.....	69
11.5.8	QUERY RESET STATE	69
11.5.9	QUERY MISSING SHORT ADDRESS	69
11.5.10	QUERY VERSION NUMBER.....	70
11.5.11	QUERY CONTENT DTR0	70
11.5.12	QUERY DEVICE TYPE	70
11.5.13	QUERY NEXT DEVICE TYPE	70
11.5.14	QUERY PHYSICAL MINIMUM.....	70
11.5.15	QUERY POWER FAILURE.....	71
11.5.16	QUERY CONTENT DTR1	71
11.5.17	QUERY CONTENT DTR2	71
11.5.18	QUERY OPERATING MODE.....	71
11.5.19	QUERY LIGHT SOURCE TYPE	71
11.5.20	QUERY ACTUAL LEVEL.....	72
11.5.21	QUERY MAX LEVEL.....	72
11.5.22	QUERY MIN LEVEL.....	72
11.5.23	QUERY POWER ON LEVEL	72
11.5.24	QUERY SYSTEM FAILURE LEVEL	72
11.5.25	QUERY FADE TIME/FADE RATE.....	72
11.5.26	QUERY EXTENDED FADE TIME	72
11.5.27	QUERY MANUFACTURER SPECIFIC MODE	72
11.5.28	QUERY SCENE LEVEL (<i>sceneX</i>)	72
11.5.29	QUERY GROUPS 0-7	73
11.5.30	QUERY GROUPS 8-15	73
11.5.31	QUERY RANDOM ADDRESS (H).....	73
11.5.32	QUERY RANDOM ADDRESS (M)	73
11.5.33	QUERY RANDOM ADDRESS (L)	73
11.5.34	READ MEMORY LOCATION (<i>DTR1</i> , <i>DTR0</i>).....	73
11.6	Application extended commands	73
11.6.1	General.....	73
11.6.2	QUERY EXTENDED VERSION NUMBER.....	74
11.7	Special commands.....	74
11.7.1	General.....	74
11.7.2	TERMINATE.....	74
11.7.3	DTR0 (<i>data</i>).....	74
11.7.4	INITIALISE (<i>device</i>).....	74
11.7.5	RANDOMISE	75
11.7.6	COMPARE	75
11.7.7	WITHDRAW	75
11.7.8	SEARCHADDRH (<i>data</i>).....	75
11.7.9	SEARCHADDRM (<i>data</i>).....	76
11.7.10	SEARCHADDRL (<i>data</i>)	76
11.7.11	PROGRAM SHORT ADDRESS (<i>data</i>).....	76
11.7.12	VERIFY SHORT ADDRESS (<i>data</i>).....	76
11.7.13	QUERY SHORT ADDRESS.....	76
11.7.14	ENABLE DEVICE TYPE (<i>data</i>)	77
11.7.15	DTR1 (<i>data</i>).....	77
11.7.16	DTR2 (<i>data</i>).....	77

11.7.17	WRITE MEMORY LOCATION (<i>DTR1, DTR0, data</i>)	77
11.7.18	WRITE MEMORY LOCATION – NO REPLY (<i>DTR1, DTR0, data</i>).....	78
11.7.19	PING.....	78
<hr/>		
12 – Test procedures		
<hr/>		
Annex A (informative)	Examples of algorithms.....	79
A.1	Random address allocation.....	79
A.2	One single control gear connected to the control device.....	79
A.3	Using application extended commands.....	80
Annex B (normative)	High resolution dimmer.....	81
Bibliography.....		83
List of comments.....		84
Figure 1 – IEC 62386 graphical overview		11
Figure 2 – Control gear directly operating a light source		17
Figure 3 – Dimming curve.....		19
Figure 4 – Level over time, fading up and down		23
Figure 5 – Timing and response when executing command iteration		32
Figure 6 – Correlation between "lampFailure", "lampOn" and "fadeRunning" bits		49
Figure B.1 – Level behaviour in case of off-grid starting points		82
Table 1 – 16-bit command frame encoding.....		16
Table 2 – Dimming curve tolerance.....		20
Table 3 – Dimming curve.....		21
Table 4 – Fade times.....		25
Table 5 – Fade rates.....		25
Table 6 – Extended fade time – Base value.....		27
Table 7 – Extended fade time – Multiplier		27
Table 8 – Memory types		34
Table 9 – Basic memory map of memory banks.....		35
Table 10 – Memory map of memory bank 0.....		38
Table 11 – Memory map of memory bank 1		42
Table 12 – Power on timing		45
Table 13 – Control gear status.....		47
Table 14 – Scenes		52
Table 15 – Current bus unit configuration.....		53
Table 16 – Declaration of variables.....		53
Table 17 – Standard commands		56
Table 18 – Special commands		60
Table 19 – Light source type encoding.....		71
Table 20 – Device addressing with "INITIALISE (<i>device</i>)"		74

INTERNATIONAL ELECTROTECHNICAL COMMISSION

DIGITAL ADDRESSABLE LIGHTING INTERFACE –

Part 102: General requirements – Control gear

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This commented version (CMV) of the official standard IEC 62386-102:2022 edition 3.0 allows the user to identify the changes made to the previous IEC 62386-102:2014+AMD1:2018 CSV edition 2.1. Furthermore, comments from IEC TC 34 experts are provided to explain the reasons of the most relevant changes, or to clarify any part of the content.

A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text. Experts' comments are identified by a blue-background number. Mouse over a number to display a pop-up note with the comment.

This publication contains the CMV and the official standard. The full list of comments is available at the end of the CMV.

IEC 62386-102 has been prepared by IEC technical committee 34: Lighting. It is an International Standard.

This third edition cancels and replaces the second edition published in 2014 and Amendment 1:2018. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- the scope has been updated;
- references have been updated;
- memory bank reading of multi-byte values has been added;
- memory bank 0 and common memory bank requirements have been updated;
- reserved memory banks have been updated;
- non-volatile memory (NVM) save time has been added, and SAVE PERSISTENT VARIABLES removed;
- version number has been updated;
- bus unit configuration has been added.

The text of this International Standard is based on the following documents:

Draft	Report on voting
34/948/FDIS	34/989/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

This Part 102 of IEC 62386 is intended to be used in conjunction with Part 101, which contains general requirements for the relevant product type (system), and with the appropriate Part 2xx (particular requirements for control gear) containing clauses to supplement or modify the corresponding clauses in Part 101 and Part 102 in order to provide the relevant requirements for each type of product.

A list of all parts in the IEC 62386 series, published under the general title *Digital addressable lighting interface*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 62386-102:2022](#)

<https://standards.iteh.ai/catalog/standards/iec/2c8c9930-2808-4ee2-8ba2-0a79d065c56d/iec-62386-102-2022>

INTRODUCTION

IEC 62386 contains several parts, referred to as series. The IEC 62386 series specifies a bus system for control by digital signals of electronic lighting equipment. The IEC 62386-1xx series includes the basic specifications. Part 101 contains general requirements for system components, Part 102 extends this information with general requirements for control gear and Part 103 extends it further with general requirements for control devices. Part 104 and Part 105 can be applied to control gear or control devices. Part 104 gives requirements for wireless and alternative wired system components. Part 105 describes firmware transfer. Part 150 gives requirements for an auxiliary power supply which can be stand-alone, or built into control gear or control devices.

The IEC 62386-2xx series extends the general requirements for control gear with lamp specific extensions (mainly for backward compatibility with Edition 1 of IEC 62386) and with control gear specific features.

The IEC 62386-3xx series extends the general requirements for control devices with input device specific extensions describing the instance types as well as some common features that can be combined with multiple instance types.

This ~~second~~ third edition of IEC 62386-102 is intended to be used in conjunction with IEC 62386-101:~~2014~~ and IEC 62386-101:~~2014/AMD1:2018~~ and with the various parts that make up the IEC 62386-2xx series for control gear, and can be used together with IEC 62386-103:~~2014~~ and IEC 62386-103:~~2014/AMD1:2018~~ and the various parts that make up the ~~IEC 62386-3xx series of particular requirements~~ for control devices. The division into separately published parts provides for ease of future amendments and revisions. Additional requirements will be added as and when a need for them is recognised.

The setup of the standards is graphically represented in Figure 1 below.

[IEC 62386-102:2022](https://standards.iteh.ai/catalog/standards/iec/2c8c9930-2808-4ee2-8ba2-0a79d065c56d/iec-62386-102-2022)

<https://standards.iteh.ai/catalog/standards/iec/2c8c9930-2808-4ee2-8ba2-0a79d065c56d/iec-62386-102-2022>





Figure 1 – IEC 62386 graphical overview 1

When this part of IEC 62386 refers to any of the clauses of the other ~~two~~ parts of the IEC 62386-1xx series, the extent to which such a clause is applicable ~~and the order in which the tests are to be performed are~~ is specified. The other parts also include additional requirements, as necessary.

All numbers used in this document are decimal numbers unless otherwise noted. Hexadecimal numbers are given in the format 0xVV, where VV is the value. Binary numbers are given in the format XXXXXXXXb or in the format XXXX XXXX, where X is 0 or 1 and "x" in binary numbers means "don't care".

The following typographic expressions are used:

Variables: *variableName* or *variableName[3:0]*, giving only bits 3 to 0 of *variableName*;

Range of values: [lowest, highest];

Command: "COMMAND NAME".

DIGITAL ADDRESSABLE LIGHTING INTERFACE –

Part 102: General requirements – Control gear

1 Scope

This part of IEC 62386 is applicable to control gear ~~in a bus system~~ for control by digital signals of electronic lighting equipment ~~which is in line with the requirements of IEC 61347 (all parts), with the addition of DC supplies.~~

~~NOTE—Tests in this standard are type tests. Requirements for testing individual control gear during production are not included.~~

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 62386-101:~~2014~~2022, *Digital addressable lighting interface – Part 101: General requirements – System components*
~~IEC 62386-101:2014/AMD1:2018~~

IEC 62386-103:~~2014~~2022, *Digital addressable lighting interface – Part 103: General requirements – Control devices*
~~IEC 62386-103:2014/AMD1:2018~~

IEC 62386-2xx (all parts), *Digital addressable lighting interface – Part 2xx: Particular requirements for control gear*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 62386-101 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

actual level

value representing the current light output

3.2

arc power

power supplied to the light sources (lamps)

3.3

broadcast

type of address used to **simultaneously** address all control gear in the system ~~at once~~