

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

**Empty enclosures for low-voltage switchgear and controlgear assemblies –  
General requirements**

**Enveloppes vides destinées aux ensembles d'appareillage à basse tension –  
Exigences générales**

[IEC 62208:2023](https://standards.iteh.ai/catalog/standards/iec/59a6e991-064f-4019-9103-1f3dcbfd24a6/iec-62208-2023)

<https://standards.iteh.ai/catalog/standards/iec/59a6e991-064f-4019-9103-1f3dcbfd24a6/iec-62208-2023>



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2023 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

#### IEC publications search - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

#### IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [sales@iec.ch](mailto:sales@iec.ch).

#### IEC Products & Services Portal - [products.iec.ch](http://products.iec.ch)

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

### A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

#### Recherche de publications IEC -

##### [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

#### Service Clients - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: [sales@iec.ch](mailto:sales@iec.ch).

#### IEC Products & Services Portal - [products.iec.ch](http://products.iec.ch)

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

---

**Empty enclosures for low-voltage switchgear and controlgear assemblies –  
General requirements**

**Enveloppes vides destinées aux ensembles d'appareillage à basse tension –  
Exigences générales**

[IEC 62208:2023](https://standards.iteh.ai/standards/iec/59a6e991-064f-4019-9103-1f3dcbfd24a6/iec-62208-2023)

<https://standards.iteh.ai/catalog/standards/iec/59a6e991-064f-4019-9103-1f3dcbfd24a6/iec-62208-2023>

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

---

ICS 29.130.20

ISBN 978-2-8322-7071-4

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references .....	7
3 Terms and definitions .....	8
4 Classification.....	10
5 Electromagnetic compatibility (EMC) .....	11
6 Information to be given regarding the enclosure .....	11
6.1 General.....	11
6.2 Marking.....	11
6.3 Documentation.....	11
6.3.1 General .....	11
6.3.2 Dimensions.....	12
6.3.3 Mounting arrangements .....	12
6.3.4 Permissible loads .....	12
6.3.5 Lifting and transport support.....	12
6.3.6 Protective measures .....	12
6.3.7 Thermal power dissipation capability .....	13
7 Service conditions .....	13
7.1 General.....	13
7.2 Normal service conditions .....	13
7.3 Special service conditions.....	13
7.4 Conditions during transport and storage.....	14
8 Design and construction .....	14
8.1 General.....	14
8.2 Static loads .....	14
8.3 Lifting and transport support .....	14
8.4 Access to the interior of the enclosure .....	15
8.5 Protection against electric shock.....	15
8.5.1 General .....	15
8.5.2 Requirements for earth continuity within the class I enclosure .....	15
8.5.3 Requirements for class II enclosure .....	15
8.6 Protection against mechanical impact (IK code) .....	16
8.7 Protection against contact with live parts, ingress of solid foreign bodies and water (IP code) .....	16
8.8 Protection against corrosion.....	16
8.9 Enclosures constructed of or covered by insulating material .....	16
9 Type tests .....	16
9.1 General.....	16
9.2 General conditions of tests.....	16
9.3 Marking.....	17
9.4 Static loads.....	17
9.5 Lifting .....	18
9.6 Mechanical operation.....	18
9.7 Axial loads of metal inserts .....	18
9.8 Degree of protection against external mechanical impacts (IK code).....	19

9.9	Degree of protection (IP code) .....	20
9.9.1	Degree of protection against access to hazardous parts and against the ingress of solid foreign objects indicated by first characteristic numeral.....	20
9.9.2	Degree of protection against ingress of water as indicated by second characteristic numeral .....	20
9.9.3	Degree of protection against hazardous parts as indicated by additional letter .....	21
9.10	Properties of insulating materials .....	21
9.10.1	Thermal stability .....	21
9.10.2	Resistance to normal heat .....	21
9.10.3	Resistance to abnormal heat and fire due to internal electric effects .....	22
9.11	Dielectric strength.....	23
9.11.1	General .....	23
9.11.2	Preconditioning.....	23
9.11.3	Enclosures without metal elements inside the protected space .....	23
9.11.4	Enclosures having metal elements inside the protected space .....	24
9.11.5	Results to be obtained .....	24
9.12	Effective earth continuity between the exposed-conductive-parts of the class I enclosure and the protective circuit.....	24
9.13	Resistance to ultra-violet (UV) radiation .....	24
9.13.1	Verification by test.....	24
9.13.2	Verification by comparison to a reference design .....	25
9.14	Resistance to corrosion .....	26
9.14.1	General .....	26
9.14.2	Test procedure .....	26
9.14.3	Results to be obtained.....	27
9.15	Thermal power dissipation capability.....	27
9.15.1	General .....	27
9.15.2	Determination of the power dissipation capability by test .....	27
9.15.3	Determination of the power dissipation capability by calculation and comparison.....	28
9.15.4	Determination of the power dissipation capability by calculation method .....	28
Annex A (informative)	List of notes concerning certain countries.....	29
Bibliography.....		30
Table 1	– Climatic conditions .....	13
Table 2	– Number of samples to be tested and order of test per sample .....	17
Table 3	– Axial loads of metal inserts.....	19
Table 4	– Dielectric test voltage .....	24

# INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

## EMPTY ENCLOSURES FOR LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES – GENERAL REQUIREMENTS

### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62208 has been prepared by subcommittee 121B: Low-voltage switchgear and controlgear assemblies, of IEC technical committee 121: Switchgear and controlgear and their assemblies for low voltage. It is an International Standard.

This third edition cancels and replaces the second edition published in 2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) consideration of the modifications introduced in IEC 61439-1:2020;
- b) alignment of test procedures with the newest relevant standards.

The text of this International Standard is based on the following documents:

Draft	Report on voting
121B/180/FDIS	121B/180/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/publications](http://www.iec.ch/publications).

The reader's attention is drawn to the fact that Annex A lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh Standards  
(<http://standards.iteh.ai>)  
Document Preview

[IEC 62208:2023](#)

<https://standards.iteh.ai/catalog/standards/iec/59a6e991-064f-4019-9103-1f3dcbfd24a6/iec-62208-2023>

## INTRODUCTION

The purpose of this document is to harmonize as far as practicable all rules and requirements of a general nature applicable to empty enclosures for low-voltage switchgear and controlgear assemblies, in order to obtain uniformity of requirements and verification for empty enclosures and to avoid the need for verification in other standards.

**iTeh Standards**  
**(<https://standards.itih.ai>)**  
**Document Preview**

[IEC 62208:2023](#)

<https://standards.itih.ai/catalog/standards/iec/59a6e991-064f-4019-9103-1f3dcbfd24a6/iec-62208-2023>



# EMPTY ENCLOSURES FOR LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES – GENERAL REQUIREMENTS

## 1 Scope

This document applies to empty enclosures, as provided by the enclosure manufacturer, prior to the incorporation of switchgear and controlgear components by the assembly manufacturer.

This document specifies general definitions, classifications, characteristics and test requirements of enclosures to be used as part of switchgear and controlgear assemblies (e.g. in accordance with the product standard in the IEC 61439 series), the rated voltage of which does not exceed 1 000 V AC or 1 500 V DC, and suitable for general use for either indoor or outdoor applications.

NOTE 1 Additional requirements could apply for specific applications.

NOTE 2 Empty enclosures according to this document are suitable for mounting of electrical components.

This document does not apply to enclosures which are covered by other specific products standards (e.g. IEC 60670-24).

Compliance with the safety requirements of the applicable product standard for the final product produced using an empty enclosure is the responsibility of the assembly manufacturer.

NOTE 3 This document could serve as a basis for other technical committees.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-2:2007, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-11:2021, *Environmental testing – Part 2-11: Tests – Test Ka: Salt mist*

IEC 60068-2-30:2005, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60364 (all parts), *Low-voltage electrical installations*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 60529:1989/AMD1:1999

IEC 60529:1989/AMD2:2013

IEC 60695-2-10:2021, *Fire hazard testing – Part 2-10: Glowing/hot-wire based test methods – Glow-wire apparatus and common test procedure*

IEC 60695-2-11:2021, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test methods for end-products (GWEPT)*

IEC 60695-10-2:2014, *Fire hazard testing – Part 10-2: Abnormal heat – Ball pressure test method*

IEC 60695-11-5:2016; *Fire hazard testing – Part 11-5: Test flames – Needle-flame test method – Apparatus, confirmatory test arrangement and guidance*

IEC TR 60890:2014, *A method of temperature-rise verification of low-voltage switchgear and controlgear assemblies by calculation*

IEC 62262:2002, *Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)*  
IEC 62262:2002/AMD1:2021

ISO 178:2019, *Plastics – Determination of flexural properties*

ISO 179-1:2010, *Plastics – Determination of Charpy impact properties – Part 1: Non-instrumented impact test*

ISO 179-2:2020, *Plastics – Determination of Charpy impact properties – Part 2: Instrumented impact test*

ISO 2409:2020, *Paints and varnishes – Cross-cut test*

ISO 4628-3:2016, *Paints and varnishes – Evaluation of degradation of coatings – Designation of quantity and size of defects, and of intensity of uniform changes in appearance – Part 3: Assessment of degree of rusting*

ISO 4892-2:2013, *Plastics – Methods of exposure to laboratory light sources – Part 2: Xenon-arc lamps*

ISO 11469:2016, *Plastics – Generic identification and marking of plastic products*

<https://standards.iteh.ai/catalog/standards/iec/59a6e991-064f-4019-9103-1f3dcbfd24a6/iec-62208-2023>

### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

#### 3.1

##### **empty enclosure**

enclosure intended for support and installation of electrical equipment, whose internal space provides suitable protection against external influences as well as a specified degree of protection against approach to or contact with live parts and against contact with moving parts

Note 1 to entry: Throughout this document, the word enclosure is used for empty enclosure.

Note 2 to entry: For the purposes of this document, the terms boxes, cubicles, desks or cabinets are alternative terms for enclosures.

**3.2  
protected space**

internal space or portion of an enclosure as specified by the enclosure manufacturer intended to enclose electrical components, and which provides defined protection against external influences and contact with live parts

**3.3  
cover**

external part of the enclosure

**3.4  
door**

hinged or sliding cover

**3.5  
mounting plate**

separate internal accessory of the enclosure intended for the mounting of electrical components

**3.6  
cable gland plate**

removable accessory of the enclosure, intended for securing and sealing of cables, conductors and conduits at their point of entry

**3.7  
removable cover**

cover which is designed for closing an opening in the external enclosure and which can be removed for carrying out certain operations and maintenance work

Note 1 to entry: A lid is considered as a removable cover.

**3.8  
inspection**

action comprising careful scrutiny, including visual scrutiny where conditions are obvious, of an item carried out either without dismantling, or with the addition of partial dismantling as required, supplemented by means such as measurement, in order to arrive at a reliable conclusion as to the condition of an item

[SOURCE: IEC 60050-426:2020, 426-14-02, modified – "including visual scrutiny where conditions are obvious" has been added.]

**3.9  
rated insulation voltage**

$U_i$

value of the RMS withstand voltage assigned by the enclosure manufacturer to the enclosure or to a part of it, characterizing the specified (long-term) withstand capability of its insulation

[SOURCE: IEC 60050-312:2014, 312-06-02, modified – Symbol  $U_i$  has been added, in the definition "rated value" has been replaced by "value", "enclosure" has been added to manufacturer, "equipment" has been replaced by "enclosure" and the Note has been deleted.]

### 3.10

#### **class I enclosure**

enclosure with at least one provision for a basic protection and a connection to a protective conductor as provision for fault protection

Note 1 to entry: See IEC 61140:2016, 7.3 for further details.

[SOURCE: IEC 61439-1:2020, 3.7.24, modified – "assembly" has been replaced by "enclosure" and Note 2 to entry has been deleted.]

### 3.11

#### **class II enclosure**

enclosure which is provided with the following;

- basic insulation as provision for basic protection, and
  - supplementary insulation as provision for fault protection,
- or in which
- basic protection and fault protection are provided by reinforced insulation

Note 1 to entry: See IEC 61140:2016, 7.4 for further details.

[SOURCE: IEC 61439-1:2020, 3.7.25, modified – "assembly" has been replaced by "enclosure".]

### 3.12

#### **empty enclosure for indoor installation**

empty enclosure that is designed for use in locations where the normal service conditions for indoor use as specified in Clause 7 apply

### 3.13

#### **empty enclosure for outdoor installation**

empty enclosure that is designed for use in locations where the normal service conditions for outdoor use as specified in Clause 7 apply

## 4 Classification

Enclosures are classified according to:

- a) the type of material:
  - insulating;
  - metallic;
  - combination of insulating and metallic.
- b) method of mounting:
  - floor standing;
  - wall mounting;
  - flush mounting;
  - pole mounting.
- c) the intended location:
  - outdoor;
  - indoor.

d) the degree of protection:

- IP code, according to IEC 60529:1989 and IEC 60529:1989/AMD1:1999 and AMD2:2013;
- IK code, according to IEC 62262:2002 and IEC 62262:2002/AMD1:2021.

## 5 Electromagnetic compatibility (EMC)

EMC requirements are not applicable for enclosures according to this document.

NOTE EMC is not a basic requirement for empty enclosures to this document. However, when enclosure manufacturers want to assign a degree of protection against electromagnetic disturbances (EM code) it is referred to IEC 61000-5-7:2001.

## 6 Information to be given regarding the enclosure

### 6.1 General

The following information shall be given by the enclosure manufacturer.

### 6.2 Marking

The enclosure shall be identifiable, making it possible for the assembly manufacturer to obtain relevant information from the enclosure manufacturer. Such identification shall comprise:

- either the name, trade mark or identification mark of the enclosure manufacturer;
- type designation or identification number of the enclosure.

The marking shall be durable and easily legible and can be inside the enclosure.

Compliance is checked according to the test of 9.3 and by inspection.

Marking for the recycling of plastic parts shall be as stated in ISO 11469.

Marking of enclosures used for class II assemblies with the symbol IEC 60417-5172  (2003-02) is the responsibility of the assembly manufacturer.

### 6.3 Documentation

#### 6.3.1 General

The enclosure manufacturer's documentation shall include:

- the enclosure classification (see Clause 4);
- any instruction necessary for the correct handling, assembling, mounting and service conditions of the enclosure;
- a reference to this document, and
- the following characteristics:
  - dimensions (see 6.3.2);
  - mounting arrangements (6.3.3);
  - permissible loads (see 6.3.4);
  - lifting and transport devices, if necessary (see 6.3.5);
  - protective measures (see 6.3.6);
  - thermal power dissipation capability (see 6.3.7);
  - applicable service conditions (see Clause 7);

- location and size of protected space (see 3.2);
- rated insulation voltage  $U_i$  of enclosures constructed of an insulating material and Class II enclosures (see 9.11.3, Table 4);
- degree of protection against mechanical impact (IK code, see 8.6);
- degree of protection against contact with hazardous live parts, ingress of solid foreign bodies and water (IP code, see 8.7);
- maximum permissible temperatures inside for which enclosures constructed of insulating material is suitable (see 9.10.2).

### 6.3.2 Dimensions

The dimensions shall be given in millimetres.

The external dimensions (height, width and depth) are nominal values and shall be indicated in the catalogue of the enclosure manufacturer.

The projection of cable gland plates, removable covers and handles shall not be included in the external nominal dimensions, the dimensions of such shall be included in the enclosure manufacturer's documentation.

### 6.3.3 Mounting arrangements

The means and location of the enclosure mounting arrangements shall be defined in the enclosure manufacturer's documentation.

### 6.3.4 Permissible loads

The permissible loads that the enclosure, mounting plates, switchgear and controlgear supports and doors are able to carry shall be defined in the enclosure manufacturer's documentation. The load shall be given in Newtons.

If the enclosure includes or can include a mounting plate or switchgear and controlgear supports, the permissible load that the accessory can carry, according to the fixing means provided inside the enclosure, shall be defined in the enclosure manufacturer's documentation. (see also 8.2).

### 6.3.5 Lifting and transport support

Where required, the correct location and installation of lifting and transport support and the thread size of lifting devices shall be given in the enclosure manufacturer's documentation or in the instructions on how the enclosure has to be handled (see also 8.3).

### 6.3.6 Protective measures

The enclosure manufacturer shall indicate in the technical documentation if the enclosure is suitable for a class I or class II assembly.

In the case of a class I enclosure, the enclosure manufacturer shall indicate if the enclosure ensures electrical continuity throughout by the conductive structural parts of the enclosure or if and how separate protective conductors to the protective circuits of the installation shall be carried out (see also 8.5).