

INTERNATIONAL STANDARD

**Residual current operated circuit-breakers with integral overcurrent protection
for household and similar uses (RCBOs) –
Part 2-1: RCBOs according to classification 4.1.1**

Document Preview

[IEC 61009-2-1:2024](#)

<https://standards.iteh.ai/catalog/standards/iec/0044e268-ebc8-4201-9f8a-f7b9b42d6382/iec-61009-2-1-2024>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2024 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

International
Standards
Document Preview
standards.iteh.ai

[IEC 61009-2-1:2024](https://standards.iteh.ai/catalog/standards/iec/0044e268-ebc8-4201-9f8a-f7b9b42d6382/iec-61009-2-1-2024)

<https://standards.iteh.ai/catalog/standards/iec/0044e268-ebc8-4201-9f8a-f7b9b42d6382/iec-61009-2-1-2024>



INTERNATIONAL STANDARD

**Residual current operated circuit-breakers with integral overcurrent protection
for household and similar uses (RCBOs) –
Part 2-1: RCBOs according to classification 4.1.1**

Document Preview

[IEC 61009-2-1:2024](https://standards.iteh.ai/catalog/standards/iec/0044e268-ebc8-4201-9f8a-f7b9b42d6382/iec-61009-2-1-2024)

<https://standards.iteh.ai/catalog/standards/iec/0044e268-ebc8-4201-9f8a-f7b9b42d6382/iec-61009-2-1-2024>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.120.50

ISBN 978-2-8327-0012-9

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	3
1 Scope.....	5
2 Normative references	5
3 Terms and definitions	5
4 Classification.....	6
4.1 According to the supply conditions.....	6
5 Characteristics of RCBOs.....	6
6 Marking and other product information.....	6
7 Standard conditions for operation in service and for installation.....	6
8 Requirements for construction and operation.....	6
9 Tests	6
9.1 General.....	6
Annex A (normative) Test sequence and number of samples to be submitted for certification purposes.....	15
A.1 Test sequences	15
A.2 Number of samples to be submitted for full test procedure.....	16
A.3 Number of samples to be submitted for simplified test procedures if submitting simultaneously a range of RCBOs of the same fundamental design.....	17
Annex D (normative) Routine tests.....	21
D.3 Dielectric strength test.....	21
Bibliography.....	22
Figure 2 – Test circuit for the verification of operating characteristics and trip-free mechanism for RCBOs classified according to 4.1.1.....	12
Figure 3 – Test circuit for the verification of the correct operation in case of residual pulsating direct currents for RCBOs classified according to 4.1.1.....	13
Figure 4 – Test circuit for the verification of the correct operation in case of residual pulsating direct currents in the presence of a standing smooth direct current of 0,006 A for RCBOs classified according to 4.1.1.....	14
Table A.1 – Test sequences.....	15
Table A.2 – Number of samples for full test procedure	17
Table A.3 – Number of samples for simplified test procedure	18
Table A.4 – Test sequences for RCBOs having different instantaneous tripping currents	20
Table A.5 – Test sequences for RCBOs of different classification according to IEC 61009-1:2024, 4.3.....	20

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**RESIDUAL CURRENT OPERATED CIRCUIT-BREAKERS
WITH INTEGRAL OVERCURRENT PROTECTION
FOR HOUSEHOLD AND SIMILAR USES (RCBOs) –****Part 2-1: RCBOs according to classification 4.1.1**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61009-2-1 has been prepared by subcommittee 23E: Circuit-breakers and similar equipment for household use, of IEC technical committee 23: Electrical accessories. It is an International Standard.

This second edition cancels and replaces the first edition published in 1991. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) harmonization of all clauses between the IEC 61008, IEC 61009 and IEC 60755 series using blocks and modules approach;

- b) harmonization of all tables and figures between the IEC 61008, IEC 61009 and IEC 60755 series;
- c) terms and definitions are now referred to IEC 62873-2;
- d) modification of Subclause 4.1 for classification according to supply conditions;
- e) specific tests for operating characteristics (9.9) of RCBO according to classification 4.1.1;
- f) specific test conditions for temperature-rise (9.8), verification of trip-free (9.15), surge current tests (9.19), reliability (9.20) and ageing (9.21).

The text of this International Standard is based on the following documents:

Draft	Report on voting
23E/1371/FDIS	23E/1389/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This International Standard is to be used in conjunction with IEC 61009-1:2024.

Where this document states "addition", "deletion" or "replacement", the corresponding requirement, test specification or explanatory material in IEC 61009-1:2024 is adapted accordingly.

Where this document defines a new subclause, this subclause number starts at 100 (for example an additional definition in this document would read 3.100).

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 61009 series, published under the general title *Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

RESIDUAL CURRENT OPERATED CIRCUIT-BREAKERS WITH INTEGRAL OVERCURRENT PROTECTION FOR HOUSEHOLD AND SIMILAR USES (RCBOs) –

Part 2-1: RCBOs according to classification 4.1.1

1 Scope

IEC 61009-1:2024, Clause 1 is applicable except for the first paragraph and the last paragraph, which are replaced by the following, respectively:

This document applies to residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (hereafter referred to as RCBOs), classified according to IEC 61009-1:2024, 4.1.1. RCBOs according to this document are intended for voltages not exceeding 440 V AC with frequencies of 50 Hz, 60 Hz or 50/60 Hz and currents not exceeding 125 A and rated short-circuit capacities not exceeding 25 000 A for operation at 50 Hz or 60 Hz.

This document applies in conjunction with IEC 61009-1:2024. It specifies requirements, tests and test sequences to verify compliance and is used for certification purposes.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

<https://standards.iteh.ai/> IEC 61009-1:2024, *Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs) – Part 1: General rules*

IEC 61543:2022, *Residual current-operated protective devices (RCDs) for household and similar use – Electromagnetic compatibility*

IEC 62873-2, *Residual current operated circuit-breakers for household and similar use – Part 2: Residual current devices (RCDs) – Vocabulary*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 62873-2 and in IEC 61009-1 apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

4 Classification

IEC 61009-1:2024, Clause 4 applies with the following modifications (deletion of 4.1.2, 4.1.3, 4.1.4, 4.1.5, and 4.1.6):

4.1 According to the supply conditions

4.1.1 RCBO operating correctly on the occurrence of residual current

- within the voltage range $1,1 U_e$ and zero volt; and
- with any number of supply conductors connected.

The RCBO does not open automatically in the event of loss of supply.

5 Characteristics of RCBOs

IEC 61009-1:2024, Clause 5 applies.

6 Marking and other product information

IEC 61009-1:2024, Clause 6 applies.

7 Standard conditions for operation in service and for installation

IEC 61009-1:2024, Clause 7 applies.

8 Requirements for construction and operation

IEC 61009-1:2024, Clause 8 applies. [IEC 61009-2-1:2024](https://standards.iteh.ai/catalog/standards/iec/0044e268-ebc8-4201-9f8a-f7b9b42d6382/iec-61009-2-1-2024)

<https://standards.iteh.ai/catalog/standards/iec/0044e268-ebc8-4201-9f8a-f7b9b42d6382/iec-61009-2-1-2024>

9 Tests

IEC 61009-1:2024, Clause 9 applies with following modifications.

9.1 General

IEC 61009-1:2024, 9.1 applies with the following modification:

Replace the third paragraph with:

The test sequences and the number of samples to be submitted are stated in Annex A.

9.8 Test of temperature-rise

9.8.2 Test procedure

IEC 61009-1:2024, 9.8.2 applies with the following addition:

The test is performed at any convenient voltage.

9.9 Verification of the operating characteristics

9.9.1 Verification of the operating characteristics under residual current conditions

9.9.1.1 Test circuit and test procedure

The RCBO is installed as for normal use.

The test circuit shall be of negligible inductance. For tests according to 9.9.1.2, the test circuit shall correspond to Figure 2. For tests according to 9.9.1.3, the test circuit shall correspond to Figure 3 or Figure 4, as applicable.

The instruments for the measurement of the residual current shall display (or allow to determine) the true RMS value.

Unless otherwise specified in this document, the tests are performed with no load at the ambient air temperature of $20\text{ °C} \pm 5\text{ °C}$.

The RCBO shall perform the tests of 9.9.1.2 and 9.9.1.3, as applicable.

Each test is performed by applying the residual current to one pole only, taken at random, with five measurements, unless otherwise specified in this document. The other poles shall not be connected to the supply, unless otherwise specified in this document.

For RCBOs having more than one rated frequency, the tests shall be carried out at the lowest and highest frequency, except for the test in 9.9.1.2.5 where verification is performed at one frequency only.

For RCBOs having multiple settings of residual operating current, the tests shall be carried out for each setting.

9.9.1.2 Tests for all RCBOs

IEC 61009-2-1:2024

9.9.1.2.1 Verification of correct operation in the case of a steady increase of the residual current

The switch S_1 and the RCBO being in the closed position, the residual current is steadily increased, starting from a value not higher than $0,2 I_{\Delta n}$, trying to attain the value of $I_{\Delta n}$ within 30 s. The test shall be performed five times, the tripping current being measured each time.

All five measured values shall be situated between $I_{\Delta n0}$ and $I_{\Delta n}$.

9.9.1.2.2 Verification of correct operation on closing on a residual current

The test circuit being calibrated at the value of the rated residual operating current $I_{\Delta n}$ and the switch S_1 being closed, the RCBO is closed to simulate service conditions as closely as possible.

The break time is measured five times. No measurement shall exceed the limiting value specified for $I_{\Delta n}$ in IEC 61009-1:2024, Table 11, according to the type of RCBO.

9.9.1.2.3 Verification of correct operation in the case of sudden appearance of residual current

1) All types

The test circuit being successively calibrated at each of the values of residual current specified in IEC 61009-1:2024, Table 11, the RCBO being in the closed position, the test current is suddenly established by closing the switch S_1 .

The RCBO shall trip during each test.

Five measurements of the break time are carried out at each value of residual current.

No value shall exceed the relevant specified limiting value given in IEC 61009-1:2024, Table 11.

2) Additional test for type S

The test circuit being successively calibrated at each of the values of residual current specified in IEC 61009-1:2024, Table 11, the RCBO being in the closed position, the residual current is suddenly established by closing the switch S_1 for periods corresponding to the relevant minimum non-actuating times, with a tolerance of $_{-5}^0$ %.

Each application of residual current shall be separated from the previous one by an interval of at least 1 min.

The RCBO shall not trip during any of the tests.

9.9.1.2.4 Verification of correct operation in the case of sudden appearance of residual currents between $5 I_{\Delta n}$ and 500 A

The test circuit is calibrated successively to the following values of the residual current:

5 A, 10 A, 20 A, 50 A, 100 A and 200 A.

The RCBO being in the closed position, the residual current is suddenly established by closing the switch S_1 .

[IEC 61009-2-1:2024](https://standards.iteh.ai/catalog/standards/iec/0044e268-ebc8-4201-9f8a-f7b9b42d6382/iec-61009-2-1-2024)

The RCBO shall trip during each test. The break time shall not exceed the times given in IEC 61009-1:2024, Table 11.

The test is carried out once for each value of residual current on one pole only, taken at random.

9.9.1.2.5 Verification of correct operation with load

The tests of 9.9.1.2.2 and 9.9.1.2.3 are repeated, the pole under test and one other pole of the RCBO being loaded with rated current, at any convenient voltage.

This test is not intended to reach thermal steady-state conditions.

NOTE The loading with rated current is not shown in Figure 2.