

INTERNATIONAL STANDARD

**Electric cables – Calculation of the current rating –
Part 1-1: Current rating equations (100 % load factor) and calculation of losses –
General**

Document Preview

[IEC 60287-1-1:2023](https://standards.iteh.ai/catalog/standards/iec/164f72dc-b67a-496b-af43-97e28a944a7b/iec-60287-1-1-2023)

<https://standards.iteh.ai/catalog/standards/iec/164f72dc-b67a-496b-af43-97e28a944a7b/iec-60287-1-1-2023>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2023 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

International
Standards.iteh.ai)
Document Preview

[IEC 60287-1-1-2023](https://standards.iteh.ai/catalog/standards/iec/164f72dc-b67a-496b-af43-97e28a944a7b/iec-60287-1-1-2023)

<https://standards.iteh.ai/catalog/standards/iec/164f72dc-b67a-496b-af43-97e28a944a7b/iec-60287-1-1-2023>



INTERNATIONAL STANDARD

**Electric cables – Calculation of the current rating –
Part 1-1: Current rating equations (100 % load factor) and calculation of losses –
General**

Document Preview

[IEC 60287-1-1:2023](https://standards.iteh.ai/catalog/standards/iec/164f72dc-b67a-496b-af43-97e28a944a7b/iec-60287-1-1-2023)

<https://standards.iteh.ai/catalog/standards/iec/164f72dc-b67a-496b-af43-97e28a944a7b/iec-60287-1-1-2023>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.060.20

ISBN 978-2-8322-6937-4

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms, definitions and symbols.....	8
3.1 Terms and definitions.....	8
3.2 Symbols.....	8
4 Permissible current rating of cables.....	12
4.1 General.....	12
4.2 Buried cables where drying out of the soil does not occur or cables in air	12
4.2.1 AC cables.....	12
4.2.2 DC cables up to 5 kV.....	13
4.3 Buried cables where partial drying-out of the soil occurs.....	13
4.3.1 AC cables.....	13
4.3.2 DC cables up to 5 kV.....	14
4.4 Buried cables where drying-out of the soil shall be avoided	14
4.4.1 AC cables.....	14
4.4.2 DC cables up to 5 kV.....	15
4.5 Cables directly exposed to solar radiation.....	15
4.5.1 General.....	15
4.5.2 AC cables.....	15
5 Calculation of losses	16
5.1 AC resistance of conductor.....	16
5.1.1 General	16
5.1.2 DC resistance of conductor.....	16
5.1.3 Skin effect factor y_s	16
5.1.4 Proximity effect factor y_p for two-core cables and for two single-core cables.....	17
5.1.5 Proximity effect factor y_p for three-core cables and for three single-core cables.....	17
5.1.6 Skin and proximity effects in pipe-type cables.....	18
5.2 Dielectric losses (applicable to AC cables only)	18
5.3 Loss factor for sheath and screen (applicable to power frequency AC cables only)	19
5.3.1 General	19
5.3.2 Two single-core cables, and three single-core cables (in trefoil formation), sheaths bonded at both ends of an electrical section	20
5.3.3 Three single-core cables in flat formation, with regular transposition, sheaths bonded at both ends of an electrical section	21
5.3.4 Three single-core cables in flat formation, without transposition, sheaths bonded at both ends of an electrical section	21
5.3.5 Variation of spacing of single-core cables between sheath bonding points	22
5.3.6 Effect of Milliken conductors	23
5.3.7 Single-core cables, with sheaths bonded at a single point or cross- bonded	23
5.3.8 Two-core unarmoured cables with common sheath.....	26

5.3.9	Three-core unarmoured cables with common sheath	26
5.3.10	Two-core and three-core cables with steel tape armour	27
5.3.11	Cables with each core in a separate metallic sheath (SL type) and armoured	28
5.3.12	Losses in screen and sheaths of pipe-type cables	28
5.4	Loss factor for armour, reinforcement and steel pipes (applicable to power frequency AC cables only)	29
5.4.1	General	29
5.4.2	Non-magnetic armour or reinforcement	29
5.4.3	Magnetic armour or reinforcement	30
5.4.4	Losses in steel pipes	34
Annex A (normative) Correction factor for increased lengths of individual cores within multicore cables		38
Bibliography		39
Table 1 – Electrical resistivities and temperature coefficients of metals used		35
Table 2 – Skin and proximity effects – Experimental values for the coefficients k_s and k_p		36
Table 3 – Values of relative permittivity and loss factors for the insulation of high- voltage and medium-voltage cables at power frequency		37
Table 4 – Absorption coefficient of solar radiation for cable surfaces		37
Table A.1 – Values of factor C_{fL} for different numbers of cores		38

Document Preview

[IEC 60287-1-1:2023](https://standards.iteh.ai)

<https://standards.iteh.ai/catalog/standards/iec/164f72dc-b67a-496b-af43-97e28a944a7b/iec-60287-1-1-2023>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRIC CABLES –
CALCULATION OF THE CURRENT RATING –****Part 1-1: Current rating equations (100 % load factor)
and calculation of losses – General**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60287-1-1 has been prepared by IEC technical committee 20: Electric cables. It is an International Standard.

This third edition cancels and replaces the second edition published in 2006 and Amendment 1:2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) thorough redefinition of symbols used across the IEC 60287 and IEC 60853 series to realign and unify definitions, eliminate inconsistencies and to improve cross-use of the different parts of both IEC 60287 and IEC 60853 series;
- b) introduction of corrective factors on relevant calculated physical characteristics to take into account the effect of multicore lay-lengths; a dedicated annex to highlight correction factors for different number of cores has been introduced (Annex A).

The text of this International Standard is based on the following documents:

Draft	Report on voting
20/2096/FDIS	20/2103/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 60287 series, published under the general title *Electric cables – Calculation of the current rating*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh Standards
(<https://standards.itih.ai>)
Document Preview

[IEC 60287-1-1:2023](https://standards.itih.ai/catalog/standards/iec/164f72dc-b67a-496b-af43-97e28a944a7b/iec-60287-1-1-2023)

<https://standards.itih.ai/catalog/standards/iec/164f72dc-b67a-496b-af43-97e28a944a7b/iec-60287-1-1-2023>

INTRODUCTION

This part of IEC 60287 contains formulae for the quantities R_C , W_d , λ_1 and λ_2 .

It contains methods for calculating the permissible current rating of cables from details of the permissible temperature rise, conductor resistance, losses and thermal resistivities.

Formulae for the calculation of losses are also given.

The formulae in this document contain quantities which vary with cable design and materials used. The values given in the tables are either internationally agreed, for example, electrical resistivities and resistance temperature coefficients, or are those which are generally accepted in practice, for example, thermal resistivities and permittivities of materials. In this latter category, some of the values given are not characteristic of the quality of new cables but are considered to apply to cables after a long period of use. In order that uniform and comparable results can be obtained, the current ratings should be calculated with the values given in this document. However, where it is known with certainty that other values are more appropriate to the materials and design, then these may be used, and the corresponding current rating declared in addition, provided that the different values are quoted.

Quantities related to the operating conditions of cables are liable to vary considerably from one country to another. For instance, with respect to the ambient temperature and soil thermal resistivity, the values are governed in various countries by different considerations. Superficial comparisons between the values used in the various countries can lead to erroneous conclusions if they are not based on common criteria: for example, there can be different expectations for the life of the cables, and in some countries design is based on maximum values of soil thermal resistivity, whereas in others average values are used. Particularly, in the case of soil thermal resistivity, it is well known that this quantity is very sensitive to soil moisture content and can vary significantly with time, depending on the soil type, the topographical and meteorological conditions, and the cable loading.

The following procedure for choosing the values for the various parameters should, therefore, be adopted:

Numerical values should preferably be based on results of suitable measurements. Often such results are already included in national specifications as recommended values, so that the calculation can be based on these values generally used in the country in question; a survey of such values is given in IEC 60287-3-1.

A suggested list of the information required to select the appropriate type of cable is given in IEC 60287-3-1.

ELECTRIC CABLES – CALCULATION OF THE CURRENT RATING –

Part 1-1: Current rating equations (100 % load factor) and calculation of losses – General

1 Scope

This part of IEC 60287 is applicable to the conditions of steady-state operation of cables at all alternating voltages, and direct voltages up to 5 kV, buried directly in the ground, in ducts, troughs or in steel pipes, both with and without partial drying-out of the soil, as well as cables in air. The term "steady state" is intended to mean a continuous constant current (100 % load factor) just sufficient to produce asymptotically the maximum conductor temperature, the surrounding ambient conditions being assumed constant.

This document provides formulae for current ratings and losses.

The formulae given are essentially literal and designedly leave open the selection of certain important parameters. These can be divided into three groups:

- parameters related to construction of a cable (for example, thermal resistivity of insulating material) for which representative values have been selected based on published work;
- parameters related to the surrounding conditions, which can vary widely, the selection of which depends on the country in which the cables are used or will be used;
- parameters which result from an agreement between manufacturer and user and which involve a margin for security of service (for example, maximum conductor temperature).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60228, *Conductors of insulated cables*

IEC 60287-1-3, *Electric cables – Calculation of the current rating – Part 1-3: Current rating equations (100 % load factor) and calculation of losses – Current sharing between parallel single-core cables and calculation of circulating current losses*

IEC 60287-2-1:2023, *Electric cables – Calculation of the current rating – Part 2-1: Thermal resistance – Calculation of the thermal resistance*

3 Terms, definitions and symbols

3.1 Terms and definitions

No terms and definitions are listed in this document.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.2 Symbols

The symbols used in this document and the quantities which they represent are given in the following list.

A_A	cross-sectional area of the armour	mm^2
B_1, B_2	coefficients (see 5.4.3)	Ω/m
C	capacitance per core	F/m
C_F	coefficient defined in 5.3.6	
C_{fL}	coefficient to take into account the position of the neutral axis of the helically wound core in Annex A	
C_{gs}	coefficient used in 5.3.7.1	
C_{LL}	length correction factor for considering laying up of cores	
C_{M1}	coefficient defined in 5.3.6	
C_N	coefficient defined in 5.3.6	
C_P	coefficient defined in 5.3.4	Ω/m
C_p	coefficient used in 5.3.7.2	
C_Q	coefficient defined in 5.3.4	Ω/m
C_q	coefficient used in 5.3.7.2	
D_e^*	external diameter of cable	m
D_i	diameter over insulation	mm
D_p^*	diameter over the individual core of a multicore cable	m
D_s	external diameter of metal sheath	mm
D_{oc}	diameter of the imaginary coaxial cylinder which just touches the crests of a corrugated sheath	mm
D_{it}	diameter of the imaginary cylinder which just touches the inside surface of the troughs of a corrugated sheath	mm
E_e	intensity of solar radiation	W/m^2
H	magnetizing force (see 5.4.3)	A/m
H_s	inductance of sheath	H/m
H_1, H_2, H_3	components of inductance due to the steel wires (see 5.4.3)	H/m
I	current in one conductor (RMS value)	A
I_S	current in sheath (RMS value)	A
L_L^*	axial cable length over which the cores make one full helical turn	m

R_C	alternating current resistance of conductor at its maximum operating temperature per unit length of the cable	Ω/m
R_A	AC resistance of armour at its maximum operating temperature per unit length of the cable	Ω/m
R_{Ao}	AC resistance of armour at 20 °C per unit length of the cable	Ω/m
R_e	equivalent AC resistance of sheath and armour in parallel	Ω/m
R_s	AC resistance of cable sheath or screen at their maximum operating temperature per unit length of the cable	Ω/m
R_{so}	AC resistance of cable sheath or screen at 20 °C per unit length of the cable	Ω/m
R'	DC resistance of conductor at maximum operating temperature per unit length of the cable	Ω/m
R_o	DC resistance of conductor at 20 °C per unit length of the cable	Ω/m
T_1	thermal resistance per core between conductor and sheath per unit length of the cable	$\text{K} \cdot \text{m}/\text{W}$
T_2	thermal resistance between sheath and armour per unit length of the cable	$\text{K} \cdot \text{m}/\text{W}$
T_3	thermal resistance of external serving per unit length of the cable	$\text{K} \cdot \text{m}/\text{W}$
T_4	thermal resistance of surrounding medium (ratio of cable surface temperature rise above ambient to the losses per unit length)	$\text{K} \cdot \text{m}/\text{W}$
$T_4^\#$	thermal resistance in free air, adjusted for solar radiation	$\text{K} \cdot \text{m}/\text{W}$
T_4'	thermal resistance between cable and duct (or pipe)	$\text{K} \cdot \text{m}/\text{W}$
T_4''	thermal resistance of the duct (or pipe)	$\text{K} \cdot \text{m}/\text{W}$
T_4'''	thermal resistance of the medium surrounding the duct (or pipe)	$\text{K} \cdot \text{m}/\text{W}$
U_o	voltage between conductor and screen or sheath	V
W_A	losses in armour per unit length of the cable	W/m
W_C	losses in conductor per unit length of the cable	W/m
W_d	dielectric losses per unit length of the cable per phase	W/m
W_s	losses dissipated in sheath per unit length of the cable	W/m
$W_{(s+A)}$	total losses in sheath and armour per unit length of the cable	W/m
X	reactance of sheath (two-core cables and three-core cables in trefoil) per unit length of the cable	Ω/m
X_1	reactance of sheath (cables in flat formation)	Ω/m
X_m	mutual reactance between the sheath of one cable and the conductors of the other two when cables are in flat information	Ω/m
a	shortest minor length in a cross-bonded electrical section having unequal minor lengths	m
c	distance between the axes of conductors and the axis of the cable for three-core cables	mm
d	mean diameter of sheath or screen	mm
d'	mean diameter of sheath and reinforcement	mm

d_2	mean diameter of reinforcement	mm
d_A	mean diameter of armour	mm
d_c	external diameter of conductor	mm
d'_c	external diameter of equivalent round solid conductor having the same central duct as a hollow conductor	mm
d_d	internal diameter of pipe	mm
d_f	diameter of a steel wire	mm
d_i	internal diameter of hollow conductor	mm
d_M	major diameter of screen or sheath of an oval conductor	mm
d_m	minor diameter of screen or sheath of an oval conductor	mm
d_x	diameter of an equivalent circular conductor having the same cross-sectional area and degree of compactness as the shaped one	mm
f	system frequency	Hz
k_f	factor used in the calculation of hysteresis losses in armour or reinforcement (see 5.4.3.4)	
k_p	factor used in calculating x_p (proximity effect)	
k_s	factor used in calculating x_s (skin effect)	
l^*	length of a cable section (general symbol, see 5.3.5)	m
\ln	natural logarithm (logarithm to base e, see IEC 60027-3)	
m	parameter used in calculation of eddy-current loss factor	10^{-7} m/ Ω
n	number of conductors in a cable	
n_1	number of steel wires in a cable (see 5.4.3)	
p	length of lay of a steel wire along a cable (see 5.4.3)	
r_1	circumscribing radius of two- or three-sector shaped conductors	mm
s	axial separation of conductors	mm
s_1	axial separation of two adjacent cables in a horizontal group of three, not touching	mm
s_2	axial spacing between adjacent cables in trefoil formation; for cables in flat formation s_2 is the geometric mean of the three spacings	mm
t_0	insulation thickness between conductors	mm
t_3	thickness of the serving	mm
t_s	thickness of the sheath	mm
ν	ratio of the thermal resistivities of dry and moist soils ($\nu = \rho_d/\rho_w$)	
x_p	argument of a Bessel function used to calculate proximity effect	
x_s	argument of a Bessel function used to calculate skin effect	
y_p	proximity effect factor (see 5.1)	
y_s	skin effect factor (see 5.1)	