

INTERNATIONAL STANDARD



High-voltage switchgear and controlgear –
Part 214: Internal arc classification for AC metal-enclosed pole-mounted
switchgear and controlgear for rated voltages above 1 kV and up to and
including 52 kV

Document Preview

[IEC 62271-214:2024](#)

<https://standards.iteh.ai/catalog/standards/iec/57bfe5f0-208c-482b-8d75-6dbf67803947/iec-62271-214-2024>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2024 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

International Standards
standards.iteh.ai
Document Preview

[IEC 62271-214:2024](https://standards.iteh.ai/catalog/standards/iec/57bfe5f0-208c-482b-8d75-6dbf67803947/iec-62271-214-2024)

<https://standards.iteh.ai/catalog/standards/iec/57bfe5f0-208c-482b-8d75-6dbf67803947/iec-62271-214-2024>



IEC 62271-214

Edition 2.0 2024-04
COMMENTED VERSION

INTERNATIONAL STANDARD



**High-voltage switchgear and controlgear –
Part 214: Internal arc classification for AC metal-enclosed pole-mounted
switchgear and controlgear for rated voltages above 1 kV and up to and
including 52 kV**

Document Preview

[IEC 62271-214:2024](https://standards.iteh.ai/catalog/standards/iec/57bfe5f0-208c-482b-8d75-6dbf67803947/iec-62271-214-2024)

<https://standards.iteh.ai/catalog/standards/iec/57bfe5f0-208c-482b-8d75-6dbf67803947/iec-62271-214-2024>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.130.10

ISBN 978-2-8322-8792-7

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	4
INTRODUCTION	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	8
3.1 General terms and definitions	8
3.8 Index of definitions	10
4 Normal and special service conditions	11
5 Ratings	11
5.1 General	11
5.2 Rated voltage (U_r)	11
5.2.1 General	11
5.3 Rated insulation level (U_d , U_p , U_s)	12
5.4 Rated frequency (f_r)	12
5.101 Ratings of the internal arc classification (IAC)	12
5.101.1 General	12
5.101.2 Rated approach distance (D_{AP})	12
5.101.3 Rated arc fault currents (I_A , I_{Ae})	12
5.101.4 Rated arc fault duration (t_A , t_{Ae})	12
6 Design and construction	13
6.11 Nameplate	13
6.11.2 Application	13
6.101 Internal arc fault	13
6.102 Enclosure	14
7 Type tests	15
7.1 General	15
7.1.1 Basics	15
7.1.2 Information for identification of test object	16
7.1.3 Information to be included in type-test reports	16
7.101 Internal arc type test	17
7.101.1 General	17
7.101.2 Test conditions	17
7.101.3 Arrangement of the equipment	18
7.101.4 Indicators (for assessing the thermal effects of the gases)	21
7.101.5 Arrangement of indicators	21
7.101.6 Test parameters	22
7.101.7 Test procedure	23
7.101.8 Criteria to pass the test	29
7.101.9 Transferability of the test results	30
8 Routine tests	30
9 Guide to the selection of switchgear and controlgear (informative)	30
9.1 General	30
9.101 Internal arc fault	30
9.101.1 General	30
9.101.2 Causes and preventive measures	31

9.101.3	Supplementary protective measures.....	32
9.101.4	Considerations for the selection and installation	32
9.101.5	Internal arc test.....	32
9.101.6	IAC designation.....	33
10	Information to be given with enquiries, tenders and orders (informative)	33
10.1	General.....	33
11	Transport, storage, installation, operation instruction and maintenance.....	34
11.1	General.....	34
11.2	Conditions during transport, storage and installation.....	34
11.3	Installation	34
11.3.1	General.....	34
11.101	Maintenance.....	34
12	Safety.....	34
12.1	General.....	34
13	Influence of the product on the environment.....	34
Annex A	(normative) Identification of the test objects	36
A.1	General.....	36
A.2	Data.....	36
A.3	Drawings.....	36
Bibliography	37
List of comments	39
Figure 1	– Examples of enclosures and compartment(s) in different arrangements	15
Figure 2	– Test arrangement for pole-mounted switchgear	20
Figure 3	– Horizontal indicator.....	21
Figure 4	– Flow-chart for the choice of arc initiation depending on the construction	27
Table 1	– Nameplate information	13
Table 2	– Parameters for internal arc fault test according to enclosure and compartment construction	25
Table 3	– Locations, causes and examples of measures to decrease the probability of internal arc faults	31
Table 4	– Single-phase-to-earth arc fault current depending on the network neutral earthing	33

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 214: Internal arc classification for AC metal-enclosed pole-mounted switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This commented version (CMV) of the official standard IEC 62271-214:2024 edition 2.0 allows the user to identify the changes made to the previous IEC 62271-214:2019 edition 1.0. Furthermore, comments from IEC TC SC 17C experts are provided to explain the reasons of the most relevant changes, or to clarify any part of the content.

A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text. Experts' comments are identified by a blue-background number. Mouse over a number to display a pop-up note with the comment.

This publication contains the CMV and the official standard. The full list of comments is available at the end of the CMV.

IEC 62271-214 has been prepared by subcommittee 17C: Assemblies, of IEC technical committee 17: High voltage switchgear and controlgear. It is an International Standard.

This second edition cancels and replaces the first edition published in 2019. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) indicators positioning update;
- b) neutral earthing connection of the test circuit for three-phase tests;
- c) general review for consistency with IEC 62271-200, Ed.3.0:2021.

The text of this International Standard is based on the following documents:

Draft	Report on voting
17C/924/FDIS	17C/931/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This standard shall be read in conjunction with IEC 62271-1, second edition, published in 2017, to which it refers, and which is applicable unless otherwise specified in this standard. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC 62271-1. Amendments to these clauses and subclauses are given under the same references whilst additional subclauses are numbered from 101. Any clause with the term "Not applicable" relates to the clause not being relevant to IEC 62271-214, and does not infer the clause is or is not relevant for its applicable switchgear standard.

A list of all parts of the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC 62271-214 has been developed due to the requirement to remove IAC Type C designated pole-mounted switchgear from IEC 62271-200. ~~Only enclosed terminal equipment is to be considered within IEC 62271-200. For this reason,~~ IEC 62271-214 is to be considered independent of IEC 62271-200, however it is still related to other product standards of the IEC 62271 series.

Only open terminal pole-mounted switchgear and controlgear has been considered within this document.

This equipment relates to operation in three-phase, two-phase and single-phase systems.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 62271-214:2024](https://standards.iteh.ai/catalog/standards/iec/57bfe5f0-208c-482b-8d75-6dbf67803947/iec-62271-214-2024)

<https://standards.iteh.ai/catalog/standards/iec/57bfe5f0-208c-482b-8d75-6dbf67803947/iec-62271-214-2024>

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 214: Internal arc classification for

AC 1 metal-enclosed pole-mounted switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

1 Scope

This part of IEC 62271 specifies requirements for internal arc classification of AC metal-enclosed pole-mounted switchgear ~~installations used for alternating current~~ and controlgear with rated voltages above 1 kV and up to and including 52 kV with service frequencies up to and including 60 Hz.

This document is applicable to three-phase, two-phase and single-phase open terminal equipment for which an internal arc classification is assigned 2. Enclosures may include fixed and removable components and may be filled with fluid (liquid or gas) to provide insulation.

NOTE 1 The IAC classification takes into account the installation disposition of the high-voltage switchgear and controlgear and worker's operating area. 3

NOTE 2 For the use of this document, high-voltage (IEC 60050-601:1985, 601-01-27) is the rated voltage above 1 000 V. However, medium voltage (IEC 60050-601:1985, 601-01-28) is commonly used for distribution systems with voltages above 1 kV and generally applied up to and including 52 kV; refer to [1]¹.

This document does not preclude that other equipment may be included in the same enclosure. In such a case, any possible influence of that equipment on the switchgear and controlgear is to be taken into account.

2 Normative references

[IEC 62271-214:2024](https://standards.iec.ai/Catalog/standards/iec/57bfe5f0-208c-482b-8d75-6dbf67803947/iec-62271-214-2024)

<https://standards.iec.ai/Catalog/standards/iec/57bfe5f0-208c-482b-8d75-6dbf67803947/iec-62271-214-2024>

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-151:2001, *International Electrotechnical Vocabulary (IEV) – Part 151: Electrical and magnetic devices*

IEC 60050-151:2001/AMD1:2013

IEC 60050-151:2001/AMD2:2014

IEC 60050-151:2001/AMD3:2019

IEC 60050-151:2001/AMD4:2020

IEC 60050-151:2001/AMD5:2021

IEC 60050-441:1984, *International Electrotechnical Vocabulary (IEV) – Part 441: Switchgear, controlgear and fuses*

IEC 60050-441:1984/AMD1:2000

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

IEC 62271-1:2017/AMD1:2021

¹ Numbers in square brackets refer to the Bibliography.

IEC 62271-200:2021, *High-voltage switchgear and controlgear – Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 62271-1, IEC 60050-151 and IEC 60050-441, as well as the following apply.

NOTE 1 The classification system for definitions of IEC 62271-1:2017 is not followed. Terms and definitions are referenced and prioritized in the following order:

- Clause 3 of this document;
- IEC 62271-1:2017;
- IEC 60050-441;
- IEC 60050-151.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

NOTE 2 Additional definitions are classified so as to be aligned with the classification system used in IEC 60050-441.

3.1 General terms and definitions

3.1.101

metal-enclosed switchgear and controlgear

switchgear and controlgear assemblies with an external metal enclosure intended to be earthed, and completely assembled except for external connections

[SOURCE: IEC 60050-441:1984, 441-12-04, modified – "complete" has been replaced by "completely assembled"; NOTE has been deleted.]

~~3.1.102~~

~~**functional unit**~~

~~part of pole-mounted switchgear and controlgear comprising all the components of the main circuits and auxiliary circuits that contribute to the fulfilment of a single function~~

~~Note to entry: Functional units are distinguished according to the function for which they are intended, e.g. incoming unit, outgoing unit, etc.~~

~~[SOURCE: IEC 60050-441:1984, 441-13-04, modified – references to the supply and feed sides in the note has been deleted]~~

3.1.102

enclosure

part of an assembly providing a specified degree of protection of equipment against external influences and a specified degree of protection against approach to or contact with live parts and against contact with moving parts

[SOURCE: IEC 60050-441:1984, 441-13-01, modified – <of an assembly> has been deleted.]

3.1.103

high-voltage compartment

compartment of switchgear and controlgear, containing high-voltage conducting parts, enclosed except for openings necessary for interconnection, control or ventilation, where one segment of the compartment can be part of the outer earthed metallic enclosure

3.1.104
component

essential part of the high-voltage or earthing circuits of pole-mounted switchgear and controlgear which serves a specific function (e.g. circuit-breaker, disconnecter, switch, fuse, instrument transformer, bushing, busbar)

3.1.105
main circuit

all the high-voltage conductive parts of pole-mounted switchgear and controlgear included in a circuit which is intended to carry the rated continuous current

[SOURCE: IEC 60050-441:1984, 441-13-02, modified – "high voltage" has been added, "assembly" has been substituted by "pole-mounted switchgear and controlgear" and "transmit electrical energy" has been substituted by "carry the rated continuous current".]

3.1.106
earthing circuit

conductors, connections, and the conducting parts of earthing devices intended to connect the high-voltage conductive parts to the earthing system of the installation

Note 1 to entry: Parts of metallic enclosures connected to the earthing system can be part of the earthing circuit.

3.1.107
normal operating condition

in service condition with all covers properly closed and secured

Note 1 to entry: The term "in service" implies "under live conditions".

[SOURCE: IEC 62271-200:2021[2], 3.1.106, modified – "<of an assembly>" and "doors and" have been removed and Note 1 to entry has been added.]

3.1.108
pressure relief device

device incorporated as part of an enclosure or compartment intended to operate to prevent excessive pressure in the enclosure or compartment

3.1.109
fluid-filled compartment

high-voltage compartment of pole-mounted switchgear and controlgear filled with a fluid, either gas, other than ambient air, or liquid, for insulation purposes

3.1.110
pole

vertical single member support in wood, concrete, steel or other material, with one end buried in the ground, either directly or by means of a foundation

Note 1 to entry: The term pole as defined here is not to be mixed up with the use of the same term as synonymous for phase as used in other standards.

[SOURCE: IEC 60050-466:1990, 466-07-01[8], modified – Note 1 to entry has been added.]

3.1.111
pole-mounted switchgear and controlgear

metal-enclosed switchgear and controlgear, typically connected to overhead lines, installed on one or more poles or equivalent structures at a defined height, with restricted accessibility by installation out of reach

3.1.112

**internal arc ~~classified switchgear and controlgear~~ classification
IAC**

metal-enclosed switchgear and controlgear for which prescribed criteria, for protection of authorized persons and the general public beneath the apparatus **4**, are met in the event of internal arc for specified installation conditions, as demonstrated by type tests

Note 1 to entry: The internal arc classification is described by the characteristics given from 3.1.~~4013~~114 to 3.1.~~4046~~116.

[SOURCE: IEC 62271-200:~~2011~~2021, 3.~~4326~~.117, modified – "authorized" and "and general public beneath the apparatus" have been added, "assembly" has been changed by "metal-enclosed switchgear and controlgear".]

3.1.113

arc fault current

three-phase and where applicable the single-phase-to-earth RMS value of the internal arc fault current for which the switchgear and controlgear is designed to protect persons in the event of an internal arc

[SOURCE: IEC 62271-200:~~2011~~2021, 3.~~432-37~~.101]

3.1.114

arc fault duration

duration of the internal arc fault current for which the switchgear and controlgear is designed to protect persons in the event of an internal arc

[SOURCE: IEC 62271-200:~~2011~~2021, 3.~~432-47~~.102]

3.1.115

approach distance

distance between the test object and indicators arranged in an IAC test

3.1.116

arc mitigation device

device dedicated to reacting to internal arc fault conditions to decrease the arc energy

[SOURCE: CIGRE TECHNICAL BROCHURE 686:2017][5]

3.8 Index of definitions

A – C

approach distance.....	3.1.115
arc fault current.....	3.1.113
arc fault duration.....	3.1.114
arc mitigation device.....	3.1.116
component.....	3.1.104

E – F

earthing circuit.....	3.1.106
enclosure.....	3.1.102
fluid-filled compartment.....	3.1.109

H – I

high-voltage compartment	3.1.103
internal arc classification, IAC	3.1.112

M – N

main circuit	3.1.105
metal-enclosed switchgear and controlgear	3.1.101
normal operating condition	3.1.107

P

pole	3.1.110
pole-mounted switchgear and controlgear	3.1.111
pressure relief device	3.1.108

4 Normal and special service conditions**4.1 General**

~~Unless otherwise specified in this document, operation under normal and special service conditions is considered to be covered by the relevant IEC standard.~~

Clause 4 of IEC 62271-1:2017 and IEC 62271-1:2017/AMD1:2021 is not applicable.

5 Ratings

Subclauses of Clause 5 of IEC 62271-1:2017 and IEC 62271-1:2017/AMD1:2021 not mentioned below are not applicable for this document.

5.1 General

Subclause 5.1 of IEC 62271-1:2017 and IEC 62271-1:2017/AMD1:2021 is not applicable and replaced by following text:

The relevant ratings ~~with respect to the arc fault classification of pole-mounted switchgear and controlgear~~ for the internal arc classification are the following:

- rated voltage (U_r);
- rated frequency (f_r);
- ratings of the internal arc classification (IAC).

5.2 Rated voltage (U_r)

Subclause 5.2 of IEC 62271-1:2017 is applicable with following addition to 5.2.1.

5.2.1 General

The rated voltage is equal to the maximum system voltage for which the equipment is designed. It indicates the maximum value of the "highest system voltage" of networks for which the equipment may be used (refer to Clause 9 of IEC 60038:2009 [6]).

NOTE It is possible that components forming part of pole-mounted switchgear and controlgear have differing values of rated voltage in accordance with their relevant standards.

5.3 Rated insulation level (U_d , U_p , U_s)

Not applicable.

5.4 Rated frequency (f_r)

~~The standard values of the rated frequency are 16,7 Hz, 25 Hz, 50 Hz and 60 Hz.~~

Subclause 5.4 of IEC 62271-1:2017 and IEC 62271-1:2017/AMD1:2021 is applicable.

5.101 Ratings of the internal arc classification (IAC)

5.101.1 General

An IAC classified pole-mounted switchgear and controlgear shall have the following ratings: rated approach distance, arc fault currents and arc fault durations.

5.101.2 Rated approach distance (D_{AP})

The rated approach distance shall be stated by the manufacturer (refer to Figure 2).

5.101.3 Rated arc fault currents (I_A , I_{Ae})

The ~~standard~~ value of rated arc fault currents should be selected from the R 10 series specified in IEC 60059 [7].

Two ratings of the arc fault currents are recognised:

- a) three-phase and phase-to-phase arc fault current (I_A), when applicable;
- b) single-phase-to-earth arc fault current (I_{Ae}), when applicable.

When only a three-phase rating is specified, the single-phase rating is by default 87 % of the three-phase rating, and need not be specified.

NOTE 1 The rationale for this 87 % is the arc fault test with 2-phase ignition; refer to 7.101.7.2.

The manufacturer shall specify the compartments to which the single-phase-to-earth arc fault current rating applies. Such value is assigned to switchgear and controlgear where its construction will prevent the arc from becoming multiphase, as demonstrated during the internal arc test.

~~When IAC testing on single phase switchgear and controlgear or single phase high voltage compartments where only a singlephase supply circuit has been applied only an I_{Ae} rating shall be assigned.~~ In the case where all high-voltage compartments are only designed for single-phase-to-earth arc faults, instead of I_A rating, the I_{Ae} rating shall be assigned (refer to 7.101.7.2).

NOTE 2 Information about the relationship between type of neutral earthing and the single-phase-to-earth arc fault current is provided in 9.101.6.

5.101.4 Rated arc fault duration (t_A , t_{Ae})

~~Standard~~ Recommended values for the arc fault duration (t_A , t_{Ae}) are 0,1 s, 0,5 s and 1 s.

NOTE It is in general not possible to calculate the permissible arc duration for a current which differs from that used in the test.