



IEC 61558-2-15

Edition 3.0 2022-05
REDLINE VERSION

INTERNATIONAL STANDARD



GROUP SAFETY PUBLICATION

**Safety of transformers, reactors, power supply units and combinations thereof –
Part 2-15: Particular requirements and tests for isolating transformers
for medical IT systems for the supply of medical locations**

Document Preview

[IEC 61558-2-15:2022](#)

<https://standards.iteh.ai/catalog/standards/iec/2d4cc950-13e2-4fc1-88d3-0142238a68eb/iec-61558-2-15-2022>





THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2022 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

International Standards
standards.iteh.ai
Document Preview

[IEC 61558-2-15:2022](https://standards.iteh.ai/catalog/standards/iec/2d4cc950-13e2-4fc1-88d3-0142238a68eb/iec-61558-2-15-2022)

<https://standards.iteh.ai/catalog/standards/iec/2d4cc950-13e2-4fc1-88d3-0142238a68eb/iec-61558-2-15-2022>



IEC 61558-2-15

Edition 3.0 2022-05
REDLINE VERSION

INTERNATIONAL STANDARD



GROUP SAFETY PUBLICATION

**Safety of transformers, reactors, power supply units and combinations thereof –
Part 2-15: Particular requirements and tests for isolating transformers
for medical IT systems for the supply of medical locations**

Document Preview

[IEC 61558-2-15:2022](https://standards.iteh.ai/catalog/standards/iec/2d4cc950-13e2-4fc1-88d3-0142238a68eb/iec-61558-2-15-2022)

<https://standards.iteh.ai/catalog/standards/iec/2d4cc950-13e2-4fc1-88d3-0142238a68eb/iec-61558-2-15-2022>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.180

ISBN 978-2-8322-5041-9

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	4
INTRODUCTION	2
1 Scope	8
2 Normative references	9
3 Terms and definitions	9
4 General requirements	10
5 General notes on tests	10
6 Ratings	10
7 Classification	11
8 Marking and other information	11
9 Protection against electric shock	12
10 Change of input voltage setting	13
11 Output voltage and output current under load	13
12 No-load output voltage	13
13 Short-circuit voltage	13
14 Heating	14
15 Short-circuit and overload protection	15
16 Mechanical strength	15
17 Protection against harmful ingress of dust, solid objects and moisture	15
18 Insulation resistance, dielectric strength and leakage current	15
19 Construction	18
20 Components	20
21 Internal wiring	20
22 Supply connection and other external flexible cable or cords	20
23 Terminals for external conductors	21
24 Provisions for protective earthing	21
25 Screws and connections	21
26 Creepage distances, clearances and distances through insulation	21
27 Resistance to heat, fire and tracking	21
28 Resistance to rusting	21
Annexes	22
Annex H (normative) Electronic circuits	22
Annex L (normative) Routine tests (production tests)	22
Bibliography	23
Index of defined terms
Figure 101 – Required circuit for measuring the leakage current from the output winding to the earthing	17
Figure 102 – Required circuit for measuring the leakage current at the protective earthing conductor	18

Table 101 – Symbols indicating the kind of transformer	12
Table 102 – Additional dielectric strength test voltages	16

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 61558-2-15:2022](#)

<https://standards.iteh.ai/catalog/standards/iec/2d4cc950-13e2-4fc1-88d3-0142238a68eb/iec-61558-2-15-2022>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SAFETY OF TRANSFORMERS, REACTORS, POWER SUPPLY UNITS AND COMBINATIONS THEREOF –

Part 2-15: Particular requirements and tests for isolating transformers for medical IT systems for the supply of medical locations

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 61558-2-15:2011. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC 61558-2-15 has been prepared by IEC technical committee 96: Transformers, reactors, power supply units and combinations thereof. It is an International Standard.

This third edition cancels and replaces the second edition published in 2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) Adjustment of structure and references in accordance with IEC 61558-1:2017;

The text of this International Standard is based on the following documents:

Draft	Report on voting
96/535/FDIS	96/536/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

It has the status of a group safety publication in accordance with IEC Guide 104.

This International Standard is to be used in conjunction with IEC 61558-1:2017.

NOTE When "Part 1" is mentioned in this standard, it refers to IEC 61558-1:2017.

This document supplements or modifies the corresponding clauses in IEC 61558-1:2017, so as to convert that publication into the IEC standard: *Particular requirements and tests for isolating transformers for medical IT systems for the supply of medical locations*.

A list of all parts in the IEC 61558 series published under the general title *Safety of transformers, reactors, power supply units and combinations thereof*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

Where this document states "*addition*", "*modification*" or "*replacement*", the relevant text of IEC 61558-1:2017 is to be adapted accordingly.

In this document, the following print types are used:

- requirements proper: in roman type;
- *test specifications*: in italic type;
- explanatory matter: in smaller roman type.

In the text of this document, the words in **bold** are defined in Clause 3.

Subclauses, notes, figures and tables additional to those in IEC 61558-1:2017 are numbered starting from 101; supplementary annexes are entitled AA, BB, etc.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 61558-2-15:2022](#)

<https://standards.iteh.ai/catalog/standards/iec/2d4cc950-13e2-4fc1-88d3-0142238a68eb/iec-61558-2-15-2022>

INTRODUCTION

IEC TC 96 has a group safety function in accordance with IEC Guide 104 for transformers other than those intended to supply distribution networks, in particular transformers and power supply units intended to allow the application of protective measures against electric shock as defined by TC 64, but in certain cases including the limitation of voltage and horizontal safety function for SELV, in accordance with IEC 60364-4-41.

The group safety function (GSF) is necessary because of responsibility for safety extra-low voltage (SELV) in accordance with IEC 61140:2016, 5.2.6 and IEC 60364-4-41:2005, 414.3.1 or control circuits in accordance with IEC 60204-1:2016, 7.2.4.

The group safety function is needed for each part of IEC 61558-2 because different standards of the IEC 61558 series can be combined in one construction but in certain cases with no limitation of rated output power.

For example an auto-transformer in accordance with IEC 61558-2-13 can be designed with a separate SELV-circuit in accordance with the particular requirements for IEC 61558-2-6 relating to the general requirements of IEC 61558-1.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 61558-2-15:2022](#)

<https://standards.iteh.ai/catalog/standards/iec/2d4cc950-13e2-4fc1-88d3-0142238a68eb/iec-61558-2-15-2022>

SAFETY OF TRANSFORMERS, REACTORS, POWER SUPPLY UNITS AND COMBINATIONS THEREOF –

Part 2-15: Particular requirements and tests for isolating transformers for medical IT systems for the supply of medical locations

1 Scope

Replacement

This part of IEC 61558 deals with safety ~~aspects~~ of **isolating transformers for medical IT systems for the supply of medical locations**.

NOTE 1 Safety includes electrical, thermal and mechanical aspects.

Unless otherwise specified, from here onward, the term **transformer** covers **isolating transformers for medical IT systems for the supply of medical locations**.

This document is applicable to **stationary**, single-phase or three-phase, air-cooled (natural or forced) ~~independent~~ **dry-type isolating transformers** for the supply of **medical IT-systems system** for group 2 medical locations, designed to be permanently connected to the fixed wiring and intended to form the **medical IT-power system** on the secondary side. The windings ~~may~~ **can** be encapsulated or non-encapsulated.

NOTE 2 ~~IT-power systems~~ are defined in IEC 60364-1.

~~NOTE 3~~—The installation rules for **medical IT-systems system** for group 2 medical locations are covered by IEC 60364-7-710.

NOTE 3 National installation rules of some countries have different or additional requirements listed in Annex C of IEC 60364-7-710:2021.

~~NOTE 4~~—**Transformers** covered by this document are intended for **medical IT systems for the supply of medical locations**. All other **transformers** or equipments ~~s-connected downstream from the transformer~~ are not covered by this document.

The **rated supply voltage** does not exceed 1 000 V AC. The **rated supply frequency** and **internal operational frequency** do not exceed 500 Hz.

The **rated output** is not less than 0,5 kVA and does not exceed 10 kVA for single-phase and three-phase **transformers for medical IT system** for group 2 medical locations.

This document ~~is~~ **can be** applicable to **isolating transformers** intended to supply other medical installations that are not group 2 medical locations without limitation of the **rated output** subject to an agreement between the purchaser and the manufacturer.

NOTE 54 **Transformers** intended to supply ~~power to~~ distribution networks other than **medical IT systems** are not included in the scope.

The **no-load output voltage** and the **rated output voltage** does not exceed 250 V AC for single-phase or three-phase **transformer** (phase-to-phase voltage).

This document does not cover **power supply units**.

This document is not applicable to external circuits and their components intended to be connected to the input terminals and output terminals of the **transformers**.

Transformers covered by this document are used in applications where **double or reinforced insulation** between circuits is required by the installation rules or by the appliance specification.

NOTE 6—Attention is drawn to the following, if necessary:

- additional requirements for **transformers** intended to be used in vehicles, on board ships, and aircraft ~~additional requirements~~ (from other applicable standards, national rules, etc. ~~may be necessary~~);
- measures to protect the **enclosure** and the components inside the **enclosure** against external influences such as fungus, vermin, termites, solar-radiation, and icing ~~should also be considered~~;
- the different conditions for transportation, storage, and operation of the **transformers** ~~should also be considered~~;
- additional requirements in accordance with other appropriate standards and national rules may be applicable to **transformers** intended for use in special environments.

This group safety publication focusing on safety guidance is primarily intended to be used as a product safety standard for the products mentioned in the scope, but is also intended to be used by TCs in the preparation of publications for products similar to those mentioned in the scope of this group safety publication, in accordance with the principles laid down in IEC Guide 104 and ISO/IEC Guide 51.

One of the responsibilities of a TC is, wherever applicable, to make use of BSPs and/or GSPs in the preparation of its publications.

2 Normative references

This clause of Part 1 is applicable except as follows:

Addition

<https://standards.iteh.ai/> IEC 61558-2-15:2022
~~IEC 61558-1:2005~~ 2017, ~~Safety of power transformers, power supplies, reactors and similar products~~ Safety of transformers, reactors, power supply units and combinations thereof – Part 1: General requirements and tests

3 Terms and definitions

~~This clause of Part 1 is applicable, except as follows:~~

For the purposes of this document, the terms and definitions given in Part 1 apply, except as follows:

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

Addition

3.1.101

isolating transformer for medical IT systems for the supply of medical locations

isolating transformer used for the supply of **medical IT-systems system** for group 2 medical locations, designed to be permanently connected and with **double or reinforced insulation** between each part of the transformer (body, screen, circuits, thermal sensitive device) except between the core and the **body**

3.2.101

medical IT system

electric IT system fulfilling all specific additional requirements of group 2 medical locations

[SOURCE: IEC 60364-7-710:2021, 710.3.10, modified – Note 1 to entry has been deleted.]

3.5.101

rated input current

~~input~~ input current assigned to the transformer by the manufacturer, when the **transformer** is loaded with **rated output**

3.6.101

no-load input current

input current when the **transformer** is connected to the **rated supply voltage**, at the **rated supply frequency**, with no-load on the output

3.6.101~~2~~

inrush current

maximum instantaneous value of the **no-load input current** of the **transformer** (peak value) when the **transformer** is switched on at **rated supply voltage**

3.47.101

functional screening

separation between two windings or between a winding and the core or shielding of a part or of the whole **transformer**, by means of an interposed conductive screen for functional reasons

4 General requirements

This clause of Part 1 is applicable.

5 General notes on tests

[IEC 61558-2-15:2022](https://standards.iteh.ai/IEC/61558-2-15-2022)

<https://standards.iteh.ai/catalog/standards/iec/2d4cc950-13e2-4fc1-88d3-0142238a68eb/iec-61558-2-15-2022>

This clause of Part 1 is applicable.

6 Ratings

This clause of Part 1 is applicable except as follows:

~~Replacement~~ Addition

6.101 The **rated output voltage** ~~(phase-to-phase voltage)~~ shall not exceed 250 V AC for single-phase or three-phase **transformers** (phase-to-phase voltage).

6.102 The **rated output** shall not be less than 0,5 kVA and shall not exceed 10 kVA for single-phase or three-phase **transformers**.

Transformers intended to supply other medical installations that are not group 2 medical locations without limitation of the **rated output** shall be subject to an agreement between the purchaser and the manufacturer.

6.103 The rated frequency and internal operational frequency shall not exceed 500 Hz.

6.104 The **rated supply voltage** shall not exceed 1 000 V AC.

Compliance with the requirements of 6.101 to 6.104 shall be ~~verified~~ checked by inspection of the marking.

7 Classification

This clause of Part 1 is applicable, except as follows:

Replacement

7.2 ~~Replacement:~~

~~According to short-circuit protection or protection against abnormal conditions:~~

~~— non-short-circuit proof transformer.~~

Transformers shall be **non-short-circuit proof transformers** in accordance with the short-circuit characteristic or protection against abnormal use.

7.4

Transformers shall be **stationary transformers**.

7.5

Transformers shall be classified for **continuous duty**.

7.8

Transformers shall be classified for **overvoltage category III**.

[IEC 61558-2-15:2022](https://standards.iteh.ai/IEC/61558-2-15/2022)

<https://standards.iteh.ai/IEC/61558-2-15/2022>

8 Marking and other information

This clause of Part 1 is applicable except as follows:

8.1 h)

Replacement

~~Replace the first sentence by the following: Relevant graphical symbols shown in 8.11 indicating the type of transformer;~~

Replace the content up to the first semi-colon by the following:

relevant graphical symbols shown in Table 101 that indicate the kind of **transformer**

~~t) Addition:~~

~~**Transformers** shall be marked with the measured **short-circuit voltage** expressed as a percentage of the **rated supply voltage**.~~

8.1 s)

Replacement

Transformers shall be marked with the measured **short-circuit voltage** expressed as a percentage of the **rated supply voltage**.

Addition

8.1.101 When the **inrush current** exceeds 8 times the peak value of the **rated input current**, the resulting value shall be marked on the transformer.

8.6



Addition

All terminals shall be clearly marked.

8.11

Addition

Table 101 – Symbols indicating the kind of transformer

Symbol or graphical symbol	Explanation or title	Identification
	<p>non-short-circuit proof isolating transformer for the supply of medical locations</p>	<p>IEC 60417-5972 (DB-2010-08)</p>
	<p>Non-short-circuit proof isolating transformers for medical IT systems for the supply of group 2 medical locations</p> <p>NOTE This symbol is not applicable for transformers > 10 kVA</p>	<p>IEC 60417-5972:2003-08</p>

8.14

Addition

The instruction sheet shall state: "Screens whose connection to the earthing is necessary for compliance with the leakage current requirements of Clause 18 shall be connected to the earthing."

~~The instruction sheet shall qualify the type of temperature sensor built in the transformer, if any. The instruction sheet shall give the required value of the circuit of the transformer, when it is allowed by national installation rules.~~

The instruction sheet shall include type and characteristic of sensor to over-temperature monitoring, if any.

The **rated input current** shall be provided as information given either on the transformer marking or made available in the manufacturer's catalogue or similar.