



Designation: **C1542/C1542M – 16a** C1542/C1542M – 19

Standard Test Method for Measuring Length of Concrete Cores¹

This standard is issued under the fixed designation C1542/C1542M; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope*

1.1 This test method is used to determine the length of a core drilled from concrete.

1.2 The values stated in either SI units or inch-pound units are to be regarded separately as standard. ~~Within the text, the inch-pound units are shown in brackets.~~ The values stated in each system are not necessarily exact equivalents; therefore, to ensure conformance with the standard, each system shall be used independently of the other, and values from the two systems shall not be combined.

1.3 The text of this standard refers to notes and footnotes that provide explanatory material. These notes and footnotes (excluding those in tables and figures) shall not be considered as requirements of this standard.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.5 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 *ASTM Standards:*²

C42/C42M Test Method for Obtaining and Testing Drilled Cores and Sawed Beams of Concrete

C125 Terminology Relating to Concrete and Concrete Aggregates

C174/C174M Test Method for Measuring Thickness of Concrete Elements Using Drilled Concrete Cores

C670 Practice for Preparing Precision and Bias Statements for Test Methods for Construction Materials

C1604/C1604M Test Method for Obtaining and Testing Drilled Cores of Shotcrete

3. Terminology

3.1 *Definitions:*

3.1.1 For definitions of terms used in this test method, refer to Terminology **C125**.

4. Significance and Use

4.1 This test method provides two procedures for determining the length of a core obtained in accordance with either Test Method **C42/C42M** or Test Method **C1604/C1604M**. This length is used in conjunction with condition surveys, density and voids analysis, and other applications.

4.2 This procedure does not intend to include in the length measurement adhered particles not part of the concrete mixture.

4.3 Test Method **C174/C174M** also determines the length of concrete cores using a different measuring apparatus and procedure.

NOTE 1—Test Method **C174/C174M** uses an apparatus that establishes two parallel planes a known distance apart. The length of the core is determined by calculation using the known distance between the two parallel planes and the measured distance from the upper plane to the top of the core.

¹ This test method is under the jurisdiction of ASTM Committee **C09** on Concrete and Concrete Aggregates and is the direct responsibility of Subcommittee **C09.61** on Testing for Strength.

Current edition approved June 1, 2016/Dec. 1, 2019. Published June 2016/January 2020. Originally approved in 2002. Last previous edition approved in 2016 as **C1542/C1542M**/**C1542/C1542M – 16a**. DOI: 10.1520/C1542-16A-10.1520/C1542-19.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

*A Summary of Changes section appears at the end of this standard