



Designation: E2777 – 20

Standard Guide for Vegetative (Green) Roof Systems¹

This standard is issued under the fixed designation E2777; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reappraisal. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reappraisal.

1. Scope

1.1 This guide identifies terminology, principles, and fundamental concepts including those related to sustainability, technical requirements of construction, and types of vegetative (green) roof systems used on buildings.

1.2 The considerations for sustainable development relative to vegetative (green) roof systems are categorized as follows: environmental, social, and economic as consistent with Guide E2432. (See Appendix X1.)

1.3 This guide discusses technical requirements for vegetative (green) roof systems pertaining to the following categories: plants, media, wind scour resistance, soil reinforcement, separation or filter layers, drain layers, water retention layers, protection layers, and root penetration barriers.

1.4 This guide addresses intensive and extensive vegetative (green) roof systems for roofs up to 15 % slope. Roofing/waterproofing membranes and insulation are key components of vegetative (green) roof systems, but technical requirements regarding their role in such roof systems is beyond the scope of this guide.

NOTE 1—ASTM Technical Committees D08 and C16 have jurisdiction over the development of standards for roofing/waterproofing membranes and insulations, respectively. Some of their existing standards may be helpful in the evaluation of membranes and insulation used in vegetative (green) roof systems. As these two committees develop standards for such roofs, this guide will be revised appropriately.

1.5 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

1.6 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.7 *This international standard was developed in accordance with internationally recognized principles on standard-*

ization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.

2. Referenced Documents

2.1 ASTM Standards:^{2,3}

- C88/C88M Test Method for Soundness of Aggregates by Use of Sodium Sulfate or Magnesium Sulfate
- D1079 Terminology Relating to Roofing and Waterproofing
- D1987 Test Method for Biological Clogging of Geotextile or Soil/Geotextile Filters
- D2974 Test Methods for Moisture, Ash, and Organic Matter of Peat and Other Organic Soils
- D3786/D3786M Test Method for Bursting Strength of Textile Fabrics—Diaphragm Bursting Strength Tester Method
- D4354 Practice for Sampling of Geosynthetics and Rolled Erosion Control Products (RECPs) for Testing
- D4439 Terminology for Geosynthetics
- D4491/D4491M Test Methods for Water Permeability of Geotextiles by Permittivity
- D4595 Test Method for Tensile Properties of Geotextiles by the Wide-Width Strip Method
- D4716/D4716M Test Method for Determining the (In-plane) Flow Rate per Unit Width and Hydraulic Transmissivity of a Geosynthetic Using a Constant Head
- D4751 Test Methods for Determining Apparent Opening Size of a Geotextile
- D4759 Practice for Determining the Specification Conformance of Geosynthetics
- D4873/D4873M Guide for Identification, Storage, and Handling of Geosynthetic Rolls and Samples
- D5262 Test Method for Evaluating the Unconfined Tension Creep and Creep Rupture Behavior of Geosynthetics
- D5617 Test Method for Multi-Axial Tension Test for Geosynthetics
- D5818 Practice for Exposure and Retrieval of Samples to Evaluate Installation Damage of Geosynthetics

¹ This guide is under the jurisdiction of ASTM Committee D08 on Roofing and Waterproofing and is the direct responsibility of Subcommittee D08.24 on Sustainability.

Current edition approved Feb. 1, 2020. Published February 2020. Originally approved in 2014. Last previous edition approved in 2014 as E2777 – 14. DOI: 10.1520/E2777-20.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Whenever a specific version of a standard is not identified, the most recent edition of the standard shall apply.

- D6637/D6637M** Test Method for Determining Tensile Properties of Geogrids by the Single or Multi-Rib Tensile Method
- D7361** Test Method for Accelerated Compressive Creep of Geosynthetic Materials Based on Time-Temperature Superposition Using the Stepped Isothermal Method
- D7492/D7492M** Guide for Use of Drainage System Media with Waterproofing Systems
- D7877** Guide for Electronic Methods for Detecting and Locating Leaks in Waterproof Membranes
- E108** Test Methods for Fire Tests of Roof Coverings
- E136** Test Method for Assessing Combustibility of Materials Using a Vertical Tube Furnace at 750°C
- E631** Terminology of Building Constructions
- E2114** Terminology for Sustainability Relative to the Performance of Buildings
- E2396/E2396M** Test Method for Saturated Water Permeability of Granular Drainage Media [Falling-Head Method] for Vegetative (Green) Roof Systems
- E2397/E2397M** Practice for Determination of Dead Loads and Live Loads Associated with Vegetative (Green) Roof Systems
- E2398/E2398M** Test Method for Water Capture and Media Retention of Geocomposite Drain Layers for Vegetative (Green) Roof Systems
- E2399/E2399M** Test Method for Maximum Media Density for Dead Load Analysis of Vegetative (Green) Roof Systems
- E2400/E2400M** Guide for Selection, Installation, and Maintenance of Plants for Vegetative (Green) Roof Systems
- E2432** Guide for General Principles of Sustainability Relative to Buildings
- E2788/E2788M** Specification for Use of Expanded Shale, Clay and Slate (ESCS) as a Mineral Component in the Growing Media and the Drainage Layer for Vegetative (Green) Roof Systems
- 2.2 *ASCE/SEI Standard*:⁴
- ASCE/SEI 7** Minimum Design Loads for Buildings and Other Structures (latest edition)
- 2.3 *ANSI/SPRI Standards*:⁵
- ANSI/SPRI RP-14** Wind Design Standard for Vegetative Roofing Systems
- ANSI/SPRI VF-1** External Fire Design Standard for Vegetative Roofs
- 2.4 *CSA Standard*:⁶
- CSA A123.24** Standard Test Method for Wind Resistance of Modular Vegetated Roof Assembly

3. Terminology

3.1 Definitions:

3.1.1 For terms related to building, refer to Terminology **E631**.

3.1.2 For terms related to sustainability and buildings, refer to Terminology **E2114**.

3.1.3 For terms related to roofing and waterproofing, refer to Terminology **D1079**.

3.2 Definitions of Terms Specific to This Standard:

3.2.1 *apparent opening size (AOS), n*—for a geotextile, a property which indicates the approximate largest particle that would effectively pass through the geotextile.

3.2.2 *capillary potential, n*—of geotextiles, a property that indicates the ability of a geotextile to distribute moisture.

3.2.3 *cation exchange capacity (CEC), n*—the capacity of a soil to retain and exchange the cations of nutrients, defined as the sum of exchangeable cations that a media can retain per unit weight **(1)**.⁷

3.2.4 *clogging, n*—for geotextiles, the condition where soil particles move into and are retained in the openings of the fabric, thereby reducing the hydraulic conductivity.

3.2.5 *dead load, n*—for a vegetative (green) roof system, the weight of a mature vegetative (green) roof system from the structural deck up, following rainfall, during which retained and captured water attain maximum levels.

3.2.6 *drain layer, n*—horizontal layer, including one or more discrete components, that has been specifically designed to convey water toward the roof deck drains, gutters, or scuppers.

3.2.6.1 *Discussion*—Drain layers may be simple, consisting of a single component, or complex, combining multiple components including: geosynthetics, geocomposites, and coarse mineral aggregate. See also *geocomposite drain layer* and *granular drain layer*.

3.2.7 *eutrophication, n*—the process by which bodies of water or other aquatic systems become overly enriched with minerals and other nutrients.

3.2.8 *evapotranspiration, n*—the process by which water is released to the atmosphere by evaporation from the surface of media and plant foliage, and components of the vegetative (green) roof system.

3.2.8.1 *Discussion*—Potential evapotranspiration rates can be determined using local climatic data. Specific evapotranspiration rates may vary with plant type, plant foliage density, vegetative (green) roof media composition, and availability of irrigation.

3.2.9 *extensive vegetative (green) roof system, n*—a roof system that features plants that can be sustained in shallow media layers (with 6 in. or less of growing media), and typically utilizes non-woody, drought-tolerant herbs, grass, moss, and succulents.

3.2.10 *gap-graded, adj*—granular materials in which the particle size distribution curve is markedly discontinuous. Mixtures containing particles of both large and small sizes, in which particles of certain intermediate sizes are wholly or substantially absent. See *particle size distribution curve*.

⁷ The boldface numbers in parentheses refer to the list of references at the end of this standard.

⁴ Available from American Society of Civil Engineers (ASCE), 1801 Alexander Bell Dr., Reston, VA 20191, <http://www.asce.org>.

⁵ Available from Single Ply Roofing Industry (SPRI), 465 Waverley Oaks Road, Suite 421, Waltham, MA 02452, <http://www.spri.org>.

⁶ Available from Canadian Standards Association (CSA), 178 Rexdale Blvd., Toronto, ON M9W 1R3, Canada, <http://www.csagroup.org>.

3.2.11 *geocomposite*, *n*—a product composed of two or more materials, at least one of which is a geosynthetic.

3.2.12 *geocomposite drain layer*, *n*—drain layer composed of a synthetic sheet, mat, or panel.

3.2.12.1 *Discussion*—Geocomposite drain layers may include absorptive drain mats whose principle function is drainage, but which will also contribute to water retention. Some geocomposite drain layers may incorporate reservoirs that will capture water. See also *granular drain layer*.

3.2.13 *geosynthetic*, *n*—a planar product manufactured from polymeric material used with soil, rock, earth, or other geotechnical-engineering-related material as an integral part of a vegetative (green) roof system (as described in Practice D4354, Practice D4759, Guide D4873/D4873M, Test Method D5617, and Practice D5818).

3.2.14 *geotextile*, *n*—any permeable textile used with foundation, soil, rock, earth, or any other geotechnical-engineering-related material as an integral part of a man-made project, structure, or system.

3.2.14.1 *Discussion*—Geotextiles perform several functions in geotechnical engineering applications, including: separation, filtration, drainage, reinforcement, and protection.

3.2.15 *granular drainage media*, *n*—coarse aggregate applied in a layer at the base of the vegetated vegetative (green) roof system profile or filled into the upper face of a reservoir sheet to provide a horizontal plane for free drainage of the vegetative (green) roof system.

3.2.16 *granular drain layer*, *n*—a drain layer composed entirely of granular drainage media.

3.2.17 *hardscape*, *n*—non-vegetated surfacing on vegetative (green) roof systems.

3.2.17.1 *Discussion*—Hardscape is most often used in place of soil at walkways, plazas, maintenance areas, or at staging areas for mechanical equipment and façade access.

3.2.18 *hydraulic transmissivity*, *n*—for a geosynthetic or geocomposite, the volumetric flow rate per unit width of specimen per unit gradient in a direction parallel to the plane of the specimen; also referred to as in-plane flow and, for a granular drainage media, saturated water permeability multiplied by the layer thickness (as determined using Test Method D4716/D4716M).

3.2.19 *intensive vegetative (green) roof system*, *n*—intensive vegetative (green) roof systems feature large perennial plants or turf grass.

3.2.19.1 *Discussion*—The use of large plants generally requires media thicknesses in excess of 6 in. (15 cm), and in most instances, irrigation. Intensive vegetative (green) roofs will require levels of maintenance similar to onground gardens. See also extensive vegetated (green) roof system.

3.2.20 *maximum media density*, *n*—the density of a granular drainage media or vegetative (green) roof media determined after they have been subjected to a specific amount of compaction and hydrated by immersion to simulate prolonged exposure to both foot traffic and rainfall.

3.2.20.1 *Discussion*—The maximum media density applies to drained conditions.

3.2.21 *module*, *n*—pre-manufactured unit containing some of the functional elements of a vegetative (green) roof system.

3.2.21.1 *Discussion*—Independent modules are designed to be placed adjacent, and sometimes linked to one another, in order to cover roof surfaces.

3.2.22 *open-graded*, *adj*—granular materials that contain relatively few fines in order to leave fairly large spaces between particles when compacted. See *particle size distribution curve*.

3.2.23 *organic matter*, *n*—material in a soil or vegetative (green) roof media that volatilizes from a dry sample when heated in an oven to 824 °F (440 °C).

3.2.24 *particle size distribution curve*, *n*—curve, based on sieve and hydrometer analysis, that describes the relative quantities of particles of different sizes in a mixture.

3.2.24.1 *Discussion*—For planting media, this descriptor is limited to the non-organic fraction.

3.2.25 *permeability*, *n*—see *saturated water permeability*.

3.2.26 *permittivity*, *n*—of geotextiles, the volumetric flow rate of water per unit cross-sectional area per unit head under laminar flow conditions, perpendicular to the plane of the geotextile.

3.2.27 *phytotoxic*, *n*—poisonous to plants.

3.2.28 *protection layer*, *n*—any continuous layer that is intended to protect the roofing/waterproofing membrane from damage and which is placed in direct contact with the roofing/waterproofing membrane.

3.2.28.1 *Discussion*—Agents for damage may include abrasion, puncture, UV exposure, and temperature fluctuation. Protection layers may include additional layers of material (as recommended by the membrane manufacturer), coatings, geosynthetic materials, geotextiles, geocomposites, tiles, and insulation.

3.2.29 *reservoir sheet*, *n*—a shaped plastic membrane containing receptacles on its upper surface to capture and retain water.

3.2.29.1 *Discussion*—In some vegetative (green) roof systems, these receptacles are filled with granular drainage media.

3.2.30 *root penetrability*, *n*—of a geotextile, a property that indicates the ease with which plant roots can penetrate a geotextile.

3.2.31 *root penetration barrier*, *n*—continuous layer incorporated in a vegetative (green) roof system to prevent damage to the roofing/waterproofing membrane system caused by root growth.

3.2.32 *root resistance*, *n*—ability of component to prevent penetration by roots as measured in a long-duration test that simulates field conditions (2).

3.2.33 *saturated water permeability*, *n*—for vegetative (green) roof media, the coefficient which when multiplied times the hydraulic gradient yields the apparent velocity with

which water at 68 °F (20 °C) moves through a cross-section of fully submerged media.

3.2.34 *soundness, n*—for granular drainage media, the capacity to resist freezing without fracturing.

3.2.35 *thermal capacitance, n*—a property of a material that determines how readily it absorbs and releases thermal energy (3).

3.2.35.1 *Discussion*—Heat capacity, or specific heat, is the measure for thermal capacitance. Heat capacity of a material is determined by measuring the increase in temperature that attends the addition of thermal energy. In vegetative (green) roof systems, the material with the highest heat capacity is usually water.

3.2.36 *underflow, n*—water derived from rainfall or irrigation that percolates to the base of the vegetative (green) roof system profile and then flows horizontally through the drain layer toward roof discharge facilities such as area drains, scuppers, and gutters.

3.2.37 *vegetated (green) roof covering, n*—see *vegetative (green) roof system*, defined in Terminology **D1079**.

3.2.38 *vegetative (green) roof media, n*—materials that fulfill the role that natural soil would fulfill in at-grade landscape.

3.2.38.1 *Discussion*—To achieve specified requirements for weight, drainage, fertility, saturated water permeability, density, etc., vegetative (green) roof media is typically prepared as mixture of fine and coarse mineral aggregate, organic materials, and admixtures.

3.2.39 *vegetative (green) roof system weight, n*—see *dead load*.

4. Significance and Use

4.1 *Intended Use*—The intended use of this guide is to provide general information to practitioners in the fields of vegetative (green) roof design and construction. The guide encourages innovative but responsible vegetative (green) roof design, with a focus on performance and quality assurance. Numerical ranges, practical minimums, and benchmarks that are incorporated in the guide are intended for reference. Design requirements for specific projects vary and, therefore, qualified professionals may prepare designs with features that may vary from the recommendations contained in the guide. In all instances, vegetative (green) roof system designs shall conform to the applicable code requirements of federal, state, provincial, or local agencies with jurisdiction.

4.2 *Users*—Users of this guide include: planners, developers, architects, landscape architects, engineers, general contractors, subcontractors, owners, facility managers, financial organizations related to building industry, building materials and product manufacturers, government agencies including building officials, and other building professionals.

5. Principles Relative to Vegetative (Green) Roof Systems

5.1 *Design Intent and Building Function*—Vegetative (green) roof systems should contribute or enhance, or both, a

building's function/purpose. The design of the vegetative (green) roof system should be responsive to the project objectives.

5.2 *Sustainability*—Vegetative (green) roof systems should improve the sustainability of a building, including environmental, social, and economic impacts. **Appendix XI** provides a review of potential contributions that vegetative (green) roof systems may make toward achieving sustainability objectives.

5.3 Design Considerations:

5.3.1 *Maintenance*—All vegetative (green) roof systems shall be accompanied by a detailed written maintenance procedures manual, provided by the design professional, vegetative (green) roof installation company, or system manufacturer. Maintenance manuals should include instructions for operation of irrigation systems, where relevant, and directions for proper weeding and fertilization. These documents should also include methods for recognizing and dealing with commonly encountered problems, including: insect infestations, weed infestations, bare spots, wet spots, or areas with perennial surface water ponding. Depending on the vegetative (green) roof system and site conditions, provisions for employing temporary irrigation should also be addressed. Manuals should also include instructions for inspecting exposed elements of the roofing/waterproofing membrane system, most notably the drains. Minimum requirements for site visitations should be provided, including safety considerations for accessing rooftop areas. When applying nutrients, the type and method of fertilization should take into account the quality of stormwater runoff. Fertilization procedures using nitrogen-based fertilizers shall also address mitigation of eutrophication.

5.3.2 *Performance*—The design professional working on a vegetative (green) roof system shall convey to the owner a written description of the system, showing conformance with the specified performance characteristics. These descriptions include at minimum: (1) maximum or minimum associated dead load, (2) moisture retention capacity per hydrology study by the manufacturer, (3) assurances of the longevity of the vegetative (green) roof system, (4) assurances of the survival of the plant foliage cover, and (5) assurances that the roofing/waterproofing membrane is compatible with the selected vegetative (green) roof system and suitable for the application. Written descriptions of vegetative (green) roof system performance characteristics typically emanate from, and will be supported by, the manufacturer or provider of the vegetative (green) roof system.

5.3.3 *Longevity*—The longevity of vegetative (green) roof systems can be limited by: (1) degradation or loss of function of components of the vegetative (green) roof system, or (2) premature failure of the roofing/waterproofing membrane system. Consideration should be given to locating leaks and repairing the membrane. For novel designs or large-scale projects, mock-ups of vegetative (green) roof systems may be advisable. Exposed surfaces of the roofing/waterproofing membrane system (for example, flashings and penetrations) may become the most important factor in determining the longevity of an installation. Consideration should be given to providing protection for all surfaces of the roofing/

waterproofing membrane system. For instance, flashings should be protected with a durable and UV-resistant protection layer or counterflashing.

5.3.4 Structural Loads—The introduction of a vegetative (green) roof system to a new or existing structure has an effect on the live, dead, and seismic loads. The addition of materials associated with vegetative (green) roof systems usually increases the dead load in varying amounts based on the number, composition, and thickness of the layers of the system. Because of the transient water retention capacity of vegetative (green) roof systems, the live loads may increase as well. In accessible roofs, the live loads created by human occupants should be taken into account. Minimum live load allowances for access by pedestrians, as well as by maintenance personnel, apply in most jurisdictions. The additional dead and live load attributable to the vegetative (green) roof also contribute to the seismic mass of the building structure, substantially increasing the horizontal seismic response, as well as affecting the fundamental period. Consideration of appropriate loads is the responsibility of the design professional and shall be addressed before the vegetative (green) roof system is designed.

5.3.4.1 Take into account all components in the vegetative (green) roof system profile and include the weight of matured plants and retained moisture.

5.3.5 Roof Access—Building maintenance and other personnel shall be provided with a safe means of accessing the roof.

5.3.6 Equipment Access—When mechanical equipment is located on the roof, accommodations shall be made to provide safe access to that equipment. Determination shall be made that the vegetative (green) roof system will not interfere with equipment operation. Allowances shall be made for required clearances for working around and under the equipment. Hardscape may be used in these spaces to provide working areas. Measures shall be included to prevent damage to the vegetative (green) roof system caused by wash-down, ‘blow-down,’ or other discharges of fluids associated with operation or maintenance of mechanical equipment. Chemicals used in the operation or maintenance of mechanical equipment located in the field of a vegetative (green) roof system should not be phytotoxic to any of the designated plant varieties or damaging to the components of the vegetative (green) roof system.

5.3.7 Façade Access—In many instances, the roof serves as the primary point of façade access. Consideration should be given in vegetative (green) roof system design for access to façade rigging equipment, including the use of temporary equipment (beams and weights). If walkways and staging areas for façade maintenance are not provided, damage to the vegetative (green) roof system may result. Chemicals used for window and façade cleaning and maintenance should be reviewed prior to their use to determine if they are phytotoxic and may inhibit plant growth in areas affected by façade maintenance. Materials that will be phytotoxic to plant varieties designated for the vegetated (green) roof system should be replaced by alternative materials that are benign toward these plants.

5.3.8 Wind Resistance—Damage by wind is a concern with vegetative (green) roof system installations, particularly along perimeters and corners, at obstructions such as mechanical

equipment, and adjacent to penthouse structures. Guidance on wind design for vegetative (green) roof systems can be found in ANSI/SPRI RP-14. The potential for damage by wind will vary with building height, building geometry, geographic location, and local topography. The roofing system as a whole must resist wind uplift forces as required by code. In addition, the vegetative (green) roof system must resist wind damage to the exposed vegetative components, such as growth media being scoured away (specifically covered in 7.4). On vegetative roofs that are properly designed and maintained such that vegetation cover increases with time, probability of wind damage to the exposed vegetative components is greatest with high winds immediately after installation and diminishes as the vegetative (green) roof matures. Evaluation of the wind resistance of modular vegetative (green) roof systems (resistance to wind uplift as well as resistance to wind flow) can be performed using CAN/CSA A123.24. With many vegetative (green) roof systems, methods for temporarily protecting the media prior to establishment of a mature plant ground cover may be advisable. This may include mats or mesh fabricated from organic fibers or geosynthetics, tackifying agents, or the installation of pre-grown mats or modules. Various permanent stabilized leading-edge systems may be viable for a particular project, including: gravel or stone margins, unit pavers, strapped or bolted pavers, reinforced media layers, and buried ballasts in conjunction with reinforcing geotextiles. The width of stabilized leading-edge systems depends on the local wind environment, which is specific to each building and geographic setting. Measures shall comply with requirements of federal, state, provincial, or local entities with jurisdiction. Methodologies for determining ballast requirements often rely on estimates of wind velocities and uplift pressures based on ASCE/SEI 7. The dry weight should be used when evaluating the ballast weight of a vegetative (green) roof system. In some jurisdictions upper limits on basic wind speed (3-s gusts) may apply to inclusion of gravel or stone ballast, due to the risk of these becoming windborne missiles.

5.3.9 Fire Resistance—Just like any other roofing system, vegetative (green) roof systems must meet the fire classification required by code. In that regard, guidance is provided in ANSI/SPRI VF-1. In regions where wildfires are an identified threat, it is recommended that designs emphasize foliage cover consisting of succulent plants (for example, Sedum, Senecio, Delosperma, Graptopetalum, Echeveria, etc.), and the vegetative (green) roof system should be maintained to regularly remove dead or dormant grass and shrubs. Non-vegetated margins, consisting of coarse stone, gravel, concrete pavers, or stone pavers can be used to set back foliage-covered areas. Specifically, setbacks for plant foliage are recommended in the following situations: (1) walls immediately beneath the sills of operable windows, and (2) adjacent to hatchways, thresholds, and mechanical equipment. Non-vegetated setbacks are recommended for boundaries with roofing/waterproofing membrane systems that are not rated Class A, as determined by Test Methods E108, and for building surfaces constructed using materials that have not been successfully tested in accordance with Test Method E136. For vegetative (green) roof systems that are not rated Class A or B as determined by Test Methods

E108, additional precautions are recommended, including providing breaks in the vegetative (green) roof system that will limit the area of any contiguous, foliage-covered roof zone. Breaks may consist of concrete or masonry curbs that are taller than adjacent plant foliage or non-vegetated strips. Non-vegetated strips may consist of either: (1) coarse stone, gravel, concrete pavers, or stone pavers, or (2) roof covering rated Class A, as determined by Test Methods **E108**. All vegetative (green) roof systems should be provided with access to hose bibs, faucets, or an irrigation system that can provide sufficient water to allow the entire vegetative (green) roof system to be thoroughly soaked within an elapsed time of 2 h. Provisions for introducing fire-resistance measures shall comply with requirements of federal, state, provincial, or local entities with jurisdiction.

5.3.10 *Flashing*—To minimize the opportunity for water to gain entry through the roofing/waterproofing membrane system, minimum vertical isolation distances between the upper surface of the vegetative (green) roof cover and the top of the flashing is advised. These vertical isolation distances may vary with manufacturer and flashing type; some manufacturers require a minimum vertical isolation of 8 in. Vegetative (green) roof system profile thicknesses must be adjusted accordingly. If the recommended vertical isolation distance cannot be satisfied, then the vegetative (green) roof cover should be set back from the flashing using rigid edging.

5.3.11 *Leak Detection*—Design of the vegetative (green) roof system should include consideration of how leaks can be located and repaired. For example, compatibility of the roofing/waterproofing membrane system and other components of the vegetative (green) roof system with leak detection systems, as well as methods involving high and low-voltage electrical methods of leak detection, should be determined. Guidance on electric leak detection techniques can be found in Guide **D7877**.

5.3.12 *Drainage*—Vegetative (green) roof systems can be adversely affected by either excessive or insufficient drainage capacity. The first concern of the designer when addressing drainage should be to ensure that the vegetative (green) roof system can efficiently percolate and discharge the underflow associated with mandated design storms. Unless specifically designed to generate surface runoff, vegetative (green) roofs systems should not experience ponding or surface flow when subjected to rainfall events that would be normal for a typical year. Prior to installation of overburden materials, the completed roofing membrane should be inspected to confirm satisfactory drainage conditions of the roofing system. All drains and scuppers should be isolated by a filter fabric, or other appropriate means, to protect from clogging caused by the accumulation of foliage or debris. Conventional ‘beehive’ or ‘bonnet’ strainers are not suitable for this purpose. Chambers with removable lids are recommended for use at all drains and scuppers. Surrounding all drains and scuppers and along depressions where underflow concentrates, coarse stone aggregate should be placed to facilitate percolation and horizontal flow toward the drainage facilities. The designer should avoid excessive drainage of the vegetative (green) roof system which

may lead to perennially stressed conditions for the plants and, in extreme conditions, plant mortality.

5.3.13 *Freeze-Thaw Cycling*—Vegetative (green) roof systems, especially those with areas open to air below, can be adversely affected by freeze-thaw cycling. In cold weather, water can percolate through the soil over an enclosed area until it reaches an area where the temperature drops. When the water reaches the colder roof, it can refreeze and form a dam. This prevents upstream water from being able to drain and in turn adds to the weight of the roof. To avoid this situation, roofs over colder areas may require additional design loads or some type of heating to keep water from freezing.

5.3.14 *Soil Creep*—The growing media in vegetative (green) roof systems can, over time, redistribute its mass. Maintenance plans discussed in **5.3.1** should allow for periodic inspections of the media, including depth sampling as well as instructions for re-grading of the surface when the soil depths get beyond those for which they were designed.

6. Quality Assurance

6.1 *Specifications*—Specifications should clearly define the performance requirements for the vegetative (green) roof system, identify the relevant properties of constituent components, identify hazardous conditions, and include appropriate procedures to monitor construction, provide a safe working environment, and provide ongoing maintenance.

6.1.1 *Performance Requirements*—Performance requirements may vary. However, where vegetative (green) roof systems have been selected with specific objectives in mind, these should be included in the specification. Where specific energy conservation or stormwater control objectives are important, civil engineering reports, supporting computations, field data, or computer simulations should be required of providers of vegetative (green) roof systems.

6.1.2 *Submittals*—Properties cited in specifications should be relevant to the successful performance of the vegetative (green) roof system. To the extent practical, specifications should provide ranges of acceptable performance, or design minimums and maximums.

6.1.2.1 For materials and components that are unique to vegetative (green) roofs, contractors should provide certifications by manufacturers that any tests have been successfully performed by an independent laboratory and that their products comply with the specification.

6.1.2.2 For vegetative (green) roof media, samples should be accompanied by certified statements by the manufacturer/blender—or recent tests by an independent laboratory—demonstrating compliance with the specifications. Since the characteristics of feed stocks such as ESCS and compost may vary over time, tests for specific media formulations should be conducted on a periodic basis.

6.1.3 *Maintenance Program*—Contract documents should be specific concerning the maintenance requirements and responsibilities of the vegetative (green) roof system installer or system manufacturer. For example:

6.1.3.1 Procedures for leak detection and repair, as necessary, for the roofing/waterproofing membrane.