

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE

**High-voltage switchgear and controlgear –  
Part 200: AC metal-enclosed switchgear and controlgear for rated voltages  
above 1 kV and up to and including 52 kV**

**Appareillage à haute tension –  
Partie 200: Appareillage sous enveloppe métallique pour courant alternatif  
de tensions assignées supérieures à 1 kV et inférieures ou égales à 52 kV**

<https://standards.iteh.ai/catalog/standards/iec/1-1-16-11b-f58e-4aa4-bab7-efeb45b960b1/iec-62271-200-2003>

WILEY-SON



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2003 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland  
Email: [inmail@iec.ch](mailto:inmail@iec.ch)  
Web: [www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: [www.iec.ch/webstore/custserv](http://www.iec.ch/webstore/custserv)

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: [csc@iec.ch](mailto:csc@iec.ch)

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

### A propos de la CEI

La Commission Electrotechnique internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: [www.iec.ch/searchpub/cur\\_fut-f.htm](http://www.iec.ch/searchpub/cur_fut-f.htm)

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: [www.iec.ch/webstore/custserv/custserv\\_entry-f.htm](http://www.iec.ch/webstore/custserv/custserv_entry-f.htm)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: [csc@iec.ch](mailto:csc@iec.ch)

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

**High-voltage switchgear and controlgear –  
Part 200: AC metal-enclosed switchgear and controlgear for rated voltages  
above 1 kV and up to and including 52 kV**

**Appareillage à haute tension –  
Partie 200: Appareillage sous enveloppe métallique pour courant alternatif  
de tensions assignées supérieures à 1 kV et inférieures ou égales à 52 kV**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

PRICE CODE  
CODE PRIX

**XC**

## CONTENTS

FOREWORD .....	5
1 General.....	9
1.1 Scope .....	9
1.2 Normative references.....	10
2 Normal and special service conditions .....	11
3 Terms and definitions.....	11
4 Ratings .....	17
4.1 Rated voltage ( $U_r$ ).....	17
4.2 Rated insulation level .....	17
4.3 Rated frequency ( $f_r$ ) .....	17
4.4 Rated normal current and temperature rise .....	17
4.5 Rated short-time withstand current ( $I_k$ ).....	18
4.6 Rated peak withstand current ( $I_p$ ).....	18
4.7 Rated duration of short circuit ( $t_k$ ).....	18
4.8 Rated supply voltage of closing and opening devices and of auxiliary and control circuits ( $U_a$ ).....	18
4.9 Rated supply frequency of closing and opening devices and of auxiliary circuits.....	18
4.10 Rated pressure of compressed gas supply for insulation and/or operation.....	18
4.10.1 Rated filling level (of fluid-filled compartments).....	18
5 Design and construction .....	19
5.1 Requirements for liquids in switchgear and controlgear .....	19
5.2 Requirements for gases in switchgear and controlgear .....	19
5.3 Earthing .....	19
5.4 Auxiliary and control equipment.....	21
5.5 Dependent power operation .....	21
5.6 Stored energy operation.....	21
5.7 Independent manual operation .....	21
5.8 Operation of releases.....	21
5.9 Low- and high-pressure interlocking and monitoring devices.....	21
5.10 Nameplates.....	21
5.11 Interlocking devices .....	22
5.12 Position indication.....	23
5.13 Degrees of protection by enclosures.....	23
5.14 Creepage distances .....	23
5.15 Gas and vacuum tightness .....	23
5.16 Liquid tightness.....	24
5.17 Flammability .....	24
5.18 Electromagnetic compatibility (EMC) .....	24
6 Type tests .....	30
6.1 General .....	30
6.2 Dielectric tests .....	32
6.3 Radio interference voltage (r.i.v.) test.....	35
6.4 Measurement of the resistance of circuits.....	36
6.5 Temperature-rise tests.....	38
6.6 Short-time withstand current and peak withstand current tests.....	37

6.7	Verification of the protection.....	39
6.8	Tightness tests .....	39
6.9	Electromagnetic compatibility tests (EMC).....	39
6.10	Additional tests on auxiliary and control circuits .....	39
7	Routine tests.....	43
7.1	Dielectric test on the main circuit.....	44
7.2	Tests on auxiliary and control circuits .....	44
7.3	Measurement of the resistance of the main circuit .....	44
7.4	Tightness test .....	44
7.5	Design and visual checks .....	44
8	Guide to the selection of metal-enclosed switchgear and controlgear for service.....	46
8.1	Selection of rated values.....	46
8.2	Selection of design and construction .....	46
8.3	Internal arc classification.....	49
9	Information to be given with enquiries, tenders and orders.....	53
10	Rules for transport, storage, installation, operation and maintenance.....	55
10.1	Conditions during transport, storage and installation.....	55
10.2	Installation .....	55
10.3	Operation.....	55
10.4	Maintenance .....	55
11	Safety.....	56
Annex A (normative) Internal fault – Method for testing the metal-enclosed switchgear and controlgear under conditions of arcing due to an internal fault .....		57
A.1	Introduction.....	57
A.2	Types of accessibility .....	58
A.3	Test arrangements.....	58
A.4	Current and voltage applied.....	62
A.5	Test procedure.....	63
A.6	Acceptance criteria.....	64
A.7	Test report.....	65
A.8	Designation of IAC classification.....	66
Annex B (normative) Partial discharge measurement .....		73
B.1	General.....	73
B.2	Application .....	73
B.3	Test circuits and measuring instruments.....	74
B.4	Test procedure.....	74
B.5	Maximum permissible partial discharge quantity .....	75
Annex C (informative) Explanatory notes .....		79
C.1	Changes in classifications, compared to the third edition (1990) of IEC 60298 .....	79
C.2	ANSI defined metal-clad.....	82

C.3 Former IEC defined metal-clad in terms of IEC 62271-200 definitions .....	82
C.4 Example of modular fuse-switch type.....	83
Bibliography .....	85
Figure A.1 – Mounting frame for vertical indicators.....	67
Figure A.2 – Horizontal indicator .....	67
Figure A.3 – Position of the indicators.....	68
Figure A.4 – Room simulation and indicator positioning for accessibility A, functional unit at or above 1,5 m.....	69
Figure A.5 – Room simulation and indicator positioning for accessibility B, functional unit above 2 m high .....	70
Figure A.6 – Room simulation and indicator positioning for accessibility B, functional unit below 2 m high .....	71
Figure A.7 – Test arrangement for overhead connected pole-mounted switchgear and controlgear.....	72
Figure B.1 – Partial discharge test circuit (three-phase arrangement).....	77
Figure B.2 – Partial-discharge test circuit (system without earthed neutral).....	78
Table 1 – Nameplate information .....	21
Table 2– Locations, causes and examples of measures to decrease the probability of internal faults .....	50
Table 3 – Summary of technical requirements, ratings and optional tests for metal enclosed switchgear .....	51
Table B.1 – Test circuits and procedures .....	76
Table C.1 – Comparison of IEC and IEEE definition of metal-clad .....	79
Table C.2 – Classification related to personnel safety in case of internal arc .....	80

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

## HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

**Part 200: AC metal-enclosed switchgear and controlgear  
for rated voltages above 1 kV and up to and including 52 kV**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62271-200 has been prepared by subcommittee 17C: High-voltage switchgear and controlgear assemblies, of IEC technical committee 17: Switchgear and controlgear.

This first edition of IEC 62271-200 cancels and replaces the third edition of IEC 60298, published in 1990, and constitutes a technical revision.

Significant technical changes from the third edition of IEC 60298 are as follows:

This revised document has been basically changed to be updated to today's use of high-voltage switchgear and controlgear up to 52 kV. The main changes are: new definitions and classification of equipment, introduction of internal arc classes (IAC) and its testing.

This standard is to be read in conjunction with IEC 60694<sup>1</sup> published in 1996. Clause numbering follows the clause numbering of that standard. Additional subclauses, as they relate to a particular clause or subclause from IEC 60694, are numbered 101, 102, etc.

The text of this standard is based on the following documents:

FDIS	Report on voting
17C/311/FDIS	17C/315/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until 2009. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

Withdrawing

iTeh Standards  
(<https://standards.itih.ai>)  
Document Preview

<https://standards.itih.ai/iec/62271-200:2003>

<https://standards.itih.ai/iec/62271-200:2003>

---

<sup>1</sup> IEC 60694 (1996) will be replaced by IEC 62271-1 as soon as available.



**COMMON NUMBERING OF IEC 62271 PUBLICATIONS FALLING UNDER  
THE RESPONSIBILITY OF SUBCOMMITTEES SC 17A AND SC 17C**

In accordance with the decision taken at the joint SC 17A/SC 17C meeting in Frankfurt, June 1998 (item 20.7 of 17A/535/RM), a common numbering system has been established for the publications falling under the responsibility of SC 17A and SC 17C. IEC 62271 – *High-voltage switchgear and controlgear* is the publication number and main title element for the common publications.

The numbering of these publications will apply the following principle.

- a) Common standards prepared by SC 17A and SC 17C will start with IEC 62271-1.
- b) Standards of SC 17A will start with IEC 62271-100.
- c) Standards of SC 17C will start with number IEC 62271-200.
- d) Publications prepared by SC 17A and SC 17C will start with number IEC 62271-300.

The table below relates the new numbers to the old numbers. The parts numbered (xxx) will be given a final number pending the decision to publish the revised publication as standard or technical report.

iTeh Standards  
(<https://standards.itih.ai>)  
Document Preview

[IEC 62271-200:2003](https://standards.itih.ai/iec-62271-200:2003)

<https://standards.itih.ai/iec-62271-200:2003>

**Common numbering of IEC 62271 publications falling under the responsibility of subcommittees SC 17A and SC 17C**

<b>IEC 62271 series</b>	<b>HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR</b>	<b>Old IEC number, if any</b>
<b>Part</b>	<b>New title</b>	
1	Common specifications	IEC 60694
2	Seismic qualification for rated voltages of 72,5 kV and above	-
100	High-voltage alternating current circuit-breakers	IEC 60056
101	Synthetic testing	IEC 60427
102	High-voltage alternating current disconnectors and earthing switches	IEC 60129
103	Switches for rated voltages above 1 kV and less than 52 kV	IEC 60265-1
104	Switches for rated voltages of 52 kV and above	IEC 60265-2
105	Alternating current switch-fuse combinations	IEC 60420
106	Alternating current contactors and contactor-based motor-starters	IEC 60470
107	Alternating current switchgear-fuse combinations	-
108	Switchgear having combined functions	-
109	Series capacitor by-pass switches	-
200	AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV	IEC 60298
201	Insulation-enclosed switchgear and controlgear for rated voltages up to and including 52 kV	IEC 60466
202	High-voltage/low-voltage prefabricated substations	IEC 61330
203	Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV	IEC 60517
204	High-voltage gas-insulated transmission lines for rated voltages of 72,5 kV and above	IEC 61640
(300)	Guide for seismic qualification of high-voltage alternating current circuit-breakers	IEC 61166
(301)	Guide for inductive load switching	IEC 61233
(302)	Guide for short-circuit and switching test procedures for metal-enclosed and dead tank circuit-breakers	IEC 61633
(303)	Use and handling of sulphur hexafluoride (SF <sub>6</sub> ) in high-voltage switchgear and controlgear	IEC 61634
(304)	Additional requirements for enclosed switchgear and controlgear from 1 kV to 72,5 kV to be used in severe climatic conditions	IEC 60932
(305)	Cable connections for gas-insulated metal-enclosed switchgear for rated voltages above 52 kV	IEC 60859
(306)	Direct connection between power transformers and gas-insulated metal-enclosed switchgear for rated voltages above 52 kV	IEC 61639
(307)	Use of electronic and associated technologies in auxiliary equipment of switchgear and controlgear	IEC 62063
308	Guide for asymmetrical short-circuit breaking test duty T100a	-
309	TRV parameters for high-voltage switchgear and controlgear for rated voltages above 1 kV and less than 100 kV	-
310	Electrical endurance testing for circuit-breakers rated 72,5 kV and above	-

## HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

### Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

#### 1 General

##### 1.1 Scope

This part of IEC 62271 specifies requirements for factory-assembled metal-enclosed switchgear and controlgear for alternating current of rated voltages above 1 kV and up to and including 52 kV for indoor and outdoor installation, and for service frequencies up to and including 60 Hz. Enclosures may include fixed and removable components and may be filled with fluid (liquid or gas) to provide insulation.

NOTE 1 Although primarily dedicated to three-phase systems, this standard can also be applied to single-phase or two-phase systems.

This standard defines several types of metal enclosed switchgear and controlgear which differ due to

- the consequences on network service continuity in case of maintenance on the switchgear and controlgear;
- the need and convenience of maintenance of the equipment.

NOTE 2 Safety of an installation results from the design, implementation and coordination of products, installations and operations.

For metal-enclosed switchgear and controlgear containing gas-filled compartments, the design pressure is limited to a maximum of 300 kPa (relative pressure).

NOTE 3 Gas-filled compartments having a design pressure exceeding 300 kPa (relative pressure) should be designed and tested in accordance with IEC 60517.

Metal-enclosed switchgear and controlgear for special use, for example, in flammable atmospheres, in mines or on board ships, may be subject to additional requirements.

Components contained in metal-enclosed switchgear and controlgear are to be designed and tested in accordance with their various relevant standards. This standard supplements the standards for the individual components regarding their installation in switchgear and controlgear assemblies.

This standard does not preclude that other equipment may be included in the same enclosure. In such a case, any possible influence of that equipment on the switchgear and controlgear is to be taken into account.

NOTE 4 Switchgear and controlgear assemblies having an insulation enclosure are covered by IEC 60466.

NOTE 5 Metal-enclosed switchgear and controlgear for rated voltages above 52 kV insulated by ambient air may be covered by this standard taking into account the insulation levels of IEC 60694.

## 1.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050(151):2001, *International Electrotechnical Vocabulary – Chapter 151: Electrical and magnetic devices*

IEC 60050(441):1984, *International Electrotechnical Vocabulary – Chapter 441: Switchgear, controlgear and fuses*

IEC 60060-1:1989, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60243-1:1998, *Electrical strength of insulating materials – Test methods – Part 1: Tests at power frequencies*

IEC 60265-1:1998, *High-voltage switches – Part 1: Switches for rated voltages above 1 kV and less than 52 kV*

IEC 60270:2000, *High-voltage test techniques – Partial discharge measurements*

IEC 60466:1987, *AC insulation-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 38 kV*

IEC 60470:2000, *High-voltage alternating current contactors and contactor-based motor-starters*

IEC 60480:1974, *Guide to the checking of sulphur hexafluoride (SF<sub>6</sub>) taken from electrical equipment*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

<https://standards.iteh.ai/> IEC 60694:1996, *Common specifications for high-voltage switchgear and controlgear standards*

IEC 60909-0:2001, *Short-circuit currents in three-phase a.c. systems – Part 0: Calculation of currents*

IEC 60932:1988, *Additional requirements for enclosed switchgear and controlgear from 1 kV to 72,5 kV to be used in severe climatic conditions*

IEC 61634:1995, *High-voltage switchgear and controlgear – Use and handling of sulphur hexafluoride (SF<sub>6</sub>) in high-voltage switchgear and controlgear*

IEC 62271-100:2001, *High-voltage alternating-current circuit-breakers*

IEC 62271-102:2001, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

IEC 62271-105:2002, *High-voltage switchgear and controlgear – Part 105: Alternating current switch-fuse combinations*

ISO/IEC Guide 51:1999, *Safety aspects – Guidelines for their inclusion in standards*

## 2 Normal and special service conditions

Clause 2 of IEC 60694 is applicable with the following addition:

Unless otherwise specified in this standard, the metal-enclosed switchgear and controlgear is designed to be used under normal service conditions.

## 3 Terms and definitions

For the purposes of this document, the following definitions as well as the definitions of IEC 60050(441), IEC 60050(151) and IEC 60694 apply, except where indicated. Some standard definitions are recalled here for ease of reference.

Additional definitions are classified so as to be aligned with the classification system used in IEC 60050(441).

### 3.101

#### **switchgear and controlgear**

general term covering switching devices and their combination with associated control, measuring, protective and regulating equipment, also assemblies of such devices and equipment with associated interconnections, accessories, enclosures and supporting structures

[IEV 441-11-01]

### 3.102

#### **metal-enclosed switchgear and controlgear**

switchgear and controlgear assemblies with an external metal enclosure intended to be earthed and completely assembled, except for external connections

[IEV 441-12-04, modified]

### 3.103

#### **functional unit (of an assembly)**

part of metal-enclosed switchgear and controlgear comprising all the components of the main circuits and auxiliary circuits that contribute to the fulfilment of a single function

[IEV 441-13-04, modified]

NOTE Functional units may be distinguished according to the function for which they are intended, for example, incoming unit, outgoing unit, etc.

### 3.104

#### **multi-tier**

two or more functional units arranged vertically within a single enclosure

### 3.105

#### **transport unit**

part of metal-enclosed switchgear and controlgear suitable for shipment without being dismantled

### 3.106

#### **enclosure**

part of metal-enclosed switchgear and controlgear providing a specified degree of protection of equipment against external influences and a specified degree of protection against approach to or contact with live parts and against contact with moving parts

[IEV 441-13-01 modified]

### **3.107**

#### **compartment**

part of metal-enclosed switchgear and controlgear enclosed except for openings necessary for interconnection, control or ventilation

[IEV 441-13-05, modified]

Four types of compartments are distinguished, three that can be opened, called accessible (see 3.107.1 to 3.107.3) and one that cannot be opened, called non-accessible (see 3.107.4)

NOTE Compartments are identified according to the main component(s) contained therein (refer to 5.103.1).

#### **3.107.1**

##### **interlock-controlled accessible compartment**

compartment containing high-voltage parts, intended to be opened for normal operation and/or normal maintenance as stated by the manufacturer, in which access is controlled by integral design of the switchgear and controlgear

NOTE Installation, extension, repairing, etc. are not considered as normal maintenance.

#### **3.107.2**

##### **procedure-based accessible compartment**

compartment containing high-voltage parts, intended to be opened for normal operation and/or normal maintenance as stated by the manufacturer, in which access is controlled by a suitable procedure combined with locking

NOTE Installation, extension, repairing, etc. are not considered as normal maintenance.

#### **3.107.3**

##### **tool-based accessible compartment**

compartment containing high-voltage parts, that may be opened, but not for normal operation and maintenance. Special procedures are required. Tools are necessary for opening

#### **3.107.4**

##### **non-accessible compartment**

compartment containing high-voltage parts that must not be opened. Opening may destroy the integrity of the compartment. Clear indication not to open is provided on/by the compartment

### **3.108**

#### **partition**

part of metal-enclosed switchgear and controlgear separating one compartment from other compartments

[IEV 441-13-06, modified]

### **3.109**

#### **partition class**

class defining whether metallic or non-metallic material for separation to live parts is used

#### **3.109.1**

##### **partition class PM**

metal-enclosed switchgear and controlgear providing continuous metallic partitions and/or shutters (if applicable), intended to be earthed, between opened accessible compartments and live parts of the main circuit