



Designation: **C1320 – 10 (Reapproved 2016) C1320 – 20**

Standard Practice for Installation of Mineral Fiber Batt and Blanket Thermal Insulation for Light Frame Construction¹

This standard is issued under the fixed designation C1320; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice covers procedures for the installation of mineral fiber batt and blanket thermal insulation in ceilings, attics, floors, and walls of new or existing housing and other light frame construction.

1.2 This practice covers the installation process from pre-installation inspection through post-installation inspection. It does not cover the production of the insulation materials.

1.3 This practice is not intended to replace installation instructions by manufacturers, but it shall be used in conjunction with such instructions. This practice is not intended to supersede local, state, or federal codes.

1.4 This practice assumes that the installer possesses a working knowledge of applicable codes and regulations, safety practices, tools, equipment, and methods necessary for the installation of thermal insulation materials. It also assumes that the installer understands the fundamentals of construction that affect the installation of insulation.

1.5 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

1.6 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.7 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 ASTM Standards:²

[C168 Terminology Relating to Thermal Insulation](#)

[C665 Specification for Mineral-Fiber Blanket Thermal Insulation for Light Frame Construction and Manufactured Housing](#)

[C755 Practice for Selection of Water Vapor Retarders for Thermal Insulation](#)

[D3833/D3833M Test Method for Water Vapor Transmission of Pressure-Sensitive Tapes](#)

[E84 Test Method for Surface Burning Characteristics of Building Materials](#)

2.2 Other Standards:

[NFPA-31 Standard for the Installation of Oil Burning Equipment](#)³

[NFPA-54 National Fuel Gas Code](#)³

[NFPA-70 National Electric Code](#)³

[NFPA-211 Standard for Chimneys, Fireplaces, Vents and Solid-Fuel Burning Appliances](#)³

[ICC International Residential Code](#)⁴

[CPSC Product Safety Fact Sheet No. 518 “The Home Electrical System”](#)⁵

¹ This practice is under the jurisdiction of ASTM Committee C16 on Thermal Insulation and is the direct responsibility of Subcommittee C16.23 on Blanket and Loose Fill Insulation.

Current edition approved March 1, 2016; March 1, 2020. Published March 2016; March 2020. Originally approved in 1995. Last previous edition approved in 2010 as C1320 – 10; C1320 – 10 (2016). DOI: 10.1520/C1320-10R16; 10.1520/C1320-20.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, MA 02169-7471, <http://www.nfpa.org>.

⁴ Available from International Code Council (ICC), 500 New Jersey Ave., NW, 6th Floor, Washington, DC 20001-2070, <http://www.iccsafe.org>.

⁵ Available from U.S. Consumer Product Safety Commission (CPSC), 4330 East West Hwy., Bethesda, MD 20814, <http://www.cpsc.gov>.

3. Terminology

3.1 *Definitions*—Definitions relating to thermal insulation in Terminology **C168** apply to terms used in this practice.

3.2 *Description of Terms Specific to This Standard:*

3.2.1 *conditioned space*—space in a building that is served by a heating or cooling system.

3.2.2 *installer*—the person or persons who apply thermal insulation materials in buildings whether or not such person or persons have contracted with the owner to perform the work.

3.2.3 *mineral fiber batt and blanket thermal insulating materials*—those materials that meet the minimum requirements set forth in Specification **C665**.

3.2.4 *owner*—the person, partnership, corporation, agency, or other entity who owns the building to be insulated whether such ownership is by virtue of deed, contract, or any other instrument for acquiring legal title under the laws of the State in which the building is located.

3.2.5 *vapor retarder*—membrane or tape that has a water vapor permeance (perm) rating of 1 perm ($5.7 \times 10^{-11} \text{ kg} \cdot \text{Pa}^{-1} \cdot \text{s}^{-1} \cdot \text{m}^{-2}$) or less as defined in Practice **C755** or Test Method **D3833/D3833M** respectively.

4. Significance and Use

4.1 This practice recognizes that effectiveness, safety, and durability of insulation depend not only on the quality of the insulating materials but also on their proper installation.

4.2 This practice provides general procedures that will help to ensure installation of insulation in a safe and effective manner. It shall be noted that actual conditions in existing buildings vary greatly and in some cases additional care shall be taken to ensure effective and safe installation.

5. Safety Precautions

5.1 The installer shall wear proper clothing and equipment as recommended by the insulation manufacturer.

5.2 In areas where insulation is to be installed, components of the electrical system shall be in good condition. If there is reason to believe the electrical system is faulty, do not install insulation in such areas until the owner has been informed and repair has been accomplished.

NOTE 1—The CPSC Product Safety Fact Sheet No. 518 has identified the following signs of electrical deficiencies: lights dimming, fuses blowing, circuit breakers tripping frequently, electrical sparks and “glowing” from receptacles, light flickering, and coverplates on switches and outlets that are warm or hot to the touch.

6. Pre-installation Inspection and Preparation

6.1 Inspect the roof, walls, ceilings, and attic floors to identify areas where previous or existing moisture problems have caused paint peeling, warpage, staining, visible fungus growth, rotting, or other structural damage. Do not install insulation in such areas until the owner has been informed and has certified that these conditions have been corrected and their source(s) of moisture eliminated.

6.2 Provide proper attic ventilation in accordance with local building requirements or practices, such as the ICC International Residential Code.

6.3 When the attic has soffit vents at the eaves, make provisions to prevent insulation from blocking the vents and restricting attic ventilation.

6.4 Where insulation is to be installed beneath floors over crawl spaces or on crawl space walls, cover the ground surface with a vapor retarder.

6.5 Provide proper crawl space ventilation in accordance with local building requirements or practices, such as the ICC International Residential Code.

6.6 Inspect attic floors for openings that might permit entrance of air from conditioned spaces below. Do not install insulation in such areas until the owner has been informed and has certified that these conditions have been corrected.

7. Installation Procedures

7.1 *General:*

7.1.1 Handle the insulation material in accordance with the manufacturer’s instructions and keep free of extraneous materials. Keep materials dry, off the ground, and protected from water.

7.1.2 It is difficult to describe every situation that will be encountered by the insulation installer. In general, however, the installer shall be guided by the need to reduce heat flow around or through obstructions and to protect mechanical systems. Wherever insulation is installed in a building, it is very important that it fit snugly on all sides. If the insulation is too long for a space, cut it to the correct size. If it is too short, cut a piece to fill the void.