

INTERNATIONAL STANDARD



This extended version of IEC 61439-4:2023 includes the content of the references made to IEC 61439-1:2020

**Low-voltage switchgear and controlgear assemblies –
Part 4: Particular requirements for assemblies for construction sites (ACS)**

Itch Standards
(<https://standards.itech.ai>)
Document Preview

[IEC 61439-4:2023](https://standards.itech.ai/catalog/standards/iec/eff9c3b6-8e7c-4867-93d4-36536a956fde/iec-61439-4-2023)

<https://standards.itech.ai/catalog/standards/iec/eff9c3b6-8e7c-4867-93d4-36536a956fde/iec-61439-4-2023>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2023 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

International Standards
standards.iteh.ai
Document Preview

[IEC 61439-4:2023](https://standards.iteh.ai/catalog/standards/iec/eff9c3b6-8e7c-4867-93d4-36536a956fde/iec-61439-4-2023)

<https://standards.iteh.ai/catalog/standards/iec/eff9c3b6-8e7c-4867-93d4-36536a956fde/iec-61439-4-2023>

INTERNATIONAL STANDARD



This extended version of IEC 61439-4:2023 includes the content of the references made to IEC 61439-1:2020

**Low-voltage switchgear and controlgear assemblies –
Part 4: Particular requirements for assemblies for construction sites (ACS)**

**(<https://standards.iteh.ai>)
Document Preview**

[IEC 61439-4:2023](https://standards.iteh.ai/catalog/standards/iec/eff9c3b6-8e7c-4867-93d4-36536a956fde/iec-61439-4-2023)

<https://standards.iteh.ai/catalog/standards/iec/eff9c3b6-8e7c-4867-93d4-36536a956fde/iec-61439-4-2023>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.130.20

ISBN 978-2-8322-7709-6

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	8
INTRODUCTION.....	11
1 Scope.....	12
2 Normative references	12
3 Terms and definitions	15
3.1 General terms	16
3.2 Constructional units of assemblies.....	18
3.3 External design of assemblies.....	19
3.4 Structural parts of assemblies.....	20
3.5 Conditions of installation of assemblies	22
3.6 Insulation characteristics	22
3.7 Protection against electric shock.....	25
3.8 Characteristics.....	29
3.9 Verification	33
3.10 Manufacturer	33
3.101 Function of the ACS.....	34
4 Symbols and abbreviations.....	34
5 Interface characteristics	35
5.1 General.....	35
5.2 Voltage ratings.....	35
5.2.1 Rated voltage (U_n) (of the assembly).....	35
5.2.2 Rated operational voltage (U_e) (of a circuit of an assembly)	36
5.2.3 Rated insulation voltage (U_i) (of a circuit of an assembly).....	36
5.2.4 Rated impulse withstand voltage (U_{imp}) (of the assembly)	36
5.3 Current ratings.....	36
5.3.1 Rated current of an ACS (I_{nA}).....	36
5.3.2 Rated current of a main outgoing circuit (I_{nc})	36
5.3.3 Group rated current of a main circuit (I_{ng}).....	37
5.3.4 Rated peak withstand current (I_{pk})	37
5.3.5 Rated short-time withstand current (I_{cw}) (of a main circuit of an assembly).....	37
5.3.6 Rated conditional short-circuit current (I_{cc}) (of an assembly or a circuit of an assembly)	38
5.4 Rated diversity factor (RDF).....	38
5.5 Rated frequency (f_n).....	38
5.6 Other characteristics.....	38
6 Information	39
6.1 ACS designation marking.....	39
6.2 Documentation.....	39
6.2.1 Information relating to the ACS.....	39
6.2.2 Instructions for handling, installation, operation and maintenance.....	40
6.3 Device and/or component identification.....	41
7 Service conditions	41
7.1 Normal service conditions	41
7.1.1 Climatic conditions	41
7.1.2 Pollution degree	41

7.2	Special service conditions.....	42
7.3	Conditions during transport, storage and installation.....	42
8	Constructional requirements.....	42
8.1	Strength of materials and parts.....	42
8.1.1	General.....	42
8.1.2	Protection against corrosion.....	43
8.1.3	Properties of insulating materials.....	43
8.1.4	Resistance to ultra-violet (UV) radiation.....	44
8.1.5	Mechanical strength.....	44
8.1.6	Lifting provision.....	44
8.2	Degree of protection provided by an assembly enclosure.....	44
8.2.1	Protection against mechanical impact (IK code).....	44
8.2.2	Protection against contact with live parts, ingress of solid foreign bodies and water (IP code).....	45
8.2.3	Assembly with removable parts.....	45
8.3	Clearances and creepage distances.....	45
8.3.1	General.....	45
8.3.2	Clearances.....	46
8.3.3	Creepage distances.....	46
8.4	Protection against electric shock.....	47
8.4.1	General.....	47
8.4.2	Basic protection.....	47
8.4.3	Fault protection.....	48
8.4.4	Additional requirements for class II assemblies.....	51
8.4.5	Limitation of steady-state touch currents and charge.....	51
8.4.6	Operating and servicing conditions.....	52
8.5	Incorporation of switching devices and components.....	52
8.5.1	Fixed parts.....	52
8.5.2	Removable parts.....	52
8.5.3	Selection of switching devices and components.....	52
8.5.4	Installation of switching devices and components.....	53
8.5.5	Accessibility.....	53
8.5.6	Barriers.....	53
8.5.7	Direction of operation and indication of switching positions.....	54
8.5.8	Indicator lights and push-buttons.....	54
8.5.9	Power factor correction banks.....	54
8.5.101	Accessible parts of ACS.....	54
8.6	Internal electrical circuits and connections.....	54
8.6.1	Main circuits.....	54
8.6.2	Auxiliary circuits.....	55
8.6.3	Bare and insulated conductors.....	55
8.6.4	Selection and installation of non-protected live conductors to reduce the possibility of short-circuits.....	56
8.6.5	Identification of the conductors of main and auxiliary circuits.....	56
8.6.6	Identification of the protective conductor (PE, PEL, PEM, PEN) and of the neutral conductor (N) and the mid-point conductor (M) of the main circuits.....	56
8.6.7	Conductors in AC circuits passing through ferromagnetic enclosures or plates.....	57
8.7	Cooling.....	57

8.8	Terminals for external cables	57
8.101	Supports and securing devices of ACS	58
8.102	Cable outlet	59
9	Performance requirements	59
9.1	Dielectric properties	59
9.1.1	General	59
9.1.2	Power-frequency withstand voltage	59
9.1.3	Impulse withstand voltage	59
9.1.4	Protection of surge protective devices	60
9.2	Temperature-rise limits	60
9.2.1	General	60
9.2.2	Adjustment of rated currents for alternative ambient air temperatures.....	60
9.3	Short-circuit protection and short-circuit withstand strength	61
9.3.1	General	61
9.3.2	Information concerning short-circuit withstand strength.....	61
9.3.3	Relationship between peak current and short-time current.....	61
9.3.4	Coordination of protective devices	62
9.4	Electromagnetic compatibility (EMC).....	62
10	Design verification	62
10.1	General.....	62
10.2	Strength of materials and parts	64
10.2.1	General	64
10.2.2	Resistance to corrosion	64
10.2.3	Properties of insulating materials.....	66
10.2.4	Resistance to ultraviolet (UV) radiation.....	67
10.2.5	Lifting	68
10.2.6	Verification of mechanical strength	69
10.2.7	Marking	70
10.2.8	Mechanical operation.....	71
10.3	Degree of protection of assemblies (IP Code)	71
10.4	Clearances and creepage distances.....	72
10.5	Protection against electric shock and integrity of protective circuits	72
10.5.1	General	72
10.5.2	Effective earth continuity between the exposed-conductive-parts of the class I assembly and the protective circuit.....	72
10.5.3	Short-circuit withstand strength of the protective circuit	73
10.6	Incorporation of switching devices and components	73
10.6.1	General	73
10.6.2	Electromagnetic compatibility	74
10.7	Internal electrical circuits and connections	74
10.8	Terminals for external conductors	74
10.9	Dielectric properties	74
10.9.1	General	74
10.9.2	Power-frequency withstand voltage	74
10.9.3	Impulse withstand voltage	75
10.9.4	Testing of enclosures made of insulating material.....	77
10.9.5	External door or cover mounted operating handles of insulating material	77
10.9.6	Testing of conductors and hazardous live parts covered by insulating material to provide protection against electric shock.....	78

10.10	Temperature-rise	78
10.10.1	General	78
10.10.2	Verification by testing	78
10.10.3	Verification by comparison.....	85
10.10.4	Verification assessment.....	87
10.11	Short-circuit withstand strength.....	87
10.11.1	General	87
10.11.2	Circuits of assemblies which are exempted from the verification of the short-circuit withstand strength.....	87
10.11.3	Verification by comparison with a reference design – Using a checklist	88
10.11.4	Verification by comparison with a reference design(s) – Using calculation	88
10.11.5	Verification by test.....	88
10.12	Electromagnetic compatibility (EMC).....	94
11	Routine verification.....	94
11.1	General.....	94
11.2	Degree of protection against contact with hazardous live parts, ingress of solid foreign bodies and water of enclosures.....	95
11.3	Clearances and creepage distances.....	95
11.4	Protection against electric shock and integrity of protective circuits	95
11.5	Incorporation of built-in components	96
11.6	Internal electrical circuits and connections.....	96
11.7	Terminals for external conductors	96
11.8	Mechanical operation.....	96
11.9	Dielectric properties.....	96
11.10	Wiring, operational performance and function	96
101	Particular features of ACS	97
101.1	General requirements and functions.....	97
101.2	Incoming unit	97
101.3	Metering unit.....	97
101.4	Transformer unit	97
101.4.1	General	97
101.4.2	LV/ELV unit	97
101.4.3	LV/LV units.....	98
101.5	Outgoing units	98
Annex A	(normative) Minimum and maximum cross-section of copper cables suitable for connection to terminals for external cables (see 8.8)	109
Annex B	(normative) Method of calculating the cross-sectional area of protective conductors with regard to thermal stresses due to currents of short duration	110
Annex C	(informative) User information template	111
Annex D	(informative) Design verification	115
Annex E	(informative) Rated diversity factor	116
E.1	General.....	116
E.2	Rated diversity factor for outgoing circuits within an assembly	116
E.2.1	General	116
E.2.2	Example of an assembly with an RDF of 0,68	119
E.2.3	Example of an assembly with RDF declared for each section.....	120
Annex F	(normative) Measurement of clearances and creepage distances	121
F.1	Basic principles.....	121

F.2	Use of ribs	121
Annex G (normative)	Correlation between the nominal voltage of the supply system and the rated impulse withstand voltage of the equipment	126
Annex H (informative)	Operating current and power loss of copper cables	128
Annex I (informative)	Thermal equivalent of an intermittent current	130
Annex J (normative)	Electromagnetic compatibility (EMC).....	131
J.1	General.....	131
Annex K (normative)	Operating current and power loss of bare copper bars	138
Annex L (informative)	Guidance on verification of temperature-rise.....	141
L.1	General.....	141
L.1.1	Principles	141
L.1.2	Current ratings of assemblies	141
L.2	Temperature-rise limits	142
L.3	Test.....	143
L.3.1	General	143
L.3.2	Method a) – Verification of the complete assembly (10.10.2.3.5)	143
L.3.3	Method b) – Verification considering individual functional units separately and the complete assembly (10.10.2.3.6)	143
L.3.4	Method c) – Verification considering individual functional units and the main and distribution busbars separately as well as the complete assembly (10.10.2.3.7)	144
L.4	Verification assessment	144
L.5	Verification by comparison with a reference design.....	144
Annex M (normative)	Verification of the short-circuit withstand strength of busbar structures by comparison with a reference design by calculation.....	145
Annex N (informative)	List of notes concerning certain countries	146
Bibliography	147
Figure 101	– Impact test using striking element	70
Figure E.1	– Typical assembly	117
Figure E.2	– Example 1: Table E.1 – Functional unit loading for an assembly with a rated diversity factor of 0,68	119
Figure E.3	– Example 2: Table E.1 – Functional unit loading for an assembly with a rated diversity factor of 0,6 in Section B and 0,68 in Section C	120
Figure F.1	– Measurement of clearance and creepage distances	125
Figure I.1	– Example of average heating effect calculation.....	130
Figure J.1	– Examples of ports	131
Figure L.1	– Not applicable	144
Table 1	– Minimum clearances in air (8.3.2).....	99
Table 2	– Minimum creepage distances (8.3.3)	100
Table 3	– Cross-sectional area of a copper protective conductor (8.4.3.2.2)	101
Table 4	– Conductor selection and installation requirements (8.6.4).....	101
Table 5	– Minimum terminal capacity for copper protective conductors (PE) (8.8)	101
Table 6	– Temperature-rise limits (9.2)	102
Table 7	– Values for the factor n^a (9.3.3).....	103
Table 8	– Power-frequency withstand voltage for main circuits (10.9.2)	103

<https://standards.iteh.ai/catalog/standards/iec/eff9c3b6-8e7c-4867-93d4-36536a956fde/iec-61439-4-2023>

Table 9 – Power-frequency withstand voltage for auxiliary circuits (10.9.2)	103
Table 10 – Impulse withstand test voltages (10.9.3).....	103
Table 11 – Copper test conductors for rated currents up to 400 A inclusive (10.10.2.3.2).....	104
Table 12 – Copper test conductors for rated currents from 400 A to 7 000 A (10.10.2.3.2).....	105
Table 13 – Short-circuit verification by comparison with reference designs: checklist (10.5.3.3, 10.11.3 and 10.11.4).....	106
Table 14 – Relationship between prospective fault current and diameter of copper wire ...	107
Table 15 – Climatic conditions	107
Table 101 – Values of assumed loading.....	108
Table A.1 – Cross-section of copper cables suitable for connection to terminals for external cables	109
Table B.1 – Values of k for insulated protective conductors not incorporated in cables or bare protective conductors in contact with cable covering.....	110
Table C.1 – Items subject to agreement between the assembly manufacturer and the user	111
Table D.1 – List of design verifications to be performed	115
Table E.1 – Examples of loading for an assembly	118
Table F.1 – Minimum width of grooves.....	121
Table G.1 – Correspondence between the nominal voltage of the supply system and the equipment rated impulse withstand voltage.....	127
Table H.1 – Operating current and power loss of single-core copper cables with a permissible conductor temperature of 70 °C (ambient temperature inside the assembly: 55 °C).....	128
Table H.2 – Reduction factor k_1 for cables with a permissible conductor temperature of 70 °C (extract from IEC 60364-5-52:2009, Table B.52.14).....	129
Table J.1 – Tests for EMC immunity for environment A (see J.10.12.2).....	135
Table J.2 – Tests for EMC immunity for environment B (see J.10.12.2).....	136
Table J.3 – Acceptance criteria when electromagnetic disturbances are present.....	137
Table K.1 – Operating current and power loss of bare copper bars with rectangular cross-section, run horizontally and arranged with their largest face vertical, frequency 50 Hz to 60 Hz (ambient air temperature inside the assembly: 55 °C, temperature of the conductor 70 °C).....	138
Table K.2 – Factor k_4 for different temperatures of the air inside the assembly and/or for the conductors.....	139

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES –**Part 1: General rules**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This extended version (EXV) of the official IEC Standard provides the user with the comprehensive content of the Standard.

IEC 61439-4:2023 EXV includes the content of IEC 61439-4:2023, and the references made to IEC 61439-1:2020.

The specific content of IEC 61439-4:2023 is displayed on a blue background.

IEC 61439-4 has been prepared by subcommittee 121B: Low-voltage switchgear and controlgear assemblies, of IEC technical committee 121: Switchgear and controlgear and their assemblies for low voltage. It is an International Standard.

This second edition of IEC 61439-4 cancels and replaces the first edition published in 2012. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) alignment with IEC 61439-1:2020 regarding the structure and technical content, as applicable.

The text of this document is based on the following documents:

Draft	Report on voting
121B/183/FDIS	121B/188/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This document is to be read in conjunction with IEC 61439-1:2020. The provisions of the general rules dealt with in IEC 61439-1:2020 are only applicable to this document insofar as they are specifically cited. When this document states “addition”, “modification” or “replacement”, the relevant text in IEC 61439-1:2020 is to be adapted accordingly.

Subclauses that are numbered with a 101 (102, 103, etc.) suffix are additional to the same subclause in IEC 61439-1:2020.

Tables and figures in this document that are new are numbered starting with 101.

New annexes in this document are lettered AA, BB, etc.

In this document, terms written in small capitals are defined in Clause 3.

The reader’s attention is drawn to the fact that Annex N lists all of the “in-some-country” clauses on differing practices of a less permanent nature relating to the subject of this document.

A list of all parts of the IEC 61439 series, under the general title *Low-voltage switchgear and controlgear assemblies*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be:

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 61439-4:2023](#)

<https://standards.iteh.ai/catalog/standards/iec/eff9c3b6-8e7c-4867-93d4-36536a956fde/iec-61439-4-2023>

INTRODUCTION

The purpose of this document is to harmonize as far as practicable all rules and requirements of a general nature applicable to low-voltage switchgear and controlgear assemblies, in order to obtain uniformity of requirements and verification for assemblies and to avoid the need for verification in other standards. All those requirements for the various assembly standards which can be considered as general have therefore been gathered in this document together with specific subjects of wide interest and application, e.g. temperature-rise, dielectric properties, etc.

For each type of low-voltage switchgear and controlgear assembly, only two main standards are necessary to determine all requirements and the corresponding methods of verification:

- the basic standard, (this document) referred to as “IEC 61439-1” in the specific standards, covering the various types of low-voltage switchgear and controlgear assemblies;
- the specific assembly standard hereinafter also referred to as the relevant assembly standard.

For a general rule to apply to a specific assembly standard, it should be explicitly referred to by quoting this document followed by the relevant clause or subclause number e.g. “IEC 61439-1:2020, 9.1.3”.

A specific assembly standard may not require, and hence need not call up, a general rule where it is not applicable, or it can add requirements if the general rule is deemed inadequate in the particular case, but it may not deviate from it unless there is substantial technical justification detailed in the specific assembly standard.

Where, in this document, a cross-reference is made to another clause, the reference is to be taken to apply to that clause as amended by the specific assembly standard, where applicable.

Requirements in this document that are subject to agreement between the assembly manufacturer and the user are summarized in Annex C (informative). This schedule also facilitates the supply of information on basic conditions and additional user specifications to enable proper design, application and utilization of the assembly.

For the IEC 61439 series, the following parts are published:

- a) IEC 61439-1: General rules
- b) IEC 61439-2: Power switchgear and controlgear assemblies (PSC-assemblies)¹
- c) IEC 61439-3: Distribution boards intended to be operated by ordinary persons (DBO)
- d) IEC 61439-4: Particular requirements for assemblies for construction sites (ACS)
- e) IEC 61439-5: Assemblies for power distribution in public networks
- f) IEC 61439-6: Busbar trunking systems (busways)
- g) IEC 61439-7: Assemblies for specific applications such as marinas, camping sites, market squares, electric vehicle charging stations
- h) IEC TR 61439-0: Guidance to specifying assemblies.

This list is not exhaustive; additional parts can be developed as the need arises.

¹ IEC 61439-2 includes requirements for assemblies for use in photovoltaic installations.

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES –

Part 1: General rules

1 Scope

NOTE Throughout this document, the abbreviation ACS (assembly for construction site, see 3.1.101) is used for a low-voltage switchgear and controlgear assembly intended for use on construction and similar sites.

This document defines the specific requirements of ACS as follows:

- assemblies for which the rated voltage does not exceed 1 000 V in case of AC or 1 500 V in case of DC;
- assemblies where the nominal primary voltage and the nominal secondary voltage of transformers incorporated in ACS are within the limits specified above;
- assemblies intended for use on construction sites, both indoors and outdoors, i.e. temporary places of work to which the public do not generally have access and where building construction, installation, repairs, alteration or demolition of property (buildings) or civil engineering (public works) or excavation or any other similar operations are carried out;
- transportable (semi-fixed) or MOBILE assemblies with enclosure.

The manufacture and/or assembly can be carried out by an entity other than by the original manufacturer (see 3.10.1 of IEC 61439-1:2020).

This document does not apply to individual devices and self-contained components, such as motor starters, fuse switches, electronic equipment, etc. which will comply with the relevant product standards.

This document does not apply to assemblies for use in the administrative centres of construction sites (offices, cloakrooms, meeting rooms, canteens, restaurants, dormitories, toilets, etc.).

Requirements for electrical protection provided by equipment manufactured according to this document are given in IEC 60364-7-704.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-2:2007, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-11:1981, *Basic environmental testing procedures – Part 2-11: Tests – Test Ka: Salt mist*

IEC 60068-2-27, *Environmental testing – Part 2-27: Tests – Test Ea and guidance: Shock*

IEC 60068-2-30:2005, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*