


INTERNATIONAL STANDARD

NORME INTERNATIONALE

GROUP SAFETY PUBLICATION
PUBLICATION GROUPEE DE SÉCURITÉ

**Safety of transformers, reactors, power supply units and combinations thereof –
Part 2-20: Particular requirements and tests for small reactors**

**Sécurité des transformateurs, bobines d'inductance, blocs d'alimentation et
combinaisons de ces éléments – 61558-2-20:2022**
**Partie 2-20: Exigences particulières et essais pour les petites bobines
d'inductance 61558-2-20-2022**





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2022 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.



INTERNATIONAL STANDARD

NORME INTERNATIONALE

GROUP SAFETY PUBLICATION
PUBLICATION GROUPEE DE SÉCURITÉ

**Safety of transformers, reactors, power supply units and combinations thereof –
Part 2-20: Particular requirements and tests for small reactors**

**Sécurité des transformateurs, bobines d'inductance, blocs d'alimentation et
combinaisons de ces éléments – 61558-2-20:2022**
**Partie 2-20: Exigences particulières et essais pour les petites bobines
d'inductance**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.180

ISBN 978-2-8322-6118-7

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD	3
INTRODUCTION	5
1 Scope	6
2 Normative references	7
3 Terms and definitions	7
4 General requirements	9
5 General notes on tests	9
6 Ratings	10
7 Classification	10
8 Marking and other information	11
9 Protection against electric shock	13
10 Change of voltage setting	13
11 Voltage drop	14
12 No-load output voltage	14
13 Short-circuit voltage	14
14 Heating	14
15 Short-circuit and overload protection	15
16 Mechanical strength	16
17 Protection against harmful ingress of dust, solid objects and moisture	16
18 Insulation resistance, dielectric strength and leakage current	16
19 Construction	16
20 Components	17
21 Internal wiring	17
22 Supply connection and other external flexible cable or cords	17
23 Terminals for external conductors	18
24 Provisions for protective earthing	18
25 Screws and connections	18
26 Creepage distances, clearances and distances through insulation	18
27 Resistance to heat, fire and tracking	18
28 Resistance to rusting	18
Annexes	19
Annex AA (informative) Characteristic parameter measurements	19
Annex BB (normative) Particular requirements for associated reactors with frequencies > 500 Hz	19
Annex CC (normative) Partial discharge (PD) test	21
Bibliography	22
Table 101 – Symbols indicating the kind of transformer	13

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**SAFETY OF TRANSFORMERS, REACTORS,
POWER SUPPLY UNITS AND COMBINATIONS THEREOF –****Part 2-20: Particular requirements and tests for small reactors**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61558-2-20 has been prepared by IEC technical committee 96: Transformers, reactors, power supply units and combinations thereof. It is an International Standard.

This third edition cancels and replaces the second edition published in 2010. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Adjustment of structure and references in accordance with IEC 61558-1:2017.
- b) Additional Annex AA with references for characteristic parameter measurements.
- c) Additional Annex BB for associated reactors with frequencies above 500 Hz.
- d) Additional Annex CC for partial discharge.

The text of this International Standard is based on the following documents:

Draft	Report on voting
96/556/FDIS	96/564/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

It has the status of a group safety publication in accordance with IEC Guide 104.

This International Standard is to be used in conjunction with IEC 61558-1:2017.

This document supplements or modifies the corresponding clauses in IEC 61558-1:2017, so as to convert that publication into the IEC standard: *Particular requirements and tests for small reactors*.

iTeh STANDARD PREVIEW

A list of all parts in the IEC 61558 series published under the general title *Safety of transformers, reactors, power supply units and combinations thereof*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

<https://standards.ieh.ai/catalog/standards/sist/53e339cd-a455-47ee-87d1-bd1f4f6d0d4c/iec->

Where this document states "*addition*", "*modification*" or "*replacement*", the relevant text of IEC 61558-1:2017 is to be adopted accordingly.

In this document, the following print types are used:

- requirements proper: in roman type;
- *test specifications*: in italic type;
- explanatory matter: in smaller roman type.

In the text of this document, the words in **bold** are defined in Clause 3.

Subclauses, notes, figures and tables additional to those in IEC 61558-1:2017 are numbered starting from 101; supplementary annexes are entitled AA, BB, etc.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

IEC TC 96 has a group safety function in accordance with IEC Guide 104 for transformers other than those intended to supply distribution networks, in particular transformers and power supply units intended to allow the application of protective measures against electric shock as defined by TC 64, but in certain cases including the limitation of voltage and horizontal safety function for SELV, in accordance with IEC 60364-4-41.

The group safety function (GSF) is used because of responsibility for safety extra-low voltage (SELV) in accordance with IEC 61140:2016, 5.2.6 and IEC 60364-4-41:2005, 414.3.1 or control circuits in accordance with IEC 60204-1:2016, 7.2.4.

The group safety function is used for each part of IEC 61558-2 because different standards of the IEC 61558 series can be combined in one construction but in certain cases with no limitation of rated output power.

For example an auto-transformer in accordance with IEC 61558-2-13 can be designed with a separate SELV-circuit in accordance with the particular requirements for IEC 61558-2-6 relating to the general requirements of IEC 61558-1.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 61558-2-20:2022](https://standards.iteh.ai/catalog/standards/sist/53e339cd-a455-47ee-87d1-bd1f4f6d0d4c/iec-61558-2-20-2022)

<https://standards.iteh.ai/catalog/standards/sist/53e339cd-a455-47ee-87d1-bd1f4f6d0d4c/iec-61558-2-20-2022>

SAFETY OF TRANSFORMERS, REACTORS, POWER SUPPLY UNITS AND COMBINATIONS THEREOF –

Part 2-20: Particular requirements and tests for small reactors

1 Scope

Replacement

This part of IEC 61558 deals with the safety of **small reactors** for general applications. **Small reactors** incorporating **electronic circuits** are also covered by this document.

NOTE 1 Safety includes electrical, thermal and mechanical aspects.

Unless otherwise specified, from here onward, the term **transformer** or **reactor** covers **small reactors**.

This document is applicable to **stationary** or **portable**, single-phase or polyphase, air-cooled (natural or forced) general purpose **reactors** including alternating current, premagnetised and current compensated **independent** or **associated dry-type reactors**. The windings can be encapsulated or non-encapsulated.

The **rated supply voltage** does not exceed 1 000 V AC or 1 500 V ripple-free DC, the **rated supply frequency** and the **internal operating frequencies** do not exceed 100 MHz.

This document can be used for **reactors** with a fundamental frequency above 500 Hz (see Annex BB).

The **rated power** does not exceed:

- 25 kVAR AC (25 kW DC) for single-phase **reactors**,
- 50 kVAR AC (50 kW DC) for poly-phase **reactors**.

This document is applicable to **reactors** without limitation of the **rated power** subject to an agreement between the purchaser and the manufacturer.

This document does not apply to:

- **reactors** covered by IEC 60076-6 for rated voltages above 1 000 V;
- ballast for tubular fluorescent covered by IEC 61347-2-8;
- ballast for discharge lamps (excluding tubular fluorescent lamps) covered by IEC 61347-2-9.
- fixed inductors for electromagnetic interference suppression covered by IEC 60938 series

NOTE 2 For **reactors** filled with liquid dielectric or pulverised material such as sand, additional requirements are under consideration.

NOTE 3 Normally, **reactors** are intended to be associated with equipment for functional requirements of the equipment or requirements by the installation rules or by other appliance specifications. The protection against electric shock may be provided or completed by other parts or features of the equipment, such as the **body**.

NOTE 4 **Reactors** for particular applications will in the future be covered by complementary normative annexes.

Attention is drawn to the following if necessary:

- for **reactors** intended to be used in vehicles, on board ships, and aircraft, additional requirements (from other applicable standards, national rules, etc.);

- measures to protect the **enclosure** and the components inside the enclosure against external influences such as fungus, vermin, termites, solar-radiation, and icing;
- the different conditions for transportation, storage, and operation of the **reactors**;
- additional requirements in accordance with other appropriate standards and national rules may be applicable to **reactors** intended for use in special environments.

Future technological development of **reactors** may necessitate a need to increase the upper limit of the frequencies. Until then, this document may be used as a guidance document.

This group safety publication focusing on safety guidance is primarily intended to be used as a product safety standard for the products mentioned in the scope, but is also intended to be used by technical committees in the preparation of publications for products similar to those mentioned in the scope of this group safety publication, in accordance with the principles laid down in IEC Guide 104 and ISO/IEC Guide 51.

One of the responsibilities of a technical committee is, wherever applicable, to make use of basic safety publications and/or group safety publications in the preparation of its publications.

2 Normative references

This clause of IEC 61558-1:2017 is applicable, except as follows:

Addition

IEC 60076-6:2007, *Power transformers – Part 6: Reactors*

IEC 61558-1:2017, *Safety of transformers, reactors, power supply units and combinations thereof – Part 1: General requirements and tests*

IEC 61558-2-16:2021, *Safety of transformers, reactors, power supply units and combinations thereof – Part 16: Particular requirements and tests for switch mode power supply units and transformers for switch mode power supply units for general applications*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61558-1:2017 apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

Modification

Where IEC 61558-1:2017 is applicable, the word "**transformer**", if used, shall be replaced by "**reactor**".

3.1 Transformers

This subclause of IEC 61558-1:2017 is applicable, except as follows:

Addition

3.1.101

alternating current reactor

reactor in which the magnetising current generates an alternating magnetic field, changing its polarity depending on the frequency

3.1.102

premagnetised reactor

reactor in which the magnetising direct current generates a magnetic field of only one polarity, while a superimposed alternating current alters the direct magnetic field depending on its strength and the frequency

3.1.103

current compensated reactor

reactor with at least two windings on a common core, where the magnetising currents are in opposite directions in order to reduce the magnetic flux

Replacement

3.1.9

overload proof reactor

reactor in which the temperature does not exceed the specified limits when the **reactor** is overloaded and continues to meet all requirements of this document after the removal of the overload

3.1.9.1

non-inherently overload proof reactor

overload proof reactor equipped with a protective device which opens the circuit, or reduces the current in the circuit when the **reactor** is overloaded, and which continues to meet all requirements of this document after the removal of the overload and resetting or replacing of the protective device

Note 1 to entry: Examples of protective devices are fuses, **overload releases**, thermal fuses, **thermal links**, **thermal cut-outs**, PTC resistors, and automatic circuit-breakers.

Note 2 to entry: In case of protection by a device which cannot be replaced nor re-set, the wording "continues to meet all requirements of this document after removal of the overload" does not imply that the **reactor** continues to operate.

3.1.9.2

inherently overload proof reactor

overload proof reactor not equipped with a device to protect the **reactor** and in which the temperature in the case of overload, by construction, does not exceed the specified limits and which continues to operate and meet all the requirements of this document after the removal of the overload

3.1.10

non-overload proof reactor

reactor which is intended to be protected against excessive temperature by means of a protective device not provided with the **reactor** and which continues to meet all the requirements of this document after the removal of the overload and resetting or replacing of the protective device

3.1.11

fail-safe reactor

reactor which, after abnormal use, permanently fails to function by an interruption of the failing circuit but presents no danger to the user or surroundings

3.5 Ratings

This subclause of IEC 61558-1:2017 is applicable, except as follows:

Replacement

3.5.4

rated current

rated current, assigned to the **reactor** by the manufacturer including harmonics, if any, which influence the heating of the **reactor**

Addition

3.5.101

rated power

sum of the products of the **rated voltage drop** and the **rated current** at the **rated frequency** for the different windings

3.5.102

rated inductance

inductance of the **reactor** designed by the manufacturer for the specified operating condition of the **reactor**

Note 1 to entry: The specific operating conditions of DC **reactors** are determined by the DC component and the superimposed AC component.

3.5.103

rated resistance

DC **resistance** of a winding of a **reactor** designed by the manufacturer for the specified operating conditions of the **reactor**

3.5.104

rated voltage drop

voltage across a winding of the **reactor** at the **rated current** and the **rated frequency** assigned by the manufacturer

3.6 No-load values

This subclause of IEC 61558-1:2017 is not applicable.

4 General requirements

This clause of IEC 61558-1:2017 is applicable.

5 General notes on tests

This clause of IEC 61558-1:2017 is applicable.

6 Ratings

This clause of IEC 61558-1:2017 is applicable, except as follows:

Addition

6.101 The rated supply voltage shall not exceed 1 000 V AC or 1 500 V ripple-free DC.

6.102 The rated power shall not exceed 25 kVAR AC (25 kW DC) for single-phase reactors and 50 kVAR AC (50 kW DC) for poly-phase reactors.

Reactors without limitation of the **rated output** shall be subject to agreement between the purchaser and the manufacturer.

6.103 The rated supply frequency and the internal operating frequencies shall not exceed 100 MHz.

6.104 The values of **rated inductance** and **rated resistance** shall be given at the rated ambient temperature, under no load conditions, and the tolerance shall be declared by the manufacturer.

Compliance with the requirements of 6.101 to 6.104 is checked by inspection of the marking.

NOTE 1 Measurements for characteristic parameters are described in Annex AA.

NOTE 2 See Annex BB for **reactors** with a fundamental frequency above 500 Hz.

7 Classification

This clause of IEC 61558-1:2017 is applicable, except as follows:

7.1

Replacement

Reactors are classified according to their protection against electric shock:

- **class I reactors;**
- **class II reactors;**
- **class III reactors.**

NOTE **Incorporated reactors** are not classified; their degree of protection against electric shock is determined by the way in which the **reactors** are incorporated.

7.2

Replacement

Reactors are classified according to the protection against abnormal use:

- **inherently overload proof reactors;**
- **non-inherently overload proof reactors;**
- **non-overload proof reactors;**
- **fail-safe reactors.**

8 Marking and other information

This clause of IEC 61558-1:2017 is applicable, except as follows:

8.1

Replacement

Reactors shall be marked with the following parameters:

- a) **rated supply voltage** in volts (V);
- b) **rated supply frequency** (ies) in hertz (Hz);
- c) **rated voltage drop** in volts (V) only for AC reactors;
- d) **rated power** in volt-amperes reactive VAR or kilovolt-amperes reactive kVAR for AC, in watts (W) or kilowatts (kW) for DC;
- e) **rated current** and harmonics, if any, in amperes (A) or milliamperes (mA);
- f) symbol or abbreviation DC for nature of direct current, if applicable;
- g) symbol or abbreviation AC for nature of alternating current, if applicable;
- h) **rated inductance** of the winding(s) in henries (H) or millihenries (mH) for **reactors** followed by the appropriate tolerance;

Only one of the values c), d) or h) needs to be marked.

- i) the **reactor** shall be marked with one of the graphical symbols shown in 8.11;
- j) **rated resistance** of the winding(s) in ohms (Ω) or milliohms ($m\Omega$) followed by the appropriate tolerance;

The marking j) can be given in the literature instead of being marked.

NOTE A description for characteristic parameter measurements is described in Annex AA.

- k) model or type references;
- l) name or trademark of the manufacturer or responsible vendor;
- m) indication of the protection index IP, if other than IP00;
- n) rated maximum ambient temperature t_a , if other than 25 °C;

It is recommended that the values of t_a are given in steps of 5 °C for $t_a \leq 50$ °C and in steps of 10 °C for $t_a > 50$ °C.

- o) **rated minimum ambient temperature** t_{amin} , if lower than +10 °C and if a temperature sensitive device is used;

It is recommended that the values of t_{amin} are given in steps of 5 °C.

- p) duty cycle, if any, unless the operating time is limited by the construction of the **reactor** or corresponds to the operating conditions. The marking of **short-time duty cycle** or **intermittent duty cycle** shall correspond to normal use. The operating time for **reactors** with short-time duty shall be expressed in seconds (s) or minutes (min); the operating time and the resting time of **reactors** with **intermittent duty cycle** shall be expressed in seconds (s) or minutes (min), separated by an oblique stroke;
- q) symbol for **overvoltage category**, if other than OVC II;
- r) switching frequency (ies) of the supplying frequency inverter;
- s) **reactors** to be used with forced air cooling where the fan is not a part of the **reactor** shall be marked with "AF" followed by the air speed, expressed in m/s;

- t) symbol for **class II** construction, for **class II reactors** only;
- u) symbol for **class III** construction, for **class III reactors** only;

Additional markings are allowed if there is no misunderstanding.

All markings except those under i) and j) may be illustrated as QR Code according to ISO/IEC 18004.

- v) symbol indicating the maximum altitude of installation, if higher than 2 000 m.

8.4

Replacement

Reactors with tapped or multiple windings shall be clearly marked in accordance with 8.1.

8.5

Replacement

Reactors which are declared to be **overload proof reactors** and comply with the requirements for such **reactors** shall be marked with the symbol for **overload proof reactors**.

Non-inherently overload proof reactors with incorporated fuses and **non-overload proof reactors** designed to be protected by fuses shall, in addition, be marked with the **rated current** (amperes or milliamperes) of the protecting fuse-link, followed or preceded by the symbol for the time current characteristics of the fuse in accordance with the relevant standard, if applicable.

IEC 61558-2-20:2022

Non-inherently overload proof reactors with incorporate replaceable protective devices other than fuses and **non-overload proof reactor** designed to be protected with protective devices other than fuses shall, in addition, be marked with the manufacturer's model or type reference of the device, and/or ratings of the device.

Overload proof reactors with non-replaceable devices need no additional marking regarding the protective device.

The marking shall be sufficient to ensure correct replacement of the protective device.




When replaceable protective devices other than fuses are used, appropriate information about their replacement shall be provided in an instruction sheet or the equivalent accompanying the **reactor**.

Reactors declared to be **fail-safe reactors** and comply with the requirements for such **reactors** shall be marked with the symbol for **fail-safe reactors**.

8.11

Addition

Table 101 – Symbols indicating the kind of transformer

Symbol or graphical symbol	Explanation or title	Identification
	Fail-safe reactor	IEC 60417-5950:2002-10
	Non-overload proof reactor	IEC 60417-5951:2002-10
	Overload proof reactor (inherently or non-inherently)	IEC 60417-5952:2002-10

9 Protection against electric shock

This clause of IEC 61558-1:2017 is applicable.

10 Change of input voltage setting

Replacement of the entire clause by the following:

10 Change of voltage setting

Reactors with more than one **rated supply voltage** or more than one **rated voltage drop** shall be so constructed that the voltage setting cannot be changed without the aid of a **tool**.

Reactors which can be set to different **rated supply voltages** and **rated voltage drops** shall be so constructed that the indication of the voltage to which the **reactor** is set for is discernible on the **reactor** when it is ready for use.

Compliance is checked by inspection.

NOTE As an example, the requirement concerning the voltage setting is met if a tool is needed to remove a cover before the voltage setting can be changed.