

INTERNATIONAL STANDARD

IEC
60896-22

First edition
2004-02

Stationary lead-acid batteries –

Part 22: Valve regulated types – Requirements

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 60896-22:2004](https://standards.iteh.ai/catalog/standards/iec/86139155-649c-4c69-bd8a-416cf1477cdf/iec-60896-22-2004)

<https://standards.iteh.ai/catalog/standards/iec/86139155-649c-4c69-bd8a-416cf1477cdf/iec-60896-22-2004>

*This **English-language** version is derived from the original **bilingual** publication by leaving out all French-language pages. Missing page numbers correspond to the French-language pages.*



Reference number
IEC 60896-22:2004(E)

Publication numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

Consolidated editions

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

Further information on IEC publications

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site** (www.iec.ch)

- **Catalogue of IEC publications**

The on-line catalogue on the IEC web site (www.iec.ch/searchpub) enables you to search by a variety of criteria including text searches, technical committees and date of publication. On-line information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.

- **IEC Just Published**

This summary of recently issued publications (www.iec.ch/online_news/justpub) is also available by email. Please contact the Customer Service Centre (see below) for further information.

- **Customer Service Centre**

If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre: custserv@iec.ch

Email: custserv@iec.ch
Tel: +41 22 919 02 11
Fax: +41 22 919 03 00

<https://standards.iteh.ai/catalog/standards/iec/86139155-649c-4c69-bd8a-416cf1477cdf/iec-60896-22-2004>

INTERNATIONAL STANDARD

IEC
60896-22

First edition
2004-02

Stationary lead-acid batteries –

Part 22: Valve regulated types – Requirements

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

IEC 60896-22:2004

<https://standards.iteh.ai/catalog/standards/iec/86139155-649c-4c69-bd8a-416cf1477cdf/iec-60896-22-2004>

© IEC 2004 Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

CONTENTS

FOREWORD.....	5
1 Scope.....	9
2 Normative references	9
3 Terms and definitions	9
4 Functional requirements	21
5 Reporting format.....	25
6 Requirements and characteristics	27
 Annex A (normative) User statement of requirements	51
Annex B (normative) Supplier statement of product range test results.....	53
 Bibliography.....	55
 Table 1 – Safe operation requirements	21
Table 2 – Performance requirements	23
Table 3 – Durability requirements	23
Table 4 – Requirement for gas emission information	27
Table 5 – Requirement for high current tolerance.....	29
Table 6 – Requirement for short-circuit current and d.c. internal resistance information	29
Table 7 – Requirement for protection against internal ignition from external spark sources ..	31
Table 8 – Requirement for protection against ground short propensity	31
Table 9 – Requirement for content and durability of required markings – Requirement a)	33
Table 10 – Requirement for content and durability of required markings – Requirement b)...	33
Table 11 – Requirement for material identification	35
Table 12 – Requirement for the operation of the valve	35
Table 13 – Requirement for definition of the flammability rating of the materials	35
Table 14 – Requirement for performance of the intercell connector.....	37
Table 15 – Requirement for discharge capacity performance	37
Table 16 – Requirement for charge retention during storage	39
Table 17 – Requirement for float service with daily discharges	39
Table 18 – Requirement for recharge behaviour.....	41
Table 19 – Requirement for service life at an operating temperature of 40 °C	41
Table 20 – Requirement for the impact of a stress temperature of 55 °C or 60 °C	43
Table 21 – Requirement for the impact of abusive over-discharges.....	45
Table 22 – Requirements for information on thermal runaway sensitivity.....	45
Table 23 – Requirement for the impact of low temperature service on capacity	47
Table 24 – Requirement for dimensional stability at elevated internal pressures and temperatures	47
Table 25 – Requirements for stability against mechanical abuse of units during installation ..	49

INTERNATIONAL ELECTROTECHNICAL COMMISSION

STATIONARY LEAD-ACID BATTERIES –**Part 22: Valve regulated types –
Requirements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60896-22 has been prepared by IEC technical committee 21: Secondary cells and batteries

The text of this standard is based on the following documents:

FDIS	Report on voting
21/595/FDIS	21/601/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This standard constitutes Part 22 of the IEC 60896 series, published under the general title *Stationary lead-acid batteries*. At the time of the publication of this part, the following parts had already been published:

Part 11: Vented types – General requirements and methods of tests

Part 21: Valve regulated types – Methods of test

Part 22: Valve regulated types – Requirements

The committee has decided that the contents of this publication will remain unchanged until 2009. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition or
- amended.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 60896-22:2004](https://standards.iteh.ai/catalog/standards/iec/86139155-649c-4c69-bd8a-416cf1477cdf/iec-60896-22-2004)

<https://standards.iteh.ai/catalog/standards/iec/86139155-649c-4c69-bd8a-416cf1477cdf/iec-60896-22-2004>

STATIONARY LEAD-ACID BATTERIES –

Part 22: Valve regulated types – Requirements

1 Scope

This part of IEC 60896 applies to all stationary lead-acid cells and monobloc batteries of the valve regulated type for float charge applications, (i.e. permanently connected to a load and to a d.c. power supply), in a static location (i.e. not generally intended to be moved from place to place) and incorporated into stationary equipment or installed in battery rooms for use in telecom, uninterruptible power supply (UPS), utility switching, emergency power or similar applications.

The objective of this part of IEC 60896 is to assist the specifier in the understanding of the purpose of each test contained within IEC 60896-21 and provide guidance on a suitable requirement that will result in the battery meeting the needs of a particular industry application and operational condition. This standard is used in conjunction with the common test methods described in IEC 60896-21 and is associated with all types and construction of valve regulated stationary lead-acid cells and monoblocs used in standby power applications.

This part of IEC 60896 does not apply to lead-acid cells and batteries used for vehicle engine starting applications (IEC 60095 series), solar photovoltaic applications (IEC 61427), or general purpose applications (IEC 61056 series).

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60896-21:2004, *Stationary lead-acid batteries – Part 21: Valve regulated types – Methods of test*¹⁾

ISO 1043-1, *Plastics – Symbols and abbreviated terms – Part 1: Basic polymers and their special characteristics*

3 Terms and definitions

For the purposes of this document, the following definitions apply.

3.1

accuracy (of a measuring instrument)

quality which characterizes the ability of a measuring instrument to provide an indicated value close to a true value of the measurand

[IEV 311-06-08]

NOTE Accuracy is all the better when the indicated value is closer to the corresponding true value.

3.2**accuracy class**

category of measuring instruments, all of which are intended to comply with a set of specifications regarding uncertainty

[IEV 311-06-09]

3.3**ambient temperature**

temperature of the medium in the immediate vicinity of a cell or battery

[IEV 486-03-12]

3.4**ampere-hour**

quantity of electricity or a capacity of a battery obtained by integrating the discharge current in ampere with respect to time in hours

NOTE One ampere-hour equals 3 600 coulombs.

3.5**secondary battery**

two or more secondary cells connected together and used as a source of electrical energy

[IEV 486-01-03]

3.6**monobloc battery**

secondary battery in which the plate packs are fitted in a multi-compartment container

[IEV 486-01-17]

3.7**floating battery**

secondary battery whose terminals are permanently connected to a source of constant voltage sufficient to maintain the battery approximately fully charged, intended to supply a circuit, if the normal supply is temporarily interrupted

[IEV 486-04-10]

3.8**battery capacity**

quantity of electricity or electrical charge which a fully charged battery can deliver under specified conditions

NOTE The SI unit for electric charge is the coulomb (1 C = 1 A·s) but in practice, battery capacity is expressed in ampere-hours (Ah).

[IEV 486-03-01]

3.9**charge**

operation during which a secondary battery receives from an external circuit electrical energy, which is converted into chemical energy

[IEV 486-01-11]

NOTE A charge is defined by its maximum voltage, current and duration.

3.10**full charge**

state where all the available active material of a secondary cell or battery has been reconverted to its fully charged status

[IEV 486-03-37]

3.11**overcharge**

continued charging after the full charge of a secondary cell or battery

[IEV 486-03-35]

3.12**cell**

assembly of electrodes and electrolyte, which constitutes the basic unit of a secondary battery

[IEV 486-01-02]

3.13**electrochemical cell**

electrochemical system capable of storing in chemical form the electric energy received and which can give it back by reversion, i.e. a secondary cell

[IEV 486-01-01, modified]

3.14**secondary cell**

assembly of electrodes and electrolyte which constitutes the basic unit of a secondary battery

[IEV 486-01-02]

3.15**valve-regulated cell**

secondary cell which is closed under normal conditions but which has an arrangement, which allows the escape of gas if the internal pressure exceeds a predetermined value. The cell cannot normally receive the addition of electrolyte

[IEV 486-01-20]

NOTE Such cells have an immobilized electrolyte to prevent spillage and allow for oxygen recombination on the negative electrode.

3.16**actual capacity** **C_a**

quantity of electricity delivered by a cell or battery, determined experimentally with a discharge at a specified rate to a specified end-voltage and at a specified temperature

NOTE This value is usually expressed in ampere-hours (Ah).

3.17**nominal capacity** **C_n**

suitable approximate quantity of electricity used to identify the capacity of a cell or battery

NOTE This value is usually expressed in ampere-hours (Ah).

[IEV 486-03-021]

3.18**rated capacity** **C_{rt}**

quantity of electricity, declared by the manufacturer, which a cell or battery can deliver under specified conditions after a full charge

NOTE This value is usually expressed in ampere-hours (Ah).

[IEV 486-03-22]

3.19**shipping capacity** **C_{sh}**

quantity of electricity, declared by the manufacturer, which a cell or battery can deliver, at the time of shipment, under specified conditions of charge.

NOTE 1 This value is usually expressed in ampere-hours (Ah).

NOTE 2 In the present standard this value is assumed to be at least 0,95 C_{rt} .

3.20**durability**

ability of an item (battery) to perform a required function under given conditions of use and maintenance, until a limiting state is reached

NOTE A limiting state of an item (battery) may be characterized by the end of the useful life, unsuitability for any economic or technological reasons or other relevant factors.

[IEV 191-02-02]

3.21**electrolyte**

liquid or solid phase containing mobile ions that render the phase electrically conducting

[IEV 486-02-19]

3.22**stationary equipment**

either fixed equipment or equipment not provided with a carrying handle and having such a mass that it cannot easily be moved

[IEV 826-07-06]

3.23**failure**

termination of the ability of an item (battery) to perform the required function

[IEV 603-05-06]

3.24**lead-acid battery**

secondary battery in which the electrodes are made mainly from lead and the electrolyte is a sulphuric acid solution

[IEV 486-01-04]

3.25**design life**

expected period of useful life of a battery according to components, design and application.

3.26**service life**

period of useful life of a battery under specified conditions

[IEV 486-03-23]

3.27**useful life**

under given conditions, the time interval beginning at a certain instant of time, and ending when the failure intensity becomes unacceptable or when the item (battery) is considered un-repairable as a result of a fault

[IEV 191-10-06]

3.28**performance**

characteristics defining the ability of a battery to achieve its intended functions

[IEV 311-06-11]

3.29**product range**

range of products, i.e. cells or monobloc batteries, over which specified design features, materials, manufacturing processes, and quality systems (e.g. ISO 9000) of manufacturing locations are identical

NOTE This definition guides the selection of the units to be tested in the framework of this standard.

3.30**accelerated test**

test in which the applied stress level is chosen to exceed that stated in the reference conditions in order to shorten the time duration required to observe the stress response of the item (battery), or to magnify the response in a given time duration

NOTE To be valid, an accelerated test shall not alter (or conceal) the basic fault modes and failure mechanisms, or their relative prevalence.

[IEV 191-14-07]

3.31**acceptance test**

contractual test to prove to the customer that the item (battery) meets certain conditions of its specification

[IEV 151-16-23]

3.32**commissioning test**

tests on an item (battery) carried out on site to prove that it is correctly installed and can operate correctly

[IEV 151-15-24]

3.33**compliance test**

test used to show whether or not a characteristic or property of an item (battery) complies with the stated requirements

[IEV 191-14-02]