



Designation: ~~E1995—18~~ E1995 – 21

An American National Standard

Standard Test Method for Measurement of Smoke Obscuration Using a Conical Radiant Source in a Single Closed Chamber, With the Test Specimen Oriented Horizontally¹

This standard is issued under the fixed designation E1995; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope*

1.1 This is a fire-test-response standard.

1.2 This test method provides a means of measuring smoke obscuration resulting from subjecting essentially flat materials, products, or assemblies (including surface finishes), not exceeding 25 mm [~~1 in.~~](1 in.) in thickness, in a horizontal orientation, exposed to specified levels of thermal irradiance, from a conical heater, in the presence of a pilot flame, in a single closed chamber. Optional testing modes exclude the pilot flame.

NOTE 1—The equipment used for this test method is technically equivalent to that used in ISO 5659-2 and in NFPA 270.

1.3 The principal fire-test-response characteristic obtained from this test method is the specific optical density of smoke from the specimens tested, which is obtained as a function of time, for a period of 10 min.

1.4 An optional fire-test-response characteristic measurable with this test method is the mass optical density (see [Annex A1](#)), which is the specific optical density of smoke divided by the mass lost by the specimens during the test.

1.5 The fire-test-response characteristics obtained from this test are specific to the specimen tested, in the form and thickness tested, and are not an inherent property of the material, product, or assembly.

1.6 This test method does not provide information on the fire performance of the test specimens under fire conditions other than those conditions specified in this test method. For limitations of this test method, see [5.5](#).

1.7 Use the SI system of units in referee decisions; see [IEEE/ASTM SI-10](#). The inch-pound units given in ~~brackets~~parentheses are for information only.

1.8 *This test method is used to measure and describe the response of materials, products, or assemblies to heat and flame under controlled conditions, but does not by itself incorporate all factors required for fire hazard or fire risk assessment of the materials, products, or assemblies under actual fire conditions.*

¹ This test method is under the jurisdiction of ASTM Committee E05 on Fire Standards and is the direct responsibility of Subcommittee E05.21 on Smoke and Combustion Products.

Current edition approved Dec. 1, 2018/June 1, 2021. Published January 2019/June 2021. Originally approved in 1998. Last previous edition approved in 2016/2018 as ~~E1995—16~~E1995 – 18. DOI: ~~10.1520/E1995-18~~10.1520/E1995-21.

*A Summary of Changes section appears at the end of this standard

1.9 Fire testing of products and materials is inherently hazardous, and adequate safeguards for personnel and property shall be employed in conducting these tests. This test method may involve hazardous materials, operations, and equipment. See also 6.2.1.2, Section 7, and 11.7.2.

1.10 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.11 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 ASTM Standards:²

[C1186 Specification for Flat Fiber-Cement Sheets](#)

[C1288 Specification for Fiber-Cement Interior Substrate Sheets](#)

[D2843 Test Method for Density of Smoke from the Burning or Decomposition of Plastics](#)

[D4100 Test Method for Gravimetric Determination of Smoke Particulates from Combustion Of Plastic Materials \(Withdrawn 1997\)³](#)

[D5424 Test Method for Smoke Obscuration of Insulating Materials Contained in Electrical or Optical Fiber Cables When Burning in a Vertical Cable Tray Configuration](#)

[E84 Test Method for Surface Burning Characteristics of Building Materials](#)

[E176 Terminology of Fire Standards](#)

[E603 Guide for Room Fire Experiments](#)

[E662 Test Method for Specific Optical Density of Smoke Generated by Solid Materials](#)

[E906 Test Method for Heat and Visible Smoke Release Rates for Materials and Products Using a Thermopile Method](#)

[E1354 Test Method for Heat and Visible Smoke Release Rates for Materials and Products Using an Oxygen Consumption Calorimeter](#)

[E1474 Test Method for Determining the Heat Release Rate of Upholstered Furniture and Mattress Components or Composites Using a Bench Scale Oxygen Consumption Calorimeter](#)

[E1537 Test Method for Fire Testing of Upholstered Furniture](#)

[E1590 Test Method for Fire Testing of Mattresses](#)

[IEEE/ASTM SI-10 Practice for Use of the International System of Units \(SI\): The Modernized Metric System](#)

2.2 ANSI/AHA Standard:⁴

[A135.4 Basic Hardboard](#)

2.3 ISO Standards:⁵

[ISO Guide 52—Glossary of Fire Terms and Definitions](#)

[ISO 3261 Fire Tests—Vocabulary](#)

[ISO 5659-2 Determination of Specific Optical Density by a Single-Chamber Test](#)

[ISO 5725 Precision of Test Methods—Determination of Repeatability and Reproducibility for Standard Test Method by Interlaboratory Tests](#)

2.4 British Standards:⁶

[BS 6809 Method of Calibration of Radiometers for Use in Fire Testing](#)

2.5 NFPA Standards:⁷

[NFPA 270 Standard Test Method for Measurement of Smoke Obscuration Using a Conical Radiant Source in a Single Closed Chamber](#)

3. Terminology

3.1 *Definitions*—For definitions of terms used in this test method, refer to Terminology [E176](#) and ISO 3261. In case of conflict, the definitions given in Terminology [E176](#) shall prevail.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ The last approved version of this historical standard is referenced on www.astm.org.

⁴ Available from American Hardboard Association, 1210 West Northwest Highway, Palatine, IL 60067, United States.

⁵ Available from International Standardization Organization, P.O. Box 56, CH-1211; Geneva 20, Switzerland, or from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036.

⁶ Available from British Standards Institute (BSI), 389 Chiswick High Rd., London W4 4AL, U.K.

⁷ Available from National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, MA 02169-7471, <http://www.nfpa.org>.

3.2 Definitions of Terms Specific to This Standard:

3.2.1 *assembly, n*—a unit or structure composed of a combination of materials or products, or both.

3.2.2 *continuous (as related to data acquisition), adj*—conducted at data collection intervals of 5s or less.

3.2.3 *essentially flat surface, n*—surface where the irregularity from a plane does not exceed ± 1 mm.

3.2.4 *exposed surface, n*—that surface of the specimen subjected to the incident heat.

3.2.5 *flaming mode, n*—the mode of testing that uses a pilot flame.

3.2.6 *ignition, n*—the initiation of combustion.

3.2.6.1 Discussion—

The combustion may be evidenced by glow, flame, detonation, or explosion. The combustion may be sustained or transient.

3.2.7 *mass optical density, n*—the ratio of the optical density of smoke and the mass loss of the test specimen, multiplied by the volume of the test chamber and divided by the length of the light path.

3.2.7.1 Discussion—

The mass optical density as determined in this test method is not an intrinsic material property; it is a function of the test procedure and conditions used.

3.2.8 *Nonflaming mode, n*—the mode of testing that does not use a pilot flame.

3.2.9 *sample, n*—an amount of the material, product, or assembly, to be tested, which is representative of the item as a whole.

3.2.10 *smoke obscuration, n*—the reduction in visibility due to smoke (ISO Guide 52).

3.2.11 *specimen, n*—the actual section of material, product, or assembly, to be placed in the test apparatus.

3.2.12 *time to ignition, n*—time between the start of the test and the presence of a flame on the specimen surface for a period of at least 4s.

4. Summary of Test Method

4.1 This test method assesses the reduction of light by smoke obscuration from a burning sample. The test method employs a conically-shaped, electrically-heated, radiant-energy source to produce irradiance levels of 25 and 50 kW/m², averaged over the center of the exposed surface of an essentially flat specimen, and mounted horizontally inside a closed chamber. The equipment is suitable for testing at irradiance levels of up to 50 kW/m².

4.2 The specimen is 75 by 75 mm {3(3 by 3 in.;in.)}, at a thickness not exceeding 25 mm {1 in.;(1 in.)} and is mounted horizontally within a holder.

4.3 The exposure is conducted in the presence or in the absence of a pilot flame (see details in 6.3.6). If a pilot flame is used for ignition, the test is deemed to be in the “flaming” mode; if a pilot flame is not used, the test is deemed to be in the “nonflaming” mode.

4.4 The test specimens are exposed to flaming or nonflaming conditions within a closed chamber. A photometric system with a vertical light path is used to measure the varying light transmission as smoke accumulates. The light transmittance measurements are used to calculate the specific optical density of the smoke generated during the test.

4.5 The specimens are exposed to two conditions, out of the four standard exposure conditions, to be chosen by the test requester. The four standard exposure conditions are: flaming mode at an irradiance of 25 kW/m², flaming mode at an irradiance of 50

kW/m²; nonflaming mode at an irradiance of 25 kW/m²; and, nonflaming mode at an irradiance of 50 kW/m². Unless specified otherwise, conduct testing in the two flaming mode exposure conditions (see 8.3, X1.3 and X1.4). Exposures to other irradiances also are possible.

4.6 Mass optical density is an optional fire-test-response characteristic obtainable from this test method, by using a load cell, which continuously monitors the mass of the test specimen (see Annex A1).

5. Significance and Use

5.1 This test method provides a means for determining the specific optical density of the smoke generated by specimens of materials, products, or assemblies under the specified exposure conditions. Values determined by this test are specific to the specimen in the form and thickness tested and are not inherent fundamental properties of the material, product, or assembly tested.

5.2 This test method uses a photometric scale to measure smoke obscuration, which is similar to the optical density scale for human vision. The test method does not measure physiological aspects associated with vision.

5.3 At the present time no basis exists for predicting the smoke obscuration to be generated by the specimens upon exposure to heat or flame under any fire conditions other than those specified. Moreover, as with many smoke obscuration test methods, the correlation with measurements by other test methods has not been established.

5.4 The current smoke density chamber test, Test Method E662, is used by specifiers of floor coverings and in the rail transportation industries. The measurement of smoke obscuration is important to the researcher and the product development scientist. This test method, which incorporates improvements over Test Method E662, also will increase the usefulness of smoke obscuration measurements to the specifier and to product manufacturers.

5.4.1 The following are improvements offered by this test method over Test Method E662: the horizontal specimen orientation solves the problem of melting and flaming drips from vertically oriented specimens; the conical heat source provides a more uniform heat input; the heat input can be varied over a range of up to 50 kW/m², rather than having a fixed value of 25 kW/m²; and, the (optional) load cell permits calculations to be made of mass optical density, which associates the smoke obscuration fire-test-response characteristic measured with the mass loss.

5.5 Limitations⁸:

<https://standards.iteh.ai/catalog/standards/sist/4e74f818-6899-497d-90e7-2fd0d23ed905/astm-e1995-21>

5.5.1 The following behavior during a test renders that test invalid: a specimen being displaced from the zone of controlled irradiance so as to touch the pilot burner or the pilot flame; extinction of the pilot flame (even for a short period of time) in the flaming mode; molten material overflowing the specimen holder; or, self-ignition in the nonflaming mode.

5.5.2 As is usual in small-scale test methods, results obtained from this test method have proven to be affected by variations in specimen geometry, surface orientation, thickness (either overall or individual layer), mass, and composition.

5.5.3 The results of the test apply only to the thickness of the specimen as tested. No simple mathematical formula exists to calculate the specific optical density of a specimen at a specimen thickness different from the thickness at which it was tested. The literature contains some information on a relationship between optical density and specimen thickness **{(1)}**.⁹

5.5.4 Results obtained from this test method are affected by variations in the position of the specimen and radiometer relative to the radiant heat source, since the relative positioning affects the radiant heat flux (see also Appendix X2).

5.5.5 The test results have proven sensitive to excessive accumulations of residue in the chamber, which serve as additional insulators, tending to reduce normally expected condensation of the aerosol, thereby raising the measured specific optical density (see 5.5.8.3 and 11.1.2).

5.5.6 The measurements obtained have also proven sensitive to differences in conditioning (see Section 10). Many materials,

⁸ Some of these limitations are common to many small scale fire-test-response methods.

⁹ The boldface numbers in parentheses refer to the list of references at the end of this standard.

products, or assemblies, such as some carpeting, wood, plastics, or textiles, require long periods to attain equilibrium (constant weight) even in a forced-draft conditioning chamber. This sensitivity reflects the inherent natural variability of the sample and is not specific to the test method.

5.5.7 In this procedure, the specimens are subjected to one or more specific sets of laboratory test conditions. If different test conditions are substituted or the end-use conditions are changed, it is not necessarily possible by or from this test method to predict changes in the fire-test-response characteristics measured; therefore, the results are valid only for the fire test exposure conditions described in this procedure.

5.5.8 This test method solves some limitations associated with other closed chamber test methods, such as Test Method E662(2-56) (see 5.4.1). The test method retains some limitations related to closed chamber tests, as detailed in 5.5.8.1 – 5.5.8.5.

5.5.8.1 Information relating the specific optical density obtained by this test method to the mass lost by the specimen during the test is possible only by using the (optional) load cell, to determine the mass optical density (see Annex A1).

5.5.8.2 All specimens consume oxygen when combusted. The smoke generation of some specimens (especially those undergoing rapid combustion and those which are heavy and multilayered) is influenced by the oxygen concentration in the chamber. Thus, if the atmosphere inside the chamber becomes oxygen-deficient before the end of the experiment, combustion may cease for some specimens; therefore, it is possible that those layers furthest away from the radiant source will not undergo combustion.

5.5.8.3 The presence of walls causes losses through deposition of combustion particulates.

5.5.8.4 Soot and other solid or liquid combustion products settle on the optical surfaces during a test, resulting in potentially higher smoke density measurements than those due to the smoke in suspension.

5.5.8.5 This test method does not carry out dynamic measurements as smoke simply continues filling a closed chamber; therefore, the smoke obscuration values obtained do not represent conditions of open fires.

6. Apparatus and Ancillary Equipment

6.1 *General*—The apparatus (Fig. 1) consists of an air-tight test chamber with provision for containing a sample holder, radiation




FIG. 1 Typical Arrangement of Test Chamber

cone, pilot burner, a light transmission and measuring system and other ancillary facilities for controlling the conditions of operation during a test.¹⁰

6.2 Test Chamber:

6.2.1 Construction:

6.2.1.1 Fabricate the test chamber (Figs. 1 and 2) from laminated panels, the inner surfaces of which shall consist of either a porcelain-enamelled metal, not more than $1 \pm 0.1 \text{ mm}$ [$0.04(0.04 \pm 0.004 \text{ in.})$] thick, or an equivalent coated metal, which is resistant to chemical attack and corrosion and capable of easy cleaning. The internal dimensions of the chamber shall be $914 \pm 3 \text{ mm}$ long, $914 \pm 3 \text{ mm}$ high and $610 \pm 3 \text{ mm}$ deep [$36(36 \pm 0.1 \text{ in. by } 36 \pm 0.1 \text{ in. by } 24 \pm 0.1 \text{ in.})$] (Fig. 2, where the numbers are dimensions, in mm). Provide the chamber with a hinged front-mounted door with an observation window and a removable opaque door cover to the window to prevent light entering the chamber.


6.2.1.2 Fit the chamber with a safety blow-out panel, consisting of a sheet of aluminum foil of thickness not greater than 0.04 mm [$1.6(1.6 \times 10^{-3} \text{ in.})$] and having a minimum area of $80\,600 \text{ mm}^2$ [$25(125 \text{ in.}^2)$], fastened in such a way as to provide an airtight seal. Figs. 1 and 2 show the blow-out panel location.¹¹

6.2.1.3 Mount two optical windows, each with a diameter of $75 \pm 1 \text{ mm}$ [$3(3 \pm 0.04 \text{ in.})$], one each in the top and bottom of the cabinet, at the position shown in Fig. 2, with their interior faces flush with the outside of the cabinet lining. Provide the underside of the window on the floor with an electric heater of $9 \pm 1 \text{ W}$ capacity, in the form of a ring, which shall be capable of maintaining the upper surface of the window at a temperature just sufficient to minimize smoke condensation on that face.¹² Mount the heater around the window edge so as not to interrupt the light path (Fig. 2).

6.2.1.4 Mount optical platforms, $8 \pm 0.1 \text{ mm}$ [$0.31(0.31 \pm 0.004 \text{ in.})$] thick, around the windows on the outside of the chamber and hold them rigidly in position relative to each other by three metal rods, with a diameter of at least 12.5 mm [$0.5(0.5 \text{ in.})$], extending through the chamber and fastened securely to the platforms.

6.2.1.5 Provide other openings in the cabinet for services, as specified. They shall be capable of being closed so as to develop a positive pressure of up to 1.5-kPa (150-mm water gage) above atmospheric pressure inside the chamber (see 6.2.2) and maintained when checked in accordance with 6.6 and 9.6. All components of the chamber shall be capable of withstanding a greater internal positive pressure than the safety blow-out panel.

6.2.1.6 Provide an inlet vent with shutter in the front of the chamber at the top and away from the radiator cone. Also, provide




NOTE 1—All dimensions in this figure are given in mm unless stated otherwise.

FIG. 2 Plan View of Typical Test Chamber

¹⁰ A list of suppliers for such equipment is available from ASTM Headquarters.


¹¹ Stainless steel wire mesh for fastening the aluminum foil, offers adequate protection for the blow-out panel.

¹² A window temperature of at least $50\text{-}55^\circ\text{C}$ [$122\text{-}131^\circ\text{F}$] $50\text{-}55^\circ\text{C}$ ($122\text{-}131^\circ\text{F}$) has been found suitable and normally is achieved with a 9W heater.



NOTE 1—All dimensions in this figure are given in mm unless stated otherwise.


FIG. 3 Typical Chamber Pressure Relief Manometer



NOTE 1—All dimensions in this figure are given in mm unless stated otherwise.


FIG. 4 Cross-sectional View Through the Radiator Cone Heater

an exhaust vent with shutter in the bottom of the chamber to lead, via flexible pipe with a diameter of 50 to 100 mm (2 to 4 in.), to an extraction fan capable of creating a negative pressure of at least 0.5-kPa (50-mm water gage).



NOTE 1—All dimensions in this figure are given in mm unless stated otherwise.

FIG. 5 Typical Framework for Support of Radiator Cone, Specimen and Flux Meter



NOTE 1—The dimensions in this figure are given in mm unless stated otherwise.

FIG. 6 Typical Arrangement of Radiator Cone, Specimen Holder and Radiator Shield (Side View)

6.2.2 *Sensor for Chamber Pressure Measurements*—A pressure sensor (for example, a manometer or pressure transducer) with a range up to 6 in. (152 mm) of water (1.5 kPa) shall be provided to monitor chamber pressure and leakage. The pressure measurement point shall be through a gas sampling port in the chamber.

6.2.3 *Chamber Pressure Relief System*—A simple water column or relief valve shall be provided to permit control of chamber pressure.

6.2.4 *Chamber Temperature*—A thermocouple junction, made from wires of diameter not greater than 1 mm {0.04 in.}(0.04 in.), shall be mounted on the inside of the back wall of the chamber, at the geometric center, by means of an insulating disc, such as polystyrene foam, with a thickness of 6.5 ± 0.2 mm {0.25 in.}(0.25 in.) and a diameter of not more than 20 mm {0.8 in.}(0.8 in.) attached with a suitable cement. The thermocouple junction shall be connected to a recorder, meter, or data acquisition unit, and the system shall be suitable for measuring temperatures in the range of 35 to 60 °C {64(64 to 140 °F)} (see 11.1.4).

6.3 Sample Support and Heating Arrangements:

6.3.1 Radiator Cone:

6.3.1.1 The radiator cone (Fig. 4) shall consist of a heating element, of nominal rating 450 W, contained within a stainless steel tube, 2210 ± 5 mm [$87(87 \pm 0.2$ in.)] in length and 6.5 ± 0.2 mm [$0.25(0.25 \pm 0.008$ in.)] in diameter, coiled into the shape of a truncated cone and fitted into a shade. The shade shall have an overall height of 45 ± 0.04 mm [$1.8(1.8 \pm 0.02$ in.)], an internal diameter of 55 ± 1 mm [$2.2(2.2 \pm 0.04$ in.)] and an internal base diameter of 110 ± 3 mm [$4.3(4.3 \pm 0.1$ in.)]. It shall consist of two layers of 1 ± 0.1 mm [0.04 ± 0.004 in.] 0.1 mm (0.04 ± 0.004 in.) thick stainless steel with a 10 ± 0.5 -mm [$0.4(0.4 \pm 0.02$ in.)] thickness of ceramic fibre insulation of nominal density 100 kg/m³ [$6.2(6.2$ lb/ft³)], sandwiched between them. Clamp the heating element by two plates at the top and bottom of the element (see also Appendix X1).

6.3.1.2 The radiator cone shall be capable of providing irradiance in the range 10 to 50 kW/m², at the center of the surface of the specimen. The irradiance shall also be determined at a position of 25 ± 2 mm [1 ± 0.08 in.] to each side of the specimen center, and the irradiance at these two positions shall be not less than 85 %, and not more than 115 %, of the irradiance at the center of the specimen.

6.3.1.3 The irradiance of the radiator cone shall be controlled by reference to the averaged reading of two type K thermocouples. The thermocouples shall be 1.6 ± 0.2 mm [$0.055(0.055$ to 0.071 in.)] outside diameter, sheathed with an unexposed hot junction, mounted diametrically opposite, in contact with, but not welded to, the heating element, and positioned at one third of the distance from the top surface of the cone. It has been found that thermocouples of equal length and wired in parallel to the temperature controller perform adequately; alternate wiring methods shown to give equivalent results also are acceptable (see also Appendix X2).¹³

6.3.1.4 The temperature at the heater is to be controlled and shall be held steady to $\pm 2^\circ\text{C}$ [$\pm 4^\circ\text{F}$], ± 2 °C (± 4 °F). The temperature controller for the radiator cone shall be of the proportional, integral and derivative Type 3-term controller with thyristor stack fast-cycle or phase angle control of not less than 10 A max rating. Capacity for adjustment of integral time between ~~10s and 50s~~ 10 s and 50 s and differential time between ~~25s and 30s~~ 25 s and 30 s shall be provided to permit reasonable matching with the response characteristics of the heater. A temperature input range of 0 to ~~1000°C~~ [~~32 to 1832°F~~] 1000 °C (32 to 1832 °F) is suitable; an irradiance of 50 kW/m² will be given by a heater temperature in the 700 to ~~750°C~~ [~~1292 to 1382°F~~] 750 °C (1292 to 1382 °F) temperature range. Automatic cold junction compensation of the thermocouple shall be provided. The described design has been shown to be satisfactory; alternate devices shown to give equivalent results are also acceptable.¹⁴

6.3.2 Framework for Support of the Radiator Cone, Specimen Holder, and Heat-Flux Meter:

6.3.2.1 The radiator cone shall be secured from the vertical rods of the support framework and located so that the lower rim of the radiator cone shade is 25 ± 1 mm [1 ± 0.04 in.] above the upper surface of the specimen, when oriented in the horizontal position. Details of the radiator cone and supports are shown in Figs. 5 and 6. The base of the specimen holder contains a height adjustment device to ensure a consistent distance between radiator cone and specimen surface.

6.3.3 Radiation Shield—The cone heater shall be provided with a removable radiation shield to protect the specimen from the irradiance prior to the start of the test. The radiation shield shall be made of noncombustible material with a total thickness not to exceed 12 mm. The radiation shield shall comply with either 6.3.3.1 or 6.3.3.2 and shall be kept in place for a maximum period of 10s.¹⁵

6.3.3.1 A water-cooled radiation shield coated with a durable matte black finish of surface emissivity $e = 0.95 \pm 0.05$; or,

6.3.3.2 A radiation shield with a reflective top surface in order to minimize radiation transfer but not water-cooled.

6.3.3.3 The radiation shield shall be equipped with a handle or other suitable means for quick insertion and removal. The cone heater base plate shall be equipped with the means for holding the radiation shield in position and allowing its easy and quick removal.¹⁶

6.3.4 Heat Flux Meter:


6.3.4.1 The heat flux meter shall be of the Schmidt-Boelter (thermopile) type, with a design range of at least 50 kW/m². The

¹³ Sheathed chromel/alumel type K thermocouples have been found suitable for this purpose.

¹⁴ While phase angle control is allowed for the temperature controller of the radiator cone, it must be noted that this usually will require electrical filtering to avoid the risk of inducing noise in low signal level lines.

¹⁵ It is possible that the use of a radiation shield for periods longer than 10s will affect radiator heat control and, consequently, the heat-flux level applied to the specimen.

¹⁶ This device is necessary in order to enable repeat tests to be carried out without switching off the radiator cone.



NOTE 1—The dimensions in this figure are given in mm unless stated otherwise.

FIG. 7 Specimen Holder

sensing surface of the heat flux meter (Fig. 5) shall have a flat, circular face of 10 ± 1 -mm $\{0.4(0.4 \pm 0.04\text{-in.})\}$ diameter, coated with a durable matt black finish. The heat flux meter shall be water-cooled^{17, 18} and shall have an accuracy of $\pm 3\%$ (see also Appendix X2).

6.3.4.2 The heat flux meter shall be connected directly to a suitable recorder, or data acquisition unit (6.8.6), so that it is capable, when calibrated, of recording heat fluxes of 25 kW/m^2 and 50 kW/m^2 .¹⁹

6.3.4.3 For calibration of the heat flux meter system, see 9.8.

6.3.5 Specimen Holders:

6.3.5.1 Details of the specimen holder are shown in Fig. 7. The base shall be lined with a low density (nominally 65 kg/m^3 $\{4(4 \text{ lb/ft}^3)\}$) refractory fibre blanket, with a minimum thickness of 10 mm $\{0.4\text{-in.}\}$.

6.3.5.2 A retainer frame and wire grid shall be used for all tests. The wire grid shall be 75 ± 1 -mm $\{3 \pm 0.04\text{-in.}\}$ 1 mm $\{3 \pm 0.04\text{-in.}\}$ square with $20 \pm 0.5 \text{ mm}$ $\{0.8(0.8 \pm 0.02 \text{ in.})\}$ square holes constructed from $2 \pm 0.2 \text{ mm}$ $\{0.08(0.08 \pm 0.008 \text{ in.})\}$ stainless steel rod, welded at all intersections.²⁰

6.3.6 Pilot Burner:


6.3.6.1 The flame from the single-flame burner, Fig. 8, shall have a length of $30 \pm 5 \text{ mm}$ $\{1.2(1.2 \pm 0.2 \text{ in.})\}$ and shall be positioned horizontally $10 \pm 1 \text{ mm}$ $\{0.4(0.4 \pm 0.04 \text{ in.})\}$ above the top face of the specimen. The color of the flame shall be blue, with a yellow tip. Ensure that the tip of the burner is aligned with the edge of the specimen, as shown in Fig. 9.

¹⁷ If the cooling temperature is lower than the temperature at which the gage is calibrated, condensation on the sensor is possible and would lead to serious measurement errors.


¹⁸ The manufacturer of Schmidt-Boelter gages has the following specifications for cooling water: pressure 413-621 kPa, temperature 20.0–26.6°C and flow rate 0.76–1.14 L/min.

¹⁹ If a chart recorder which only displays a millivolt output is used, the millivolt value shall be converted to heat flux, in kW/m^2 , using the calibration factor (or equation, if appropriate) specific to the heat flux meter.

²⁰ The retainer frame and wire grid particularly are appropriate when testing intumescent specimens and also for reducing unrepresentative edge combustion of composite samples or for retaining specimens prone to delamination. The wire grid is likely to affect the test results, compared to tests conducted in its absence; however, its use is recommended for several reasons: it helps to promote uniformity in testing by different laboratories, in view of the expected effect of the retainer frame and wire grid on test results, it is needed for certain specimens, as explained above, and it is required in ISO 5659–2.




Plan



Section

NOTE 1—The dimensions in this figure are given in mm unless stated otherwise.

FIG. 9 Detailed Location of Pilot Burner



NOTE 1—The dimensions in this figure are given in mm unless stated otherwise.

FIG. 8 Typical Arrangement of Radiator Cone, Specimen Holder and Radiator Shield (Front View)

6.3.6.2 Install a small spark ignition device, sited next to the outlet tube of the burner, for the operator to cause reignition of the flame without opening the door of the chamber. A suitable system is a spark plug with a 3-mm [0.11-in.]–3 mm (0.11-in.) gap, powered from a 10-kV transformer. A suitable transformer is of a type specifically designed for spark-ignition use, with an isolated (ungrounded) secondary to minimize interference with the data-transmission lines. An acceptable electrode length and spark plug location is such that the spark gap is located 13 mm [0.5 in.]–(0.5 in.) above the specimen, close to the pilot burner.

6.4 Gas Supply:

6.4.1 A mixture of propane, of at least 95 % purity and at a pressure of 3.5 ± 1 -kPa (350 ± 100 -mm water gage), and air at a pressure of 170 ± 30 -kPa (17 ± 3 -m water gage) shall be supplied to the burner. Each gas shall be fed to a point at which they are mixed and supplied to the burner.

6.4.2 The use of needle valves and calibrated flowmeters is a suitable method of controlling gas flows. The flowmeter for the propane supply shall be capable of measuring $50 \text{ cm}^3/\text{min}$ [~~$18(18 \times 10^{-4} \text{ ft}^3/\text{min})/\text{min}$~~] flow rates and that for air a value of $500 \text{ cm}^3/\text{min}$ [~~$18(18 \times 10^{-3} \text{ ft}^3/\text{min})/\text{min}$~~]. Alternate devices shown to give equivalent results are also acceptable.

6.5 Photometric System:

6.5.1 General:

6.5.1.1 The photometric system shall consist of a light source and lens in a light-tight housing mounted below the optical window in the floor of the cabinet, and a photo-detector with lens, filters and shutter in a light-tight housing above the optical window in the top of the chamber.

6.5.1.2 The system shall be as shown in Fig. 10. Equipment shall be provided to control the output of the light source and to measure the amount of light falling on the photo-detector.

6.5.2 Light Source:

6.5.2.1 The light source shall be a 6.5 V incandescent lamp. Power for the lamp shall be provided by a transformer producing 6.5 V and a rheostat so that the r.m.s. voltage across the lamp, as determined by a voltmeter, is maintained at 4 ± 0.2 V. The lamp shall be mounted in the lower light-tight box, and a lens to provide a collimated light beam of ~~51-mm [2-in.]~~ 51 mm (2-in.) diameter, passing towards and through the optical window on the floor of the chamber, shall be mounted, with provision for adjustment, to control the collimated beam in direction and diameter. The housing shall be provided with a cover to allow access for adjustments to be made to the position of the lens.

6.5.3 Photo-Detector:

6.5.3.1 The light-measuring device system shall consist of a photo-multiplier tube connected to a multirange amplifier coupled to a recording device, or data acquisition unit (6.8.6), capable of measuring continuously relative light intensity against time as percentage transmission over at least five orders of magnitude, with an S-4 spectral sensitivity response similar to that of human vision and a dark current less than 10^{-9} A. The system shall have a linear response with respect to transmittance and an accuracy of better than ± 3 % of the maximum reading on any range. For selection of photomultiplier tubes, as applicable, the minimum sensitivity shall allow a 100 % reading to be obtained with a 0.5 neutral density filter and an ND-2 range extension filter (see 6.5.3.2) in the light path. Provision shall be made for adjusting the reading of the instrument under given conditions over the full range of any scale.²¹

6.5.3.2 The photo-multiplier tube shall be mounted in the upper section of the detector housing. Below it, there shall be an assembly which provides for the rapid positioning of a filter and of a shutter, in or out of the path of the collimated light beam, each being operated separately. The filter, referred to as the range-extension filter (ND-2), shall be a glass neutral density filter of nominal optical density 2. When in the closed position, the shutter shall prevent all light in the test chamber from reaching the photo-multiplier tube. An opal diffuser shall be mounted permanently below the shutter.

6.5.3.3 The lower part of the housing shall support a 51 ± 1 -mm [~~2 ± 0.04 -in.]~~ 1 mm (2 ± 0.04 -in.) diameter lens, capable of being adjusted so that the collimated beam is focused to form a small intense spot of light at the disc aperture between the upper and lower parts of the housing. Above the lens, there shall be a mount for supporting one or more compensating filters from a set of nine gelatin neutral density filters, with optical density varying from 0.1 to 0.9 in steps of 0.1. The housing shall be provided with a cover, to allow access for adjustments to be made to the position of the lens and for inserting or removing filters.

²¹ The required accuracy of the photo-detector is obtained more easily if the measuring systems incorporate scale ranges of 30, 3, 0.3, etc., as well as ranges of 100, 10, 1, etc.