

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Switches for household and similar fixed electrical installations –
Part 2-3: Particular requirements – Time-delay switches (TDS)**

<https://standards.iteh.ai>

**Interrupteurs pour installations électriques fixes domestiques et analogues –
Partie 2-3 : Exigences particulières – Interrupteurs temporisés (minuteries)**

[IEC 60669-2-3:2024](https://standards.iteh.ai/catalog/standards/iec/f294fb74-8394-4eba-acbe-69e65c619dda/iec-60669-2-3-2024)

<https://standards.iteh.ai/catalog/standards/iec/f294fb74-8394-4eba-acbe-69e65c619dda/iec-60669-2-3-2024>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2024 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications, symboles graphiques et le glossaire. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 500 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 25 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.



INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Switches for household and similar fixed electrical installations –
Part 2-3: Particular requirements – Time-delay switches (TDS)**

**Interrupteurs pour installations électriques fixes domestiques et analogues –
Partie 2-3 : Exigences particulières – Interrupteurs temporisés (minuteriers)**

[IEC 60669-2-3:2024](https://standards.iteh.ai/catalog/standards/iec/f294fb74-8394-4eba-acbe-69e65c619dda/iec-60669-2-3-2024)

<https://standards.iteh.ai/catalog/standards/iec/f294fb74-8394-4eba-acbe-69e65c619dda/iec-60669-2-3-2024>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.120.40

ISBN 978-2-8322-8322-6

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	3
1 Scope.....	5
2 Normative references	5
3 Terms and definitions	6
4 General requirements	7
5 General remarks on tests	7
6 Ratings.....	8
7 Classification.....	8
8 Marking	9
9 Checking of dimensions.....	10
10 Protection against electric shock	10
11 Provision for earthing	10
12 Terminals	10
13 Constructional requirements	11
14 Mechanism	11
15 Resistance to ageing, protection provided by enclosures of switches and resistance to humidity.....	11
16 Insulation resistance and electric strength	11
17 Temperature rise	12
18 Making and breaking capacity.....	12
19 Normal operation	13
20 Mechanical strength	14
21 Resistance to heat.....	14
22 Screws, current-carrying parts and connections.....	14
23 Creepage distances, clearances and distances through sealing compound.....	15
24 Resistance of insulating material to abnormal heat, to fire and to tracking	16
25 Resistance to rusting	16
26 EMC requirements.....	17
Annexes	18
Annex B (informative) Changes planned for the future in order to align IEC 60669-1 with the requirements of IEC 60998 (all parts), IEC 60999 (all parts) and IEC 60228	19
Annex E (informative) Additional requirements and tests for switches intended to be used at a temperature lower than –5 °C.....	20
Bibliography.....	21
Table 1 – Number of specimens needed for the tests.....	7
Table 15 – Test voltage, points of application and minimum values of insulating resistance for the verification of electric strength	12
Table 23 – Creepage distances, clearances and distances through insulating sealing compound.....	15

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**SWITCHES FOR HOUSEHOLD AND SIMILAR FIXED
ELECTRICAL INSTALLATIONS –****Part 2-3: Particular requirements –
Time-delay switches (TDS)**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60669-2-3 has been prepared by subcommittee 23B: Plugs, socket-outlets and switches, of IEC technical committee 23: Electrical accessories. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2006. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Revision of the present edition with reference to IEC 60669-1:2017 (Edition 4);
- b) Introduction of a revision to Annex E "Additional requirements and tests for switches intended to be used at a temperature lower than -5 °C ".

The text of this International Standard is based on the following documents:

Draft	Report on voting
23B/1487/FDIS	23B/1501/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This part of IEC 60669-2 is to be used in conjunction with IEC 60669-1:2017. It lists the changes necessary to convert that standard into a specific standard for time-delay switches.

When a particular subclause of IEC 60669-1:2017 is not mentioned in this document, that subclause applies as far as reasonable.

In this document, the following print types are used:

- requirements proper: in roman type;
- *test specifications*: in italic type;
- notes: in smaller roman type.

Subclauses, figures or tables which are additional to those in IEC 60669-1:2017 are numbered starting from 101.

A list of all parts of IEC 60669 series, under the general title *Switches for household and similar fixed electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

SWITCHES FOR HOUSEHOLD AND SIMILAR FIXED ELECTRICAL INSTALLATIONS –

Part 2-3: Particular requirements – Time-delay switches (TDS)

1 Scope

IEC 60669-1:2017, Clause 1 is applicable except as follows:

Replacement of the first paragraph with the following:

This part of IEC 60669 applies to time-delay switches (hereinafter referred to as TDS) with a rated voltage not exceeding 440 V AC and a rated current not exceeding 63 A, intended for household and similar fixed electrical installations, either indoors or outdoors, operated by hand and/or by remote control. For the control circuit, the rated control voltage does not exceed 440 V AC or 220 V DC.

TDS are provided with a time-delay device operated by mechanical, thermal, pneumatic, hydraulic or electrical means or by a combination of them.

Electronic TDS are within the scope of IEC 60669-2-1 but not of this document.

TDS including only passive components such as resistors, capacitors, positive temperature coefficient (PTC) and negative temperature coefficient (NTC) components and printed circuit boards are not considered to be electronic TDS.

2 Normative references

IEC 60669-1:2017, Clause 2 is applicable with the following additions:

IEC 60317 (all parts), *Specifications for particular types of winding wires*

IEC 60445:2021, *Basic and safety principles for man-machine interface, marking and identification – Identification of equipment terminals, conductor terminations and conductors*

IEC 60664-1:2020, *Insulation coordination for equipment within low-voltage supply systems – Part 1: Principles, requirements and tests*

IEC 60664-3:2016, *Insulation coordination for equipment within low-voltage systems – Part 3: Use of coating, potting or moulding for protection against pollution*

IEC 60669-1:2017, *Switches for household and similar fixed electrical installations – Part 1: General requirements*

IEC 61558-2-6:2021, *Safety of transformers, reactors, power supply units and combinations thereof – Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers for general applications*

3 Terms and definitions

IEC 60669-1:2017, Clause 3 is applicable with the following modifications:

3.8

thread-cutting screw

Addition of the following note:

Note 101 to entry: This definition is applicable to the switching circuit only.

3.9

mechanical time-delay device

Addition of the following note:

Note 101 to entry: This definition is applicable to the switching circuit only.

Addition of the following new terminological entries:

3.101

time-delay switch

TDS

switch provided with a time-delay device which operates for a certain time (the delay time)

Note 101 to entry: Time-delay switches may be either manually actuated and/or remotely electrically initiated.

3.101.1

electronic TDS

TDS containing electronic component(s)

3.102

rated control voltage

voltage assigned to the control circuit by the manufacturer

3.103

switching circuit

circuit which contains the parts which allow the rated current to flow through the TDS

3.104

control circuit

circuit which includes electrical parts to control the switching circuit in an electrically controlled TDS

3.105

control mechanism

all parts which are intended for the operation of the TDS

3.106

incorporated hand-operated device

device which allows the switching circuit to be operated, directly or indirectly

Note 101 to entry: An incorporated hand-operated device is not intended for the normal operation of the TDS.

3.107

delay time

period during which the switching circuit(s) is (are) kept closed

Note 101 to entry: Any time taken for the decreasing of the voltage (e.g. to reduce the light) at the end of the delay period is included within the delay time.

3.108**delay device**

all components which have an influence on the delay time

Note 101 to entry: The delay device is energized by means of an impulse into the control circuit in an electrically controlled TDS.

Note 102 to entry: The delay time may be adjustable.

3.109**disconnectable TDS**

TDS consisting of two parts, the first being used as a base and including the terminals, the other being removable and including the switching and the control circuits, the two parts being resiliently connected together using a means which allows joining and/or separating with or without the use of a tool

4 General requirements

IEC 60669-1:2017, Clause 4 is applicable with the following addition:

Addition of the following after the first paragraph:

The operation of a TDS shall not be impaired when it is mounted at an angle deviating by not more than 5° from the specified position of use.

5 General remarks on tests

IEC 60669-1:2017, Clause 5 is applicable with the following additions:

Addition to Table 1:

Table 1 – Number of specimens needed for the tests

Clauses and subclauses	Number of specimens	Number of additional specimens for dual current rating
101 Abnormal operation of the control circuit	PQR	

Addition of the following subclauses:

5.101 Incorporated hand-operated device

If a TDS is provided with an incorporated hand-operated device, actuating the switching circuit directly, it shall be tested as specified in 19.101.

5.102 Operated by hand

For a TDS operated by hand, the requirements relating to the control voltage do not apply.

5.103 Control and switching circuits without common point

In the case of a TDS for which the control and the switching circuits have no common point, the test is made with the circuits supplied with the rated voltages which are specified in this document.

6 Ratings

IEC 60669-1:2017, Clause 6 is applicable except as follows:

6.1 Rated voltage

Replacement of the first paragraph with the following:

Preferred values of rated voltage are:

- AC: 6 V, 8 V, 9 V, 12 V, 24 V, 42 V, 48 V, 110 V, 130 V, 220 V, 230 V and 240 V;

NOTE These rated voltages are aligned with the rated control voltages specified in 6.101 to simplify the tests on TDS having a common point between the control and switching circuits.

Addition of the following subclause:

6.101 Rated control voltage

Preferred values of rated control voltage are:

- AC: 6 V, 8 V, 9 V, 12 V, 24 V, 42 V, 48 V, 110 V, 130 V, 220 V, 230 V and 240 V;
- DC: 6V, 9 V, 12 V, 24 V, 48 V, 60 V, 110 V and 220 V.

7 Classification

IEC 60669-1:2017, Clause 7 is applicable except as follows:

7.1 according to the possible connections (see Figure 8 of IEC 60669-1:2017):

Replace the existing nine-dash list with the following:

[IEC 60669-2-3:2024](https://standards.iteh.ai/catalog/standards/iec/f294fb74-8394-4eba-acbe-69e65c6190)

<https://standards.iteh.ai/catalog/standards/iec/f294fb74-8394-4eba-acbe-69e65c6190> Pattern number -3-2024

- single-pole switches 1
- double-pole switches 2
- three-pole switches 3
- three-pole plus switched neutral switches 03
- two-way switches 6

7.5 according to the method of actuating a switch:

Addition of the following:

- time-delay switches (TDS):
 - manually operated;
 - remotely operated;
 - manually and remotely operated.

NOTE The above methods of operation can be combined with a complementary method of operation allowing permanent ON and/or permanent OFF. These possibilities are given by a complementary device acting either directly on the switching circuit, or on the control circuit.

7.7 according to the method of installation, as a consequence of the design of the switch

Addition of the following:

- disconnectable TDS;

Addition of the following subclause:

7.101 according to the type of control mechanism:

- mechanical;
- thermal;
- pneumatic;
- hydraulic;
- electrical;
- combination(s) of the above.

8 Marking

IEC 60669-1:2017, Clause 8 is applicable with the following additions:

8.1 General

Replacement of list item b) with the following:

- b) rated voltage(s) in volts and rated control voltage(s) in volts, if different from the rated voltage(s);

Addition of the following after list item m):

Switches shall be also marked with [IEC 60669-2-3:2024](https://standards.iteh.ai/catalog/standards/iec/f294fb74-8394-4eba-acbe-69e65c619dda/iec-60669-2-3-2024)

<https://standards.iteh.ai/catalog/standards/iec/f294fb74-8394-4eba-acbe-69e65c619dda/iec-60669-2-3-2024>

- n) symbol for the adjustment of the delay time, if applicable;
- o) symbols for the positions "Permanent ON" and "Permanent OFF", if applicable;
- p) symbol for "Delay time".


Addition after Note 5:

NOTE 101 If a delay time value is indicated, it can be expressed in seconds, minutes and hours.


8.2 Addition of the following symbols:

Permanent ON

If the TDS may also be remote controlled, the symbol | is not to be used.



Delay time




Permanent OFF but only if the air gap of the switching contact of the TDS is not less than 3 mm




Adjustment of delay time



Control mechanism



Switch



NOTE 101 In the following country, the symbol consisting of 2 concentric circles is not used to indicate time delay: UK.

8.3 Visibility of markings

Replace the second paragraph with the following:

Markings as given in 8.1 a), b), c), d), e) and, if applicable, f), g), h), k), l), n), o) and p) shall be placed on the main part of the TDS.

8.4 Marking on terminals for phase conductors

Addition of the following after the fourth paragraph and before the notes of this Subclause 8.4:

If necessary, the wiring diagram on which the terminal reference is clearly indicated shall be fixed to the accessory or put inside the protective cover for the terminals.

The terminals of the control circuit shall be marked according to either IEC 60445 or with the symbols according to 8.2, or both.

[IEC 60669-2-3:2024](https://standards.iteh.ai/catalog/standards/iec/f294fb74-8394-4eba-acbe-69e65c619dda/iec-60669-2-3-2024)

<https://standards.iteh.ai/catalog/standards/iec/f294fb74-8394-4eba-acbe-69e65c619dda/iec-60669-2-3-2024>

9 Checking of dimensions

IEC 60669-1:2017, Clause 9 is applicable.

10 Protection against electric shock

IEC 60669-1:2017, Clause 10 is applicable.

11 Provision for earthing

IEC 60669-1:2017, Clause 11 is applicable.

12 Terminals

IEC 60669-1:2017, Clause 12 is applicable.