



Designation: **D4329 – 13** **D4329 – 21**

Standard Practice for Fluorescent Ultraviolet (UV) Lamp Apparatus Exposure of Plastics¹

This standard is issued under the fixed designation D4329; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reappraisal. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reappraisal.

1. Scope*

1.1 This practice covers specific procedures and test conditions that are applicable for using a fluorescent UV lamp and water apparatus exposure of plastics conducted in accordance with Practices **G151** and **G154**. This practice also covers the preparation of test specimens, the test conditions best suited for plastics, and the evaluation of test results.

1.2 The values stated in SI units are to be regarded as standard. The values given in parentheses are for information only.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, safety, health, and health environmental practices and determine the applicability of regulatory limitations prior to use.*

NOTE 1—This practice is technically similar to ISO 4892-3.

NOTE 1—This standard and ISO 4892-3 address the same subject matter, but differ in technical contact.

1.4 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 ASTM Standards:²

[D883 Terminology Relating to Plastics](#)

[D5870 Practice for Calculating Property Retention Index of Plastics](#)

[E456 Terminology Relating to Quality and Statistics](#)

[E691 Practice for Conducting an Interlaboratory Study to Determine the Precision of a Test Method](#)

[G113 Terminology Relating to Natural and Artificial Weathering Tests of Nonmetallic Materials](#)

[G141 Guide for Addressing Variability in Exposure Testing of Nonmetallic Materials](#)

[G147 Practice for Conditioning and Handling of Nonmetallic Materials for Natural and Artificial Weathering Tests](#)

[G151 Practice for Exposing Nonmetallic Materials in Accelerated Test Devices that Use Laboratory Light Sources](#)

[G154 Practice for Operating Fluorescent Ultraviolet \(UV\) Lamp Apparatus for Exposure of Nonmetallic Materials](#)

[G169 Guide for Application of Basic Statistical Methods to Weathering Tests](#)

[G177 Tables for Reference Solar Ultraviolet Spectral Distributions: Hemispherical on 37° Tilted Surface](#)

¹ This practice is under the jurisdiction of ASTM Committee **D20** on Plastics and is the direct responsibility of Subcommittee **D20.50** on Durability of Plastics. Current edition approved July 15, 2013; July 1, 2021. Published August 2013; July 2021. Originally approved in 1984. Last previous edition approved in 2005; 2013 as **D4329 – 05**; **D4329 – 13**. DOI: [10.1520/D4329-13.10.1520/D4329-21](https://doi.org/10.1520/D4329-13.10.1520/D4329-21).

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

*A Summary of Changes section appears at the end of this standard

2.2 ISO Standard:³

ISO 4892-3 Plastics—Methods of Exposure to Laboratory Light Sources—Part 3, Fluorescent UV Lamps

2.3 SAE Standard:⁴

SAE J2020 Accelerated Exposure of Automotive Exterior Materials Using a Fluorescent UV and Condensation Apparatus

3. Terminology

3.1 ~~The definitions in Terminology~~For definitions of terms relating to plastics used in this ~~G113~~ are applicable to practice, refer to Terminology ~~D883~~this practice.

3.2 For definitions of terms relating to precision and bias and associated used in this practice, refer to Terminology ~~E456~~.

3.3 For definitions of terms relating to weathering used in this practice, refer to Terminology ~~G113~~.

4. Significance and Use

4.1 The ability of a plastic material to resist deterioration of its electrical, mechanical, and optical properties caused by exposure to light, heat, and water can be very significant for is a property of significance in many applications. This practice is intended to induce property changes associated with end-use conditions, including the effects of ultraviolet solar irradiance, moisture, and heat. The exposure used in this practice is not intended to simulate the deterioration caused by localized weather phenomena, such as, atmospheric pollution, biological attack, and saltwater exposure. (**Warning**—Variation in results may be expected when operating conditions are varied within the accepted limits of this practice. practice will not necessarily provide the same results. Therefore, no reference to the use of this practice ~~should~~ shall be made unless accompanied by a report prepared in accordance with Section 8 that describes the specific operating conditions used. Refer to Practice ~~G151~~ for detailed information on the caveats applicable to use of results obtained in accordance with this practice.)

NOTE 2—Additional information on sources of variability and on strategies for addressing variability in the design, execution, and data analysis of laboratory-accelerated exposure tests is found in Guide ~~G141~~.

4.2 Reproducibility of test results between laboratories has been shown to be good when the stability of materials is evaluated in terms of performance ranking compared to other materials or to a control.^{5,6} Therefore, exposure of a similar material of known performance (a control) at the same time as the test materials is strongly recommended. It is recommended that at least three replicates of each material be exposed to allow for statistical evaluation of results.

4.3 Test results will depend upon the care that is taken to operate the equipment in accordance with Practice ~~G154~~. Significant factors include regulation of line voltage, temperature of the room in which the device operates, temperature control, and condition and age of the lamp.

5. Apparatus

5.1 Use of fluorescent UV apparatus that conforms to the requirements defined in Practices ~~G151~~ and ~~G154~~ is required to conform to this practice.

5.2 Unless otherwise specified, the spectral power distribution of the fluorescent UV lamp shall conform to the requirements in Practice ~~G154~~ for a UVA 340 lamp. ~~Fig. 1~~ is a spectral irradiance plot for a typical UVA-340 lamp and benchmark solar radiation.

NOTE 3—The source of the ultraviolet solar irradiance data in ~~Fig. 1~~ is the Standard ~~G177~~ standard solar spectrum.

5.3 Test Apparatus Location:

³ Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, <http://www.ansi.org>.

⁴ Available from SAE International (SAE), 400 Commonwealth Dr., Warrendale, PA 15096-0001, <http://www.sae.org>.

⁵ Fischer, R., "Results of Round Robin Studies of Light- and Water-Exposure Standard Practices," *Accelerated and Outdoor Durability Testing of Organic Materials, ASTM STP 1202*, Warren D. Ketola and Douglas Grossman, eds., American Society for Testing and Materials, Philadelphia, 1993.

⁶ Ketola, W., and Fischer, R., "Characterization and Use of Reference Materials in Accelerated Durability Tests," *VAMAS Technical Report No. 30*, available from NIST, Gaithersburg, MD.




FIG. 1 Representative Spectral Power Distribution of UVA-340 Fluorescent Lamps

ITeC Standards
(<https://standards.iteh.ai>)

Document Preview

ASTM D4329-21

5.3.1 Locate the apparatus in an area maintained between 18 and 27°C (65 and 80°F). Control of ambient temperature is particularly critical when one apparatus is stacked above another, because the heat generated from the lower unit can interfere with the operation—affect the ambient conditions of the units above.

5.3.2 Place the apparatus at least 300 mm from walls or other apparatus. Do not place the apparatus near a heat source such as an oven.

5.3.3 Ventilate the room in which the apparatus is located to remove heat and moisture.

6. Test Specimen

6.1 The size and shape of specimens to be exposed will be determined by the specifications of the particular test method used to evaluate the effects of the exposure on the specimens; the test method shall be determined by the parties concerned. Where practical, it is recommended that specimens be sized to fit specimen holders and racks supplied with the exposure apparatus. Unless supplied with a specific backing as an integral part of the test, specimens shall be mounted so that only the minimum specimen area required for support by the holder shall be covered. This unexposed surface must not be used as part of the test area.

6.2 For specimens of insulating materials, such as foams, quickly check the specimens during the condensation period to verify that visible condensation is occurring on the specimens. Perform this visual check once per week at least one hour after the start of condensation.

NOTE 4—If condensation is not occurring, the most likely cause involves inadequate room-air cooling: (1) the laboratory temperature is too high; (2) condensation temperature is set too low, or too close to room temperature; (3) thick specimens of insulating material may be preventing the room-air cooling necessary for condensation. For example, a 25-mm thick wood specimen may exhibit poor condensation with a condensation set point of 40°C and a lab temperature of 30°C; or (4) improper specimen mounting is allowing vapor to escape from the chamber.

6.3 To provide rigidity, attach flexible specimens to a backing panel made of aluminum, 0.635 mm (0.025 in.) thick. Suggested aluminum alloys are 5052, 6061, or 3003.

6.4 Seal any holes in specimens larger than 2 mm and any openings larger than 1 mm around irregularly shaped specimens to prevent loss of water vapor. Attach porous specimens to a solid backing such as aluminum that ~~can~~will act as a vapor barrier.

6.5 Unless otherwise specified, expose at least three replicate specimens of each test and control material.

6.6 Follow the procedures described in Practice **G147** for identification, conditioning, and handling of specimens of test, control, and reference materials prior to, during, and after exposure.

6.7 Do not mask the face of a specimen for the purpose of showing on one panel the effects of various exposure times. ~~Misleading results may~~It is possible that misleading results will be obtained by this method, since the masked portion of the specimen is still exposed to temperature and humidity cycles that in many cases will affect results.

6.8 Since it is possible the thickness of a specimen ~~may~~will markedly affect the results, thickness of test and control specimens shall be within $\pm 10\%$ of the nominal dimensions.

NOTE 5—This is especially important when mechanical properties are being investigated.

6.9 Retain a supply of unexposed file specimens of all materials evaluated.

6.9.1 When destructive tests are run, ensure that sufficient file specimens are retained ~~so that~~in order to determine the property of interest ~~can be determined~~ on unexposed file specimens each time exposed materials are evaluated.

6.10 ~~Specimens should~~It is recommended that specimens not be removed from the exposure apparatus for more than 24 h and then returned for additional tests, since this does not produce the same results on all materials as tests run without this type of interruption. When specimens are removed from the exposure apparatus for 24 h or more and then returned for additional exposure, report the elapsed time as noted in accordance with Section 9.

NOTE 6—Since the stability of the file specimen may also be time-dependent, users are cautioned that over prolonged exposure periods, or where small differences in the order of acceptable limits are anticipated, comparison of exposed specimens with the file specimen may not be valid. Instrumental measurements are recommended whenever possible.

7. Procedure

7.1 When the test and control specimens do not completely fill the specimen racks, fill all empty spaces with blank panels to maintain the test conditions within the chamber.

NOTE 7—Specimens in the extreme left and right side of the tester (position 1 and 13 in Fig. 2) experience a lower irradiance than other specimens. While these positions do meet the irradiance requirements in G151 when repositioning is used, it is recommended that these positions are excluded when test and control specimens do not completely fill the specimen racks.

7.2 Unless otherwise specified, program the device to one of the following test cycles. Operate the device continuously.

7.2.1 Cycle A:

Typical Irradiance at 340 nm is 0.89 W/(m² · nm)
 8 h UV with uninsulated black panel temperature controlled at 60°C
 4 h condensation with uninsulated black panel temperature controlled at 50°C
 (Used for most general applications)

7.2.2 Cycle B:




FIG. 2 Horizontal Specimen Holder Repositioning

ASTM D4329-21

<https://standards.iteh.ai/catalog/standards/sist/28d09c86-4a0d-4fc3-bcc6-349f534f1daa/astm-d4329-21>

Typical Irradiance at 340 nm is 0.77 W/(m² · nm)
 8 h UV with uninsulated black panel temperature controlled at 70°C
 4 h condensation with uninsulated black panel temperature controlled at 50°C
 (Typically used for automotive applications) Note: Cycle B is equivalent to the exposure test cycle specified in SAE J2020.

7.2.3 Cycle C:

Typical Irradiance at 340 nm is 0.83 W/(m² · nm)
 8 h UV with uninsulated black panel temperature controlled at 50°C
 4 h condensation with uninsulated black panel temperature controlled at 50°C
 (Typically used for some plastic building products)

NOTE 8—Unless otherwise specified, operate the apparatus to maintain the operational fluctuations specified in Table 1 for the parameters in Cycles A, B, and C. If the actual operating conditions do not agree with the machine settings after the equipment has stabilized, discontinue the test and correct the cause of the disagreement before continuing.

7.3 Practice G154 lists several other exposure cycles that are used for fluorescent UV exposures of nonmetallic materials. Obtain mutual agreement between all concerned parties for the specific exposure cycle used.

7.4 In order to minimize any effects from temperature or UV light variation, reposition the specimens as follows: specimens shall be repositioned during exposure. Fig. 2 shows a diagram of the specimen repositioning.