



Designation: **E1546 – 15** **E1546 – 21**

An American National Standard

Standard Guide for Development of Fire-Hazard-Assessment Standards¹

This standard is issued under the fixed designation E1546; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This guide covers the development of fire-hazard-assessment standards.

1.2 This guide is directed toward development of standards that will provide procedures for assessing fire hazards harmful to people, animals, or property.

1.3 Fire-hazard assessment and fire-risk assessment are both procedures for assessing the potential for harm caused by something—the subject of the assessment—when it is involved in fire, where the involvement in fire is assessed relative to a number of defined fire scenarios.

1.4 Both fire-hazard assessment and fire-risk assessment provide information that can be used to address a larger group of fire scenarios. Fire-hazard assessment provides information on the maximum potential for harm that can be caused by the fire scenarios that are analyzed or by any less severe fire scenarios. Fire-risk assessment uses information on the relative likelihood of the fire scenarios that are analyzed and the additional fire scenarios that each analyzed scenario represents. In these two ways, fire-hazard assessment and fire-risk assessment allow the user to support certain statements about the potential for harm caused by something when it is involved in fire, generally.

1.5 Fire-hazard assessment is appropriate when the goal is to characterize maximum potential for harm under worst-case conditions. Fire-risk assessment is appropriate when the goal is to characterize overall risk (average severity) or to characterize the likelihood of worst-case outcomes. It is important that the user select the appropriate type of assessment procedure for the statements the user wants to support.

1.6 Fire-hazard assessment is addressed in this guide and fire-risk assessment is addressed in Guide **E1776**.

1.7 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate ~~safety~~ safety, health, and health ~~environmental~~ practices and determine the applicability of regulatory limitations prior to use.*

1.8 This fire standard cannot be used to provide quantitative measures.

1.9 This standard is used to predict or provide a quantitative measure of the fire hazard from a specified set of fire conditions involving specific materials, products, or assemblies. This assessment does not necessarily predict the hazard of actual fires which involve conditions other than those assumed in the analysis.

¹ This guide is under the jurisdiction of ASTM Committee **E05** on Fire Standards and is the direct responsibility of Subcommittee **E05.33** on Fire Safety Engineering. Current edition approved ~~June 15, 2015~~ July 1, 2021. Published ~~August 2015~~ August 2021. Originally approved in 1993. Last previous edition approved in ~~2009~~ 2015 as E1546-09a-15. DOI: ~~10.1520/E1546-15~~ 10.1520/E1546-21.

1.10 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 ASTM Standards:²

[D2859 Test Method for Ignition Characteristics of Finished Textile Floor Covering Materials](#)

[D5425 Guide for Development of Fire Hazard Assessment Standards of Electrotechnical Products](#)

[E176 Terminology of Fire Standards](#)

[E603 Guide for Room Fire Experiments](#)

[E648 Test Method for Critical Radiant Flux of Floor-Covering Systems Using a Radiant Heat Energy Source](#)

[E1354 Test Method for Heat and Visible Smoke Release Rates for Materials and Products Using an Oxygen Consumption Calorimeter](#)

[E1678 Test Method for Measuring Smoke Toxicity for Use in Fire Hazard Analysis](#)

[E1776 Guide for Development of Fire-Risk-Assessment Standards](#)

[E2061 Guide for Fire Hazard Assessment of Rail Transportation Vehicles](#)

[E2280 Guide for Fire Hazard Assessment of the Effect of Upholstered Seating Furniture Within Patient Rooms of Health Care Facilities](#)

2.2 ISO Standards:³

[ISO 13943 Fire Safety – Vocabulary](#)

2.3 NFPA Standards:⁴

[NFPA 101 Code for Safety to Life from Fire in Buildings and Structures](#)

[NFPA 901 Uniform Coding for Fire Protection](#)

2.4 SFPE Standards:⁵

[SFPE Engineering Guide to Performance-Based Fire Protection](#)

3. Terminology

3.1 *Definitions of Terms*—See Terminology [E176](#) and ISO 13943. In case of conflict the definitions in Terminology [E176](#) shall prevail.

3.2 Definitions:

3.2.1 *environment, n*—*as related to fire*, the conditions and surroundings that may influence the behavior of a material, product, or assembly when it is exposed to ignition sources of fire.

3.2.2 *fire-characteristic profile, n*—an array of fire-test-response characteristics, all measured using tests relevant to the same fire scenario, for a material, product, or assembly, to address, collectively, the corresponding fire hazard. See also *fire hazard*, *fire risk* and *fire-test response characteristic*.

3.2.2.1 Discussion—

An array of fire-test-response characteristics in a set of data relevant to the assessment of fire hazard in a particular fire scenario. In other words, all the fire tests used would have a demonstrated validity for the fire scenario in question, for example, by having comparable fire intensities. The fire-characteristic profile is intended as a collective guide to the potential fire hazard from a material, product, or assembly involved in a fire that could be represented by the laboratory test conditions.

3.2.3 *fire hazard, n*—the potential for harm associated with fire.

3.2.3.1 Discussion—

A fire may pose one or more types of hazard to people, animals, or property. These hazards are associated with the environment and with a number of fire-test-response characteristics of materials, products, or assemblies including, but not limited to, ease of ignition, flame spread, rate of heat release, smoke generation and obscuration, toxicity of combustion products, and ease of extinguishment.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, <http://www.ansi.org>.

⁴ Available from National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, MA 02169-7471, <http://www.nfpa.org>.

⁵ Available from Society of Fire Protection Engineers (SFPE), 7315 Wisconsin Ave., Suite 620E, Bethesda, MD 20814, <http://www.sfpe.org>.

3.2.4 *fire risk, n*—an estimation of expected fire loss that combines the potential for harm in various scenarios that can occur with the probabilities of occurrence of those scenarios.

3.2.4.1 *Discussion*—

Risk may be defined as the probability of having a certain type of fire, where the type of fire may be defined in whole or part by the degree of potential harm associated with it, or as potential for harm weighted by associated probabilities. However, it is defined, no risk scale implies a single value of acceptable risk. Different individuals presented with the same risk situation may have different opinions on its acceptability.

3.2.5 *fire scenario, n*—a detailed description of conditions, including environmental, of one or more of the stages from before ignition to the completion of combustion in an actual fire, or in a full scale simulation.

3.2.5.1 *Discussion*—

The conditions describing a fire scenario, or a group of fire scenarios, are those required for the testing, analysis, or assessment that is of interest. Typically, they are those conditions that can create significant variation in the results. The degree of detail necessary will depend upon the intended use of the fire scenario. Environmental conditions may be included in a scenario definition but are not required in all cases. Fire scenarios often define conditions in the early stages of a fire while allowing analysis to calculate conditions in later stages.

3.2.6 *fire test response characteristic, n*—a response characteristic of a material, product, or assembly to a prescribed source of heat or flame, under controlled fire conditions; such response characteristics may include, but are not limited to, ease of ignition, flame spread, heat release, mass loss, smoke generation, fire endurance, and toxic potency of smoke.

3.2.6.1 *Discussion*—

A fire-test-response characteristic can be influenced by variable characteristics of the heat source, such as its intensity, or of the burning environment, such as ventilation, geometry of item or enclosure, humidity, or oxygen concentration. It is not an intrinsic property such as specific heat, thermal conductivity, or heat of combustion, where the value is independent of test variables. A fire-test-response characteristic may be described in one of several terms. Smoke generation, for example, may be described as smoke opacity, change of opacity with time, or smoke weight. No quantitative correlation need exist between values of a fire-test-response characteristic for different materials, product, or assemblies, as measured by different methods or tested under different sets of conditions for a given method.

3.3 *Definitions of Terms Specific to This Standard:*

3.3.1 *fire characteristic index, n*—a single quantitative measure that combines two or more fire-test-response characteristics for a material, product, or assembly, all developed under test conditions compatible with a common fire scenario, addressing collectively, the corresponding threat. See also *fire-characteristics profile, fire hazard, fire risk, fire-test-response characteristic*.

3.3.2 *fire hazard assessment, n*—a process for measuring or calculating the potential for harm created by the presence of a material, product, or assembly in the relevant fire scenarios.

3.3.3 *fire risk assessment, n*—a means for computing the probability of fire loss within a specified period in a defined occupancy or situation.

4. Significance and Use

4.1 This guide is intended for use by those undertaking the development of fire-hazard-assessment standards. Such standards are expected to be useful to manufacturers, architects, specification writers, and authorities having jurisdiction.

4.2 As a guide, this document provides information on an approach to the development of a fire hazard standard; fixed procedures are not established. Limitations of data, available tests and models, and scientific knowledge may constitute significant constraints on the fire-hazard-assessment procedure.

4.3 While the focus of this guide is on developing fire-hazard-assessment standards for products, the general concepts presented also may apply to processes, activities, occupancies, and buildings.

4.4 When developing fire-risk-assessment standards, use Guide E1776. The present guide also contains some of the guidance to develop such a fire-risk assessment standard.

5. Key Elements

5.1 This guide uses as its key elements the following:

5.1.1 The purpose of a fire-hazard-assessment standard or a fire-risk-assessment standard is to provide a standardized procedure for assembling a compilation of information relevant to the fire hazard or fire risk of a product under specific conditions of use.

5.1.2 The information assembled by using a fire-hazard-assessment standard should be relevant to the purpose of assessing the fire hazard of the specific designated product within the range of designated fire scenarios. The information assembled by using a fire-risk-assessment standard (see Guide E1776) should be relevant to the purpose of assessing the fire risk of the specific designated product within the range of all relevant scenarios.

5.1.3 The information assembled should be explicit and quantitative and should provide a sufficiently thorough examination of the product's fire hazard under the conditions defined by the scope of the specific standard, so as to permit valid choices and decisions with respect to the fire hazard of that product.

5.1.4 A persuasive scientific case must be made in the documentation of a specific fire-hazard-assessment standard that the procedures, data, and hazard measures specified by the standard will address questions about a product's fire hazard with sufficient accuracy and validity that a more thorough assessment procedure would not materially alter any decisions that might be made based on the standard. If such a case cannot be made for all products to be addressed, then the hazard assessment should specify those conditions under which a more thorough fire-hazard-assessment procedure should be used. In some cases, the more thorough assessment procedure identified by a fire-hazard-assessment standard can be considered to be a fire-risk-assessment procedure, but this must be confirmed via Guide E1776.

5.1.5 The absence of a data source, test method, or calculation procedure of sufficient scope and proven validity to support the needs of a particular fire-hazard-assessment procedure may not be a sufficient reason to use a data source, test method, or calculation procedure of lesser scope or unproven validity. It is recognized that fire-hazard assessments of such products may need to be performed in any event, using relevant non-standardized procedures. When such non-standardized or unvalidated procedures are used, the details shall be included to such an extent that the procedures become standardized only for use within the specified fire-hazard-assessment or fire-risk-assessment procedure through final publication of the fire-hazard-assessment or fire-risk-assessment standard document.

5.1.5.1 The concepts discussed in 5.1.5 apply both to fire-hazard assessments, conducted in accordance with this guide, and to fire-risk assessments, conducted in accordance with Guide E1776.

5.1.6 Among the significant outcomes of a fire-hazard assessment would be the revelation that a product produces either an increase, no increase, or a decrease in fire hazard on some or all hazard measures and for all or some of the scenarios specified by the standard, relative to another product or relative to baseline hazard values for those measures and scenarios. These baseline values may or may not be derived from fire-hazard assessments of products already in use. However, when the product is proposed for an existing use, it should be compared to an existing product having the same use. For example, if a product's fire hazard is uniformly rated greater than the reference values on all comparisons specified by the standard, then the overall fire-hazard assessment of the product will be greater than the fire hazard of the baseline (or product in use).

5.1.7 If the assessment shows that the product is not uniformly rated higher than, equivalent to, or less than the other product(s) or the baseline for all hazard measures and reflecting all scenarios specified by the standard, then the implications of the fire-risk assessment for product evaluation (in accordance with Guide E1776) will not be clear without the development of appropriate decision rules. Such rules would combine the fire hazard or fire risk measures, giving appropriate weighting to each fire-hazard or fire-risk measure, and, if necessary, would combine measures for different scenarios, giving appropriate weighting to each scenario. Decision rules for combining measures need not be simple weighted sums of the component measures. Decision rules for combining scenarios normally use weights reflecting the relative likelihood of different scenarios. Fire-risk-assessment standards normally include procedures for combining scenarios, but fire-hazard-assessment standards normally do not. Note that the scenario may affect not only the value of individual fire hazard or fire risk measures but also the decision rules for combining fire hazard or fire risk measures (in the latter case by using Guide E1776).

6. Relationship Between Fire Hazard and Fire Risk

6.1 It is important to differentiate between *fire hazard* and *fire risk* (see 3.1 for the definitions). The relationship is as follows.

6.1.1 A fire-hazard measure addresses the expected performance of a product for a particular fire scenario, including designated conditions of use. A fire-risk measure incorporates fire-hazard measures but also incorporates probability of occurrence of each fire scenario and addresses all relevant fire scenarios.

6.1.2 Because the number of distinguishable relevant fire scenarios in any fire-risk assessment is usually unmanageably large, it will normally be necessary for fire scenarios to be grouped into classes for purposes of analysis. This may make the fire-risk assessment less product-specific or less specific to conditions of use than would be true of a fire-hazard assessment.

6.1.3 Some existing fire-risk assessment models and calculation procedures define fire risk as the sum over all fire scenario classes of the probability-weighted fire hazard for that fire scenario class. In such an approach:

6.1.3.1 The fire scenarios in each fire scenario class shall be very similar with respect to those characteristics that determine fire hazard.

6.1.3.2 Each fire scenario class will have a probability (P_i) that represents the likelihood of a fire corresponding to a scenario in that class.

6.1.3.3 For each fire scenario class, a specific fire scenario shall be chosen as representative of the class, so that the fire hazard for that specific fire scenario can be used as a valid estimate of H_i , the fire hazard of the fire scenario class. This is defined as the probability-weighted mean fire hazard for all the specific fire scenarios in the fire scenario class, a quantity that cannot be directly calculated.

6.1.3.4 If this structure is adopted, then the relationship between the fire risk measure and fire hazard measure is given by the following formula:

$$Risk = \sum_i (P_i \times H_i) \quad (1)$$

where:

H_i = hazard for representative scenario of scenario class $i, i = 1, \dots, n$, and

P_i = probability of scenario class $i, i = 1, \dots, n$.

6.1.4 For a fire-risk-assessment standard, this formula shows that a fire-risk-assessment procedure may be constructed from a fire-hazard-assessment procedure, a valid structure of fire scenario class and representative fire scenarios by class, and valid sources for fire scenario class probability data.

6.1.5 The principal differences between a fire-hazard assessment and a fire-risk assessment are (a) a fire-risk assessment incorporates relative scenario likelihood into the information provided in the assessment, whereas a fire-hazard assessment normally does not do so; and (b) the scenarios in a fire-risk assessment need to be chosen so that they collectively represent all relevant fire scenarios, whereas the scenarios in a fire-hazard assessment need only be chosen so that a more thorough assessment would not materially alter any decisions made based on the assessment and the standard.

6.1.6 A fire-risk assessment may be most appropriate when it is not possible to demonstrate that use of a fire-hazard assessment will not materially alter any decisions made based on the assessment and the standard, relative to decisions that would have been made using a fire-risk assessment. A fire-hazard assessment may be acceptable and more efficient when the purpose is only to demonstrate that consequences are acceptably small for each scenario analyzed.

7. Fire-Hazard-Assessment Standards

7.1 Fire-hazard-assessment standards shall conform in style and content to the *ASTM Form and Style Manual*.⁶

7.2 Fire-hazard-assessment standards shall include sections labeled: Scope, Significance and Use, Terminology, and Detailed Procedure; the sections should be numbered and arranged in that order.

7.2.1 *Scope*—the Scope statement should clearly state:

⁶ Available from ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428–2959. <http://www.astm.org>.

7.2.1.1 The product or class of products of interest,

7.2.1.2 The fire scenario(s) included in the standard, and, for a fire-risk assessment, in accordance with Guide E1776, the scenario class represented by each fire scenario,

7.2.1.3 The assumptions used in the standard,

7.2.1.4 The structure of the fire-hazard-assessment procedure, including test methods, models, other calculation procedures, data sources, hazard measures, and evaluation criteria or procedures used, and

7.2.1.5 Any limitations on the application of the standard, such as the manner, form, or orientation in which the product is incorporated within an assembly, geometric restrictions essential to use of the product, the quantity of product in use, the end use of the product, and the type of occupancy to which the standard is applicable.

7.2.2 *Significance and Use:*

7.2.2.1 The major uses and any limitations of the standard fire-hazard-assessment procedure should be clearly described. For fire-risk-assessment procedures, in accordance with Guide E1776, this should include an explicit description of the extent to which the included fire scenario classes and representative fire scenarios, in 7.2.1.2, constitute all the relevant fire scenario classes and representative fire scenarios for the product (class) and occupancy type addressed by the standard.

7.2.2.2 The significance of the assessment to users should be clearly stated.

7.2.3 *Terminology*—Terms unique to the fire-hazard-assessment standard should be clearly defined. Standard terms as defined in Terminology E176 shall be used. Terms not included in Terminology E176 but useful for this guide are included in 3.3.

7.2.4 *Detailed Procedure:*

7.2.4.1 This section should include detailed descriptions of the fire-hazard-assessment procedure and its component parts, including: test methods, calculation procedures, scenario description, data sources, and evaluation criteria or procedures.

7.2.4.2 If the calculation procedures include models, the versions used should be carefully identified and referenced and major assumptions and limitations of the models noted. Validation information, or lack thereof, should also be noted.

7.2.4.3 If calculation procedures are used, sample calculations should be included.

7.2.4.4 Standard test methods should be carefully identified and referenced. If a test method not yet adopted as a national standard is used, its descriptions should provide all the information that would be included if it were being submitted separately for consideration as a standard test method. Data on reproducibility and validation of non-standardized methods should be included. If a standard test method has been modified for the standard, all details of the modification and evidence of the effects of the modification on results should be included. These guidelines also apply to any large-scale test protocols.

7.2.4.5 If sources for data on fire experience or expert judgment are cited, the procedures for assembling the data and the accuracy, precision, and reliability of the data should be documented. The data should be accessible to personnel conducting or reviewing the fire-hazard assessment.

8. Fire-Hazard-Assessment Procedures

8.1 *Overview of Elements of Fire Hazard:*

8.1.1 Possible sources of harm to people or animals, directly or indirectly, include toxic (narcotic or irritant) substances produced by a fire, thermal insults (heat stress and burns) due to convected and radiant flux, obscuration of vision by smoke (which may interfere with the ability to escape), oxygen depletion, and structural damage leading to traumatic injury.

8.1.2 Possible sources of harm to property include direct damage to contents, furnishings, structure, or other installed or moveable combustibles, from heat, corrosive smoke, soot or firefighting, and indirect damage as a consequence of business interruption or other adverse effects on the ability of the property to be used for its designed purposes.

8.1.3 Harm to the environment includes direct harm to animals for plant life located outside the property of origin, and indirect harm to people, animals, plant life, or property as a result of contamination of air, water, adjacent land.

8.1.4 The fire hazard or risk of a product depends on its properties, how it is used, and the context in which it is used, including the number and characteristics of people potentially exposed, and the value and fragility of property exposed to a fire involving the product. Therefore, a fire-hazard-assessment or fire-risk-assessment procedure for a particular product should describe the product, how it is used, and its context of use.

8.2 *Development of a Fire-Hazard-Assessment Standard*—The seven basic steps to follow in developing a fire-hazard-assessment standard are the following:

8.2.1 Define the scope (for example, the product(s) or product class of interest, where and how the products are used),

8.2.2 Identify the measure of harm to be assessed (for example, deaths, injuries, business loss, property loss),

8.2.3 Identify and describe the fire scenarios to be analyzed (for example, geometry, ventilation, and other special characteristics of environment; initial heat source; initial fuel source if not the product; locations and burning properties of secondary fuel sources; occupant characteristics), and for fire-risk assessment (in accordance with Guide E1776), including the scenario classes represented by each scenario selected for analysis,

8.2.4 Identify the test methods or calculation procedures needed to produce the measures of fire hazard (note that, when assessing fire risk in accordance with Guide E1776, probability assessments will be needed),

8.2.5 Use the scenarios to define key parameters of the test methods or calculation procedures,

8.2.6 Identify the types and sources of data required to support the selected test methods and calculation procedures, identified in 8.2.2 – 8.2.5 (note also that, when assessing fire risk, in accordance with Guide E1776, it will be necessary to identify the types and sources of data required for calculation of needed probabilities), and

8.2.7 Identify the criteria or procedures for evaluating the fire hazard measures relative to the degree of harm.

8.2.8 Identify the necessary safety factors, sensitivity analyses, or other elements required to permit valid interpretation of the fire-hazard in light of the uncertainties and biases of data or calculation methods, which should have been previously documented in 8.2.2 – 8.2.7

8.2.9 Fig. 1 graphically displays the steps in 8.2.1 – 8.2.8, where the left side shows steps for fire-hazard assessment and the right side shows steps for fire-risk assessment, in accordance with Guide E1776.

8.3 *Define the Scope and Context*—The first step involves defining the products or class of products to which the fire-hazard-assessment standard is to apply (that is, scope) and defining the general and specific environments in which the products will be used (that is, context), including implications of those environments for test conditions or model parameters in the fire-hazard-assessment calculation procedure. This may be accomplished by answering the following questions:

8.3.1 *Product or Class*—What is the product or product class to be covered? Is the definition clear enough that one can always determine whether a product is covered by the standard? Is the definition broad enough that all products capable of substituting for covered products are also included? Is the definition sufficiently specific that it does not invite invalid comparisons, such as comparisons of products that have very dissimilar uses and do not satisfy all the assumptions of the standard?

8.3.2 *Product Involvement in Fire*—When and how does the product tend to become involved in fire? Is there a particular role in fire that tends to be the only point of concern for this product class in a specific use (for example, initial heat source, initial fuel source, principal or largest fuel source, high severity per unit of product, major avenue of fire spread, major part of value at risk)? Based on this information, is there a subset of the following fire-test-response and other characteristics that can validly be isolated as the only ones providing significant variation in fire hazard for this product class? Consider the following:

8.3.2.1 Ignitability,

8.3.2.2 Flame-spread rate,




FIG. 1 Flow Chart Showing Steps in Fire-Hazard or Fire-Risk Assessment

8.3.2.3 Heat release—peak rate, rate of rise in rate (fire growth rate), total heat released,

8.3.2.4 Mass loss or smoke-generation rate,

8.3.2.5 Opacity of smoke produced (also described as smoke obscuration),

8.3.2.6 Corrosivity of smoke produced,

8.3.2.7 Profile of toxic (irritant and asphyxiant) species produced—rate, total, toxic potency,

8.3.2.8 Thermal-decomposition rates,

8.3.2.9 Fire ~~resistance~~—~~structural~~ resistance – structural integrity, thermal conductivity, mechanical response (for example, melting, collapsing),

8.3.2.10 Ease of extinguishment, and

8.3.2.11 Quantity of product in use relative to size and type of occupancy.

8.3.3 *Environment:*

8.3.3.1 What are the environments in which the product will be used? Environment characteristics of interest typically include those that define the manner of use of the product and those that define nearby heat sources and other fuel items, nearby occupants and their characteristics or behaviors, and the dimensions and characteristics of the spaces in which fire can develop. In practical terms, the general-environment characteristics of interest will generally be those that can be translated into fire test specifications or variables in calculations. Typically, most or all of these environment characteristics can be inferred from the (property) use groups or occupancy classifications where the product is to be used. Use groups and occupancy classifications suitable for this purpose can be found in many codes and in coding rules for fire incident databases.

8.3.3.2 What does this information and other information on the product's environment indicate about the number of persons or quantity and value of property that potentially could be exposed to a fire involving the product, the special capabilities or limitations of the occupants, and the special characteristics or vulnerabilities of the property? What does this information indicate about the relative importance to overall fire hazard of the particular fire-test response and other characteristics selected in 8.3.2?

(1) For example, for a product used in a small property, such as, dwelling or store, the most important measures of its involvement in a fire might include its ability to start a fire (ignitability) and the speed with which it produces hazardous conditions (heat release, smoke-generation rate, profile of toxic species produced). For a product used in a large property, like a high-rise hotel or office building, other measures of involvement in fire might also be of interest, such as its ability to produce hazardous conditions over a large area (flame-spread rate, quantity of product in use, total heat released, total toxic product produced).

(2) As another example, for a product used in a densely populated property (for example, multifamily residential, public assembly) the measures of fire involvement of greatest concern might emphasize the product's ability to produce conditions hazardous to occupants (heat release, toxic species) while for a product used in an industrial property, the measures of greatest interest might emphasize the product's ability to produce fire effects that damage property that is either expensive to replace or repair or critical to operation of the facility (endurance under fire conditions, smoke corrosivity).

8.3.3.3 *Environment*—What is known about the immediate environment of the product as it affects the likely conditions of the product's involvement in fire? Is the product always located in an exposed or enclosed space? What types of fire barriers separate the product from other spaces (for example, an ordinary wall, a fire-rated wall, an ordinary door that may be open, or a fire-rated door with automatic closing device)? Is the product used in areas where building systems or other features such as, air-handling systems or open stairways, could contribute to transport of the product's fire effects to remote parts of the property? Is the product typically used as a single unit or as a component of an assembly? Are there other products normally associated with the product in question (for example, a carpet and its pad) or installation procedures that may affect the fire-hazard development of the product? Is more, or less, humidity likely to affect performance of the product?

8.3.3.4 What is the range of conditions of the product in use? Are there patterns of age, use, or abuse that will affect its fire performance? Based on answers to questions like these, how should the product specimen and its environment be prepared for testing?

8.4 *Identify Measures Used to Calculate Fire Hazard*—There are several measures that may be used to calculate fire hazard (or fire risk, in accordance with Guide E1776). Each type of measure has advantages and disadvantages.

8.4.1 *Measures of End Outcomes*, Such measures, including deaths, injuries, or property damage, are the most directly related to

the ultimate concerns of fire impact on people and property. This direct relationship is an advantage. However, these measures require the use of scenarios that specify not only the product and its immediate environment but also the entire building or occupancy and its occupants. As the analysis goes beyond the product's immediate environment, it may become more difficult to isolate differences between products, but this effect is real.

8.4.1.1 An intermediate approach measures the arrival of a particular fire condition, such as, reduced visibility, flashover, or insufficient oxygen, that may affect occupants and property. This approach lacks the rigor required to perform a direct death or damage analysis. However, it does set meaningful general criteria by which to judge products. When this intermediate approach is used, the standard should clearly state that the hazard assessment determines the arrival of particular fire conditions that do not necessarily relate to deaths and damage.

8.4.2 *Measures of Physical Fire Effects*—Such measures, including extent of flame or smoke damage or whether flashover occurs, are less directly and reliably related to the ultimate concerns of fire impact on people, property, or the environment. However, most of these measures can be calculated with less elaborate estimation procedures, including procedures that do not characterize occupants or spaces beyond the first room or area involved in a fire. This eliminates some sources of uncertainty and makes it easier to isolate effects of product differences, although the ultimate significance, to the end outcomes that are ultimately of concern, of the risk differences so identified may be less clear.

8.4.3 *Measures of Fire-Test-Response Characteristics*—Such measures may be used individually or as elements in a fire-characteristic profile. These measures come directly from test methods, which may reduce their uncertainty, and tend to be based on tests involving only the product, which may simplify the process of isolating differences between products. These are advantages of such profiles. However, the relative importance, interaction, and relevance of the fire-test-response characteristics, individually and collectively, to the hazard posed by the product in real fires must be established by comparison to more thorough assessments. The need for such comparisons exists for all fire-hazard measures, but is greatest for measures of fire-test-response characteristics, because they are farthest removed from end-outcome measures; this is a disadvantage of this approach.

8.4.4 A *Fire-Characteristic Index* is a measure that is calculated from component fire-test-response characteristics or intrinsic fire properties. Such an index may make it easier to distinguish product differences, and because it integrates several fire-test-response characteristics, it may permit identification of simple evaluation criteria. These are advantages to this approach. Disadvantages include the need to demonstrate that the index validly integrates the component characteristics, which are likely to include the need for comparison of the index with results from large-scale tests and analyses of real fires.

8.4.5 *Calculated Measures of End Outcomes* are developed using equations to calculate measures of the type described in 8.4.1 and 8.4.1.1 from input variables consisting of measures of the type described in 8.4.3. A fire model is an example of a set of equations to perform such a calculation.

8.4.6 *Measures of Fire Risk (to be assessed by means of Guide E1776):*

8.4.6.1 *Mean of Fire Hazard*—The formula given in 6.1.3.4 defines fire risk as the mean value of fire hazard and is the fire-risk measure used in most circumstances.

8.4.6.2 *Probability of Hazard*—An alternative measure defines fire risk as the probability that a specified level of fire hazard will be met or exceeded. This measure can be used if a focus on high-severity outcomes is considered appropriate or in circumstances where the measure of fire effect is not scalar (for example, flashover occurs), which prevents the use of a mean fire hazard definition of fire risk.

8.4.6.3 *Absolute versus Relative Risk*—For any measure of fire risk, it is possible to substitute a dimensionless measure that provides only the proportional change in fire risk from some baseline. This choice removes some parts of the estimation procedures, such as the need for estimates of the absolute probability that fire will occur or for controversial assumptions such as dollar equivalent for a lost human life. If the threshold for acceptable risk is defined by the risk associated with current products for the existing use or with products compliant with current codes, then relative risk measures are likely to be sufficient.

8.5 *Identify and Describe Scenarios:*

8.5.1 A scenario is a detailed description of conditions, including environmental, of one or more of the stages from before ignition to the completion of combustion in an actual fire. A fire scenario includes a set of details required to select and specify test methods, fire model, or calculation procedure to produce one or more fire-hazard measures. The fire-hazard-assessment standard includes

procedures to identify and describe scenarios, including procedures for selecting the scenarios to be used in the calculation. The standard can also identify specific scenarios to include or represent in the calculation. Typical characteristics used to define scenarios include the following:

8.5.1.1 The location of the initial fuel for the fire, its fire-test-response characteristics, and its intrinsic fire properties;

8.5.1.2 The location of the ignition heat source and its heat-release characteristics;

8.5.1.3 Proximities and characteristics of other items near the first item ignited;

8.5.1.4 Layout of the building or other environment, including the number of rooms and floors, room and other area dimensions, and openings and vents between rooms and areas and between rooms and the outside;

8.5.1.5 Thermal properties of all room linings, fuel loads of rooms and spaces other than the first room or area involved, properties and quantities of contents and finishes providing avenues of flame spread, and properties of barriers (doors, walls) and conditions required to breach them;

8.5.1.6 Number of persons, quantities and values of property, and the locations and characteristics of people and property as they affect vulnerability and reaction to fire.

8.5.2 For fire-risk assessments, in accordance with Guide [E1776](#), each scenario selected for analysis is linked to a scenario class which it represents. Scenario classes are groups of scenarios. The rules for grouping are normally such that some characteristics are specified as common to all scenarios in the class, some characteristics are allowed to vary but only within specified ranges, and some characteristics are allowed to vary without limit (for example, if scenarios are defined by the physical details of ignition, fires involving Class III B combustible liquids constitute a scenario class in which the type of material is precisely specified as a liquid, the flashpoint is specified to within a range, and other characteristics, such as the heat source, are allowed to vary over all possibilities). Probabilities can be estimated for scenario classes but are not meaningful when calculated for fully specified scenarios. Because fire hazard is calculated for a scenario while probability is calculated for the linked scenario class, it is important that the scenario be a representative scenario for its scenario class. A representative scenario is an average scenario which may not be the same as a typical scenario. Evidence should be provided for each scenario class to support the implicit claim that all scenarios included within that scenario class can be accurately represented by a single design fire scenario. Evidence also should be provided that the scenarios and scenario classes addressed by the fire-risk assessment method collectively represent all scenarios in which the product can be involved in fire with significant probability for significant consequence.

8.5.3 Because the focus of the assessment is a product, the most important scenario dimensions typically will be those that either define the fire conditions that cause the product to become involved in fire or indicate the point in the fire when the product's contribution will have the greatest consequence for hazard. To determine this, it is necessary to answer questions like these:

8.5.3.1 *Is the product a likely first item ignited?* This may be determined through analysis of historical fire experience if the product has been in use in the same manner for some time. If the answer is yes, the same analysis can indicate the relative importance of various types of initial heat sources such as:

- (1) Glowing hot object (lighted tobacco product, fireplace ember or spark, overloaded electrical wire).
- (2) Radiant-heat source (appliance designed to, or known to, produce heat).
- (3) Open-flame source (match or lighter, torch, gas fueled burner or pilot light, fireplace fire, trash fire).
- (4) Accelerant-fed fire (arson fire set on the product with use of accelerants).

8.5.3.2 *Is the product a potential major fuel source even if not the first item ignited?* This may be estimated by the relative quantity and total heat release of the product available for fire involvement in rooms and areas where fire typically begins. If the answer is yes, then one might develop parameters for the heat source exposure to the product.

8.5.3.3 *Is the product a potential avenue of flame spread?* This may be estimated from a review of large historical fires. If the answer is yes, then one might specify testing of the product using a heat source considered to be representative of fire conditions for a well-developed fire that has not yet filled a large room or a floor.

8.5.3.4 *How close is the exposed population (or the most critical property) to the fire, and what does this imply about the most critical stage of the product's fire involvement?* Consider the following possible spatial relationships:

- (1) Population is in the same room as fire.
- (2) Population is in other rooms on the same floor or on an adjacent floor connected by an open stairway or air-handling system.

(3) Population is in building but remote from fire (several floors away or separated from fire by rated fire barriers, enclosed stairway, or considerable distance).

(4) Population is exposed by fighting the fire, whether as fire department, facility fire brigade, employees, etc.

(5) Population is exposed after the fire (for example, during overhaul or cleanup).

8.5.3.5 *What are the mental, physical, and age characteristics of the population?*

(1) Is escape hindered due to age, physical infirmity, or mental capacity?

(2) How much escape time is likely to be needed?

8.5.3.6 *Are special installation or structural requirements necessary to mitigate the hazard?*

(1) If the product is being compared to other products in the same class, is the data used relevant under the same installation requirements?

(2) Is it clear in reporting on the assessment what mitigating or protective features are necessary for the hazard measure to be viable?

8.5.4 As described in the *SFPE Engineering Guide to Performance-Based Fire Protection*, the identification of fire scenarios and the characterization and selection of design fire scenarios can be initiated through an examination of data on fires that have occurred, using failure analysis and appropriate fire incident databases, and an examination of what could occur, using Failure Modes and Effects Analysis (FMEA), What-if analysis, and hazards and operability studies (HAZOPS), among other common tools.

8.5.5 If one of the areas listed in 8.5.3 can be identified as the greatest concern, that may mean that one product fire performance characteristic is of greatest importance, such as the product's ability to generate a significant hazard quickly, its total hazard capacity (for example, quantity in use), or the persistence of its hazard during and after suppression operations. Such determinations can then be used to define test methods or calculation procedures that will measure the product's contribution to fire hazard at those stages of the fire.

8.5.6 In particular, if the greatest concern with a product is its ability to initiate fire or to produce by itself a rapid onset of hazardous conditions, then it is most likely that test methods and calculation procedures need not explicitly address the product beyond its immediate environment or the specifics of the population and property at risk. Thus, the analysis can be cut off at the immediate environment in this case, with little loss in validity and with reduced computation, if appropriate checks are incorporated. Conversely, if the greatest concerns with the product are with its contribution to large fires exposing remote populations or concentrations of value relatively late in the fire, then it may be impossible to define a valid fire-hazard-assessment procedure without explicitly addressing all the scenario dimensions that define the building.

8.5.7 In each case, the procedure is to use what is known of the scope and context to identify appropriate parameters for selection and specification of a test method, model, or calculation procedure. No algorithms or heuristics exist to fully specify this process. However, it is common practice in a fire-hazard assessment to develop one or more scenarios of the most-common-serious-fire type (for example, leading causes of fatal fires involving the product class) and one or more scenarios of the most-severe-credible-fire type (for example, characteristics of the deadliest fire involving the product in the past decade). Use of this most-likely versus most-severe approach has advantages since this permits substantial use of historical fire experience, provides a readily understandable context for experts to provide estimates of key scenarios, and is likely to produce very diverse scenarios, which provide some assurance that the product's fire potential will be fully exercised and that no surprises are likely to come up.

8.6 *Identify Test Methods or Calculation Procedures for Fire-Hazard Assessment:*

8.6.1 It is likely that in completing the preceding steps in 8.2 – 8.5, the developers of a fire-hazard-assessment standard will have been led to identify appropriate test methods and calculation procedures capable of producing the designated hazard measures. The steps in Section 7 should help in translating occupancy type, product, and product use characteristics into parameter specifications for those test methods and calculation procedures.

8.6.2 The following steps should help in translating specifications of scenario into parameter specifications for those test methods and calculation procedures.

8.6.2.1 A test method or calculation procedure will require a number of specifications or input values. For example, a test for the rate of heat release of a burning product will require specification of the circumstances of ignition (for example, piloted ignition), the level of incident heat flux, and any requirements for control of oxygen or humidity levels in the combustion atmosphere. A