

INTERNATIONAL STANDARD



Rotating electrical machines –
Part 12: Starting performance of single-speed three-phase cage induction
motors

iteh Standards
(<https://standards.iteh.ai>)

Document Preview

[IEC 60034-12:2024](#)

<https://standards.iteh.ai/catalog/standards/iec/0c6f84ee-9f6c-42eb-bade-653b3aeb03a0/iec-60034-12-2024>





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2024 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

International Standards
Document Preview

[IEC 60034-12:2024](https://standards.iteh.ai/catalog/standards/iec/0c6f84ee-9f6c-42eb-badc-653b3aeb03a0/iec-60034-12-2024)

<https://standards.iteh.ai/catalog/standards/iec/0c6f84ee-9f6c-42eb-badc-653b3aeb03a0/iec-60034-12-2024>



IEC 60034-12

Edition 4.0 2024-05
REDLINE VERSION

INTERNATIONAL STANDARD



Rotating electrical machines –
Part 12: Starting performance of single-speed three-phase cage induction
motors

Document Preview

[IEC 60034-12:2024](https://standards.iteh.ai/standards/iec/0c6f84ee-9f6c-42eb-bade-653b3aeb03a0/iec-60034-12-2024)

<https://standards.iteh.ai/catalog/standards/iec/0c6f84ee-9f6c-42eb-bade-653b3aeb03a0/iec-60034-12-2024>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.160.01

ISBN 978-2-8322-8990-7

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	4
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	7
4 Symbols	8
5 Designation	9
5.1 General.....	9
5.2 Design N.....	9
5.3 Design NE	9
5.4 Designs NY and NEY	9
5.5 Design H.....	9
5.6 Design HE	9
5.7 Designs HY and HEY	10
6 Design N requirements	10
6.1 Torque characteristics.....	10
6.2 Locked rotor current and apparent power	10
6.3 Starting requirements.....	10
7 Design NE starting requirements	11
8 Designs NY and NEY starting requirements	11
9 Design H requirements	11
9.1 Starting torque	11
9.2 Locked rotor current and apparent power.....	11
9.3 Starting requirements.....	11
10 Design HE starting requirements	12
11 Designs HY and HEY starting requirements	12
12 Determination of current and torque from measurement.....	12
12.1 Locked-rotor current and locked-rotor torque	12
12.2 Breakdown torque.....	12
12.3 Torque-speed curve and current-speed curve	13
12.3.1 General	13
12.3.2 Torque-speed and current-speed curves from direct measurement (method a).....	13
12.3.3 Torque-speed and current-speed curves from acceleration (method b)	13
12.3.4 Torque-speed and current-speed curves from measured input power (method c).....	14
12.4 Correction of data for tests performed at reduced voltage and/or other than rated frequency.....	14
Annex A (informative) Current and torque characteristics with locked rotor	20
Annex B (informative) Correction method for test done on reduced voltage.....	24
Bibliography.....	25
Figure A.1 – Locked-rotor current in multiples of rated current versus time	20
Figure A.2 – Locked-rotor torque in multiples of rated torque versus time	21
Figure A.3 – Locked-rotor torque in cNm versus rotor position in °; left: preferable number of rotor slots, right: less preferable number of rotor slots	21

Figure A.4 – Locked-rotor torque in cNm versus rotor position in ° 22

Figure A.5 – Time -courses (in s) of rotational speed (upper left), torque (lower left),
phase voltage (upper right) and phase current (lower right) during a star-delta start-up 23

Table 1 – Minimum values of torques for design N 15

Table 2 – Maximum values of locked rotor apparent power for designs N and H 16

Table 3 – Maximum values of locked rotor apparent power for designs NE and HE 16

Table 4 – External moment of inertia (*J*) 17

Table 5 – Minimum values of torques for design H 18

Table 6 – Minimum values of torques for design N motors with type of protection 'Ex
eb – increased safety' 18

Table 7 – External moment of inertia (*J*) for motors with type of protection 'Ex eb –
increased safety' 19

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 60034-12:2024](https://standards.iteh.ai/catalog/standards/iec/0c6f84ee-9f6c-42eb-bade-653b3aeb03a0/iec-60034-12-2024)

<https://standards.iteh.ai/catalog/standards/iec/0c6f84ee-9f6c-42eb-bade-653b3aeb03a0/iec-60034-12-2024>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ROTATING ELECTRICAL MACHINES –

**Part 12: Starting performance of single-speed
three-phase cage induction motors**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 60034-12:2016. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC 60034-12 has been prepared by IEC technical committee 2: Rotating machinery. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

Clause or subclause	Change
Table 6	Aligned with the requirements for explosion protected motors from TC31 WG27
12	New clause on methods for measuring locked-rotor current and torque
Annex A	New informative annex on the general current and torque characteristics with locked rotor
Annex B	New informative annex on correction of voltage and frequency

The text of this International Standard is based on the following documents:

Draft	Report on voting
2/2132/CDV	2/2150A/RVC

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 60034 series, published under the general title *Rotating electrical machines*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

ROTATING ELECTRICAL MACHINES –

Part 12: Starting performance of single-speed three-phase cage induction motors

1 Scope

This part of IEC 60034 specifies the parameters for eight designs of starting performance of single-speed three-phase 50 Hz or 60 Hz cage induction motors in accordance with IEC 60034-1 that:

- have a rated voltage up to 1 000 V;
- are intended for direct-on-line or star-delta starting;
- are rated on the basis of duty type S1;
- are constructed to any degree of protection as defined in IEC 60034-5 and explosion protection.

This document also applies to dual voltage motors provided that the flux saturation level is the same for both voltages.

The values of torque, apparent power and current given in this document are limiting values (that is, minimum or maximum without tolerance).

NOTE 1 It is not expected that all manufacturers will produce machines for all eight designs. The selection of any specific design in accordance with this document will be a matter of agreement between the manufacturer and the purchaser.

NOTE 2 Designs other than the eight specified ~~may~~ can be necessary for particular applications.

NOTE 3 ~~It should be noted that~~ Values given in manufacturers' catalogues ~~may~~ can include tolerances in accordance with IEC 60034-1.

NOTE 4 The values tabled for locked rotor apparent power are based on RMS symmetrical steady state locked rotor currents. ~~at motor switch on there will be a one-half cycle asymmetrical instantaneous~~ The start of the motor leads to transient asymmetrical currents in the whole supply, so called inrush currents, the peak ~~current~~ value of which ~~may~~ can range from 1,8 to 2,8 times the steady state locked rotor value. The current peak and decay time are a function of the motor design and switching angle. Similar effects can occur during the switchover from star to delta operation. A more detailed description is provided in Annex A.

The application of the test methods described in Clause 12 can be applied to cage induction motors outside the scope of this document. However, special care shall be taken in such cases to prevent overheating of the stator or the rotor winding depending on the concrete method and parameters chosen.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60034-1:2022, *Rotating electrical machines – Part 1: Rating and performance*

IEC 60034-5:2020, *Rotating electrical machines – Part 5: Degrees of protection provided by the integral design of rotating electrical machines (IP code) – Classification*

IEC 60034-30-1:2014, *Rotating electrical machines – Part 30-1: Efficiency classes of line-operated AC motors (IE-code)*

IEC 60079-7:2015, *Explosive atmospheres – Part 7: Equipment protection by increased safety "e"*

IEC 60079-7:2015/AMD1:2017

ISO 80000-4:2019, *Quantities and units – Part 4: Mechanics*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1

rated torque

T_N

torque the motor develops at its shaft end at rated output and speed

[SOURCE: IEC 60050-411:1996, 411-48-05]

3.2

locked-rotor torque

T_l

smallest measured torque the motor develops at its shaft end with the rotor locked, over all its angular positions, at rated voltage and frequency

<https://standards.iteh.ai/catalog/standards/iec/0c6f84ee-916c-42eb-bade-653b3aeb03a0/iec-60034-12-2024>

[SOURCE: IEC 60050-411:1996, 411-48-06]

3.3

pull-up torque

T_u

smallest steady-state asynchronous torque which the motor develops between zero speed and the speed which corresponds to the breakdown torque, when the motor is supplied at the rated voltage and frequency

[SOURCE: IEC 60050-411:1996, 411-48-42, modified – The notes 1 and 2 to entry have been modified.]

Note 1 to entry: This definition does not apply to those motors whose torque continually decreases with increase in speed.

Note 2 to entry: In addition to the steady-state asynchronous torques, harmonic synchronous torques, which are a function of rotor load angle, will be present at specific speeds. At such speeds, the accelerating torque ~~may~~ can be negative for some rotor load angles. Experience and calculation show this to be an unstable operating condition and therefore harmonic synchronous torques do not prevent motor acceleration and are excluded from this definition.

3.4 breakdown torque

T_b

maximum steady-state asynchronous torque which the motor develops without an abrupt drop in speed, when the motor is supplied at the rated voltage and frequency

[SOURCE: IEC 60050-411:1996, 411-48-43, modified – The notes 1 and 2 to entry have been modified.]

Note 1 to entry: This definition does not apply to those motors whose torque continually decreases with increase in speed.

3.5 rated output

P_N

value of the output power included in the rating

Note 1 to entry: The terms rated value and rating are defined in IEC 60034-1:2022, 3.1 and 3.2 (see also IEC 60050-411:1996, 411-51-23 and 411-51-24).

3.6 rated voltage

U_N

value of the voltage included in the rating

Note 1 to entry: The terms rated value and rating are defined in IEC 60034-1:2022, 3.1 and 3.2 (see also IEC 60050-411:1996, 411-51-23 and 411-51-24).

3.7 locked rotor apparent power

S_l

apparent power input with the motor held at rest at rated voltage and frequency after the inrush currents have decayed to a symmetrical system of current

[SOURCE: IEC 60050-411:1996, 411-48-49, modified – "after the inrush currents have decayed to a symmetrical system of current" has been added.]

3.8 locked rotor current

I_l

~~steady-state~~ current with the motor held at rest at rated voltage and frequency after the inrush currents have decayed to a symmetrical system of current

4 Symbols

I_l	Locked rotor current
J	External moment of inertia
J_M	Moment of inertia of motor under test
n	Rotational speed
p	Number of pole pairs
P_1	Power at the motor terminals during test method c) in 12.3.4
$P_{1,g}$	Power at the generator terminals during test method a) in 12.3.2
P_{fe}	Motor iron losses during test method c) in 12.3.4
P_L	Motor I^2R losses during test method c) in 12.3.4

$P_{T,g}$	Total losses of the generator during test method a) in 12.3.2
P_N	Rated output
S_l	Locked rotor apparent power
T_N	Rated torque
T_l	Locked rotor torque
T_u	Pull-up torque
T_b	Breakdown torque
T_{fw}	Motor friction and windage torque during test method c) in 12.3.4
U_N	Rated voltage

5 Designation

5.1 General

Motors designed according to this document are classified according to 5.2 to 5.7. The letters used to specify the different designs stand for:

- N: normal starting torque.
- H: high starting torque.
- Y: star-delta starting.
- E: motors utilizing extended / higher locked rotor apparent power and current to achieve a higher efficiency classes of IE3 or higher according to IEC 60034-30-1.

5.2 Design N

Normal starting torque three-phase cage induction motors, intended for direct-on-line starting, having 2, 4, 6 or 8 poles, rated from 0,12 kW to 1 600 kW.

<https://standards.iteh.ai/catalog/standards/iec/0c6f84ee-9f6c-42eb-bade-653b3aeb03a0/iec-60034-12-2024>

5.3 Design NE

Normal starting torque three-phase cage induction motors having higher locked rotor apparent power than design N, intended for direct-on-line starting, having 2, 4, 6 or 8 poles, rated from 0,12 kW to 1 600 kW.

5.4 Designs NY and NEY

Motors similar to designs N or NE, respectively, but intended for star-delta starting. For these motors in star-connection, minimum values for T_l and T_u are 25 % of the values of design N or NE, respectively, see Table 1.

5.5 Design H

High starting torque three-phase cage induction motors with 4, 6 or 8 poles, intended for direct-online starting, rated from 0,12 kW to 160 kW at a frequency of 60 Hz.

5.6 Design HE

High starting torque three-phase cage induction motors having higher locked rotor apparent power than design H, with 4, 6 or 8 poles, intended for direct-online starting, rated from 0,12 kW to 160 kW at a frequency of 60 Hz.

5.7 Designs HY and HEY

Motors similar to designs H or HE, respectively, but intended for star-delta starting. For these motors in star-connection, minimum values for T_1 and T_u are 25 % of the values of design H or HE, respectively, see Table 5.

6 Design N requirements

6.1 Torque characteristics

The starting torque is represented by three characteristic features. These features shall be in accordance with the appropriate values given in Table 1 or Table 6. The values in Table 1 and Table 6 are minimum values at rated voltage. Higher values are allowed.

The motor torque at any speed between zero and that at which breakdown torque occurs shall be not less than 1,3 times the torque obtained from a curve varying as the square of the speed and being equal to rated torque at rated speed. However, for 2-pole motors with type of protection 'Ex eb – increased safety' having a rated output greater than 100 kW, the motor torque at any speed between zero and that at which breakdown torque occurs shall not be less than 1,3 times the torque obtained from a curve varying as the square of the speed and being equal to 70 % rated torque at rated speed. For motors with type of protection 'Ex eb', the three characteristic torques shall be in accordance with the appropriate values given in Table 6.

NOTE The factor 1,3 has been chosen with regard to an undervoltage of 10 % in relation to the rated voltage at the motor terminals during the acceleration period.

6.2 Locked rotor current and apparent power

The locked rotor apparent power shall be not greater than the appropriate value given in Table 2. The values given in Table 2 are independent of the number of poles and are maximum values at rated voltage. For motors with type of protection 'e', locked rotor apparent power shall be in accordance with the appropriate values specified in IEC 60079-7.

The locked rotor current is calculated from the locked rotor apparent power according to:

$$I_l = \frac{S_l}{R_N} \times \frac{R_N}{\sqrt{3}U_N} \quad (1)$$

NOTE—The advantage of specifying S_l/P_N instead of I_l/I_N is that the locked rotor current can be calculated from rated power and rated voltage only, not requiring to know the rated current which depends on quantities such as power factor and efficiency that are usually not known in early stages of a project.

6.3 Starting requirements

Motors shall be capable of withstanding two starts in succession (coasting to rest between starts) from cold conditions and one start from hot after running at rated conditions. The retarding torque due to the driven load will be in each case proportional to the square of the speed and equal to the rated torque at rated speed with the external moment of inertia given in Table 4 or Table 7.

In each case, a further start is permissible only if the motor temperature before starting does not exceed the steady temperature at rated load. However, for 2-pole motors with type of protection 'Ex eb – increased safety' having a rated output greater than 100 kW, the retarding torque due to the driven load is proportional to the square of the speed and equal to 70 % rated torque at rated speed, with the external moment of inertia given in Table 7. After this starting, load with rated torque is possible.

NOTE—It should be recognized that the number of starts should be minimized since these affect the life of the motor.

7 Design NE starting requirements

The starting requirements are as for design N, except that the limits for locked rotor apparent power in Table 3 apply, as increasing efficiency values require physically increasing values for locked rotor apparent power.

8 Designs NY and NEY starting requirements

The starting requirements are as for designs N or NE, respectively. In addition, however, a reduced retarding torque is necessary as the starting torque in 'star connection' may be insufficient to accelerate some loads to an acceptable speed.

NOTE—It should be recognized that the number of starts should be minimized since these affect the life of the motor.

9 Design H requirements

9.1 Starting torque

The starting torque is represented by three characteristic features. These features shall be in accordance with the appropriate values given in Table 5. These values are minimum values at rated voltage. Higher values are allowed.

9.2 Locked rotor current and apparent power

The locked rotor apparent power shall be not greater than the appropriate value given in Table 2. The values in Table 2 are independent of the number of poles and are maximum values at rated voltage.

The locked rotor current is calculated from the locked rotor apparent power according to the formula given in 6.2.

9.3 Starting requirements

Motors shall be capable of withstanding two starts in succession (coasting to rest between starts) from cold conditions, and one start from hot after running at rated conditions. The retarding torque due to the driven load is assumed to be constant and equal to rated torque, independent of speed, with an external moment of inertia of 50 % of the values given in Table 4.

In each case, a further start is permissible only if the motor temperature before starting does not exceed the steady temperature at rated load.

NOTE—It should be recognized that the number of starts should be minimized since these affect the life of the motor.

10 Design HE starting requirements

The starting requirements are as for design H, except that the limits for locked rotor apparent power in Table 3 apply, as increasing efficiency values require physically increasing values for locked rotor apparent power.

11 Designs HY and HEY starting requirements

The starting requirements are as for design H or HE, respectively. In addition, however, a reduced retarding torque is necessary as the starting torque in 'star connection' may be insufficient to accelerate some loads to an acceptable speed.

NOTE—It should be recognized that the number of starts should be minimized since these affect the life of the motor.

12 Determination of current and torque from measurement

12.1 Locked-rotor current and locked-rotor torque

When possible, the locked-rotor current shall be measured at rated voltage and frequency as the current is not directly proportional to the voltage because of changes in reactance caused by saturation of the leakage paths. In case this isn't possible, see 12.4.

The locked-rotor torque may be measured with, e.g. a scale or force transducer with a brake or beam, or it may be measured directly using an in-line torque transducer, or it may be determined from the electrical input power using Formula (5). Depending on the chosen number of rotor slots, the locked-rotor torque of cage induction motors is subject to variations depending on the angular position of the rotor with respect to the stator. In case a preferable number of rotor slots is chosen according to the manufacturer's experience, it is usual practice to lock the rotor of a cage induction motor in any convenient position or to measure current and torque values with the rotor being stalled at very low speed, i.e. with a speed below 2 % of the rated speed.

<https://standards.iteh.ai/catalog/standards/iec/0c61f84ee-9f6c-42eb-bade-653b3aeb03a0/iec-60034-12-2024>

12.2 Breakdown torque

The breakdown torque can be measured by loading the motor, starting at no-load condition, with an increasing load torque. The load torque that is reached when the motor starts quickly loosing speed, is the breakdown torque.

Alternatively, the values of pull-up and breakdown torque can be measured during acceleration from reverse speed to no-load speed (see method c) below), provided the load machine inertia or load torque is sufficiently large. Sufficiently large means in case of power ratings up to 100 kW that the change of rotational speed during test satisfies, depending on the motor's moment of inertia J_M and the motor's locked-rotor torque T_l , the relation

$$\frac{dn}{dt} \leq \frac{0,05}{2\pi J_M} T_l . \quad (2)$$

Otherwise, the breakdown torque will be underestimated. For power ratings above 100 kW, different relations of the moment of inertia and the locked-rotor torque may be suitable according to the experience to the manufacturer.

In case the complete torque-speed curve is measured using one of the methods below, no separate measurement of the breakdown torque is required.