



Designation: E1003 – 13 (Reapproved 2022)

Standard Practice for Hydrostatic Leak Testing¹

This standard is issued under the fixed designation E1003; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice covers the testing of components for leaks by pressurizing them inside with a liquid.

1.2 This practice can be used on piping, valves, and containers with welded or fitted sections which can be sealed at their ends and which are designed for internal pressure.

1.3 Basic procedures are described based on the type of inspection used. These procedures should be limited to finding leakage indications of 4.5×10^{-9} mol/s (1×10^{-4} Std cm³/s)² or larger.

1.4 *Units*—The values stated in SI units are to be regarded as standard. The values given in parentheses are mathematical conversions to inch-pound units that are provided for information only and are not considered standard.

1.5 *This standard does not purport to address the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.6 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 *ASTM Standards:*³

[E543 Specification for Agencies Performing Nondestructive Testing](#)

[E1316 Terminology for Nondestructive Examinations](#)

¹ This practice is under the jurisdiction of ASTM Committee E07 on Nondestructive Testing and is the direct responsibility of Subcommittee E07.08 on Leak Testing Method.

Current edition approved June 1, 2022. Published July 2022. Originally approved in 1984. Last previous edition approved in 2018 as E1003 – 13(2018). DOI: 10.1520/E1003-13R22.

² The gas temperature is referenced to 0 °C. To convert to another gas reference temperature, T_{ref} , multiply the leak rate by $(T_{ref} + 273)/273$.

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

2.2 *ASNT Documents:*⁴

[SNT-TC-1A Recommended Practice for Personnel Qualification and Certification in Nondestructive Testing](#)
[ANSI/ASNT CP-189 ASNT Standard for Qualification and Certification of Nondestructive Testing Personnel](#)

2.3 *AIA Standard:*⁵

[NAS-410 Certification and Qualification of Nondestructive Test Personnel](#)

3. Terminology

3.1 *Definitions*—For definitions of terms used in this practice, see Terminology [E1316](#), Section E.

4. Summary of Practice

4.1 Hydrostatic testing requires that a component be completely filled with a liquid, such as water. Pressure is slowly applied to the liquid until the required pressure is reached. This pressure is held for the required time at which point the component is inspected visually to locate leaks or the pressure on the gauge is recorded to determine the components total leakage.

4.2 The two basic procedures are described together with methods for improving their sensitivity.

4.2.1 *Pressure Drop Indication*—This procedure is used primarily to measure total system leakage.

4.2.2 *Visual Inspection for Leakage*—This procedure is intended primarily to locate leaks.

4.3 Ultrasonic pretesting for gross leaks is described.

5. Basis of Application

5.1 The following items are subject to contractual agreement between the parties using or referencing this practice:

5.2 *Personnel Qualification*

5.2.1 If specified in the contractual agreement. Personnel performing examinations to this practice shall be qualified in accordance with a nationally or internationally recognized NDT personnel qualification practice or standard such as

⁴ Available from American Society for Nondestructive Testing (ASNT), P.O. Box 28518, 1711 Arlington Ln., Columbus, OH 43228-0518, <http://www.asnt.org>.

⁵ Available from Aerospace Industries Association of America, Inc. (AIA), 1000 Wilson Blvd., Suite 1700, Arlington, VA 22209-3928, <http://www.aia-aerospace.org>.

ANSI/ASNT CP-189, SNT-TC-1A, NAS-410, or similar document and certified by the employer or certifying agency, as applicable. The practice or standard used and its applicable revision shall be identified in the contractual agreement.

5.3 Qualification of Nondestructive Agencies—If specified in the contractual agreement, NDT agencies shall be qualified and evaluated as described in Specification E543. The applicable edition of Specification E543 shall be specified in the contractual agreement.

5.4 Re-examination of Repaired/Reworked Items—Re-examination of repaired/reworked items is not addressed in this practice, they shall be specified in the contractual agreement.

6. Significance and Use

6.1 This practice is useful for quality control testing and field inspection of piping systems, pipelines, valves, and containers that are expected to retain liquids. It is not sensitive enough for leak testing when toxic or explosive gas is expected to be retained under pressure.

7. Interferences

7.1 The interior and exterior welds and joints where leaks are often found must be free of oil, grease, flux, slag, or other contaminants that might temporarily block or mask leakage. New systems should be tested prior to painting, where practical.

7.2 Hydrostatic testing should not be performed before a leak test using air or a tracer gas. The liquid test media may leak small leaks causing later tests to be inaccurate.

7.3 Test liquid must be equal or above atmosphere temperature or droplets will form on the outside. The minimum temperature of the liquid should be 16 °C (61 °F).

7.4 If the container to be tested has parts made of stainless steel, nickel, or chromium alloys, the liquid or any additives used must have a sulfur and halogen content of less than 50 ppm of each. If water is used as a test fluid it should be deionized.

7.5 To avoid brittle fracture, the test pressure must not be applied until the metal and the test fluid are approximately the same temperature. The metal should be a minimum of 16 °C (61 °F) prior to the application of pressure.

7.6 If a test liquid other than water is used, the liquid's flash point should be 93 °C (200 °F) or above.

7.7 If plastic parts are used in the test container, the fluid should not promote stress cracking or softening on the plastic.

7.8 When the test container has carbon steel components, a rust inhibitor should be used.

8. Apparatus

8.1 **Pressure Gauge**—The gauge must be able to withstand normal test pressures and be accurate enough to record small pressure drops. Pressure gauges should be calibrated before each test. The gauge must be accurate to within 1 % of full scale. The gauge must read at least 1.5× but not more than 4× the maximum test pressure to be used. (See Terminology E1316 for a description of terms.)

8.2 **Pressure Relief Valve.**

8.3 **Pressure Alarm.**

8.4 **Emergency Pressure Shut-Off Valve.**

8.5 **Trapped Air Vent.**

8.6 **Pressure Pump.**

8.7 **Liquid Test Media.**

8.8 **Pressure Hoses and Fittings.**

8.9 **Protection Chamber for High-Pressure Tests.**

9. General Procedures

9.1 **Openings:**

9.1.1 Seal all openings using plugs or covers that can withstand the test pressure and can be completely removed after the test.

9.1.2 The test fluid inlet should be located on the bottom of the test object with the trapped air vent at the highest point.

9.1.3 Components rated at pressures below the test pressure must be isolated.

9.2 **Gauges**—One or more test gauges must be connected to the system. If more than one gauge is used, one may be a recording gauge. At least one gauge which is used for acceptance of the test shall be calibrated within 30 days prior to use. One indicating gauge must be easily visible to the operator controlling the pressure throughout the pressurizing and testing cycle.

9.3 **Pre-Test Inspection:**

9.3.1 Before pressurizing is begun, inspect the outside of the test object to verify that it is dry and all welds and connectors are exposed if a visual inspection is to be conducted.

9.3.2 Securely brace critical areas that may not be able to withstand the weight.

9.4 **Pressurizing**—Gradually increase the pressure in the system to 50 % of test pressure and make an initial check for leakage. Thereafter slowly increase the pressure to the final test pressure. The test pressure usually is between 75 % and 150 % of the operating design pressure.

9.5 **Leak Test:**

9.5.1 At the completion of test pressure holding time, examine the system for leakage. Examination for leakage shall be made of all accessible joints and connections, attachment welds where practical, and weep holes for paddings and attachments. Also inspect the area around inaccessible leakage sites.

9.5.2 The inspector shall circle all accessible leaks found on the equipment using a nondeleterious marker. The magnitude of leak shall be described in terms of: damp or moist area, drops per minute or steady stream.

9.6 **Depressurizing**—After inspection release the pressure slowly. The air vents need to be opened during draining to admit air and prevent collapsing of the test system.

10. Pressure Drop Method

10.1 Pressurize the system in accordance with Section 8.