



Edition 2.0 2024-06 REDLINE VERSION

# INTERNATIONAL STANDARD



Electric cables – Calculation of the current rating – Part 2-3: Thermal resistance – Cables installed in ventilated tunnels

# **Document Preview**

IEC 60287-2-3:2024

https://standards.iteh.ai/catalog/standards/iec/79bcf173-38af-42d0-b781-82af4cc87bda/iec-60287-2-3-2024





# THIS PUBLICATION IS COPYRIGHT PROTECTED Copyright © 2024 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

**IEC** Secretariat 3, rue de Varembé CH-1211 Geneva 20 Switzerland

Tel.: +41 22 919 02 11 info@iec.ch www.iec.ch

#### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

#### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

### IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

### IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

#### IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

#### Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.







Edition 2.0 2024-06 REDLINE VERSION

# INTERNATIONAL STANDARD



Electric cables – Calculation of the current rating – Part 2-3: Thermal resistance – Cables installed in ventilated tunnels

# **Document Preview**

IEC 60287-2-3:2024

https://standards.iteh.ai/catalog/standards/iec/79bcf173-38af-42d0-b781-82af4cc87bda/iec-60287-2-3-2024

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ICS 29.060.20

ISBN 978-2-8322-9370-6

Warning! Make sure that you obtained this publication from an authorized distributor.

# CONTENTS

FO	REWO	RD	4			
INT	rodu	CTION	2			
1	Scop	e	7			
2	Normative references					
3	Term	s, definitions and symbols	7			
;	3.1	Terms and definitions	7			
	3.2	Symbols	8			
4	Desc	ription of method	9			
	4.1	eneral description				
	4.2	Basic formulae	10			
	4.2.1	General	10			
	4.2.2	Radial heat transfer by conduction within the cable				
	4.2.3	tunnel	11			
	4.2.4	Heat transfer by convection from the cable surface to the air inside the tunnel	12			
	4.2.5	Heat transfer by convection from the air inside the tunnel to the inner tunnel wall	14			
	4.2.6	Longitudinal heat transfer by convection resulting from the forced or natural flow of air along the tunnel	14			
	4.2.7	Radial heat conduction in the soil surrounding the tunnel Set of formulae	15			
	4.3					
	4.4	Solving	17			
	4.5	Iterative process	19			
5	Form	ulae for air properties	20			
6	Temp	perature profile	20			
Anı		informative) Calculation example				
	A.1	Cable and installation	22			
	A.2	Calculated values	22			
Anı	nex B (	informative) Delta-star transformation	25			
Anı	nnex C (informative) Calculation of Fm $C_{\rm Fm}$ coefficient					
	C.1	Definition of spacing	27			
	C.2 Calculation of C <sub>Fm</sub> coefficient					
Bib	liograp	hy	29			
Fig	ure A. <sup>2</sup>	1 – Temperature profile along a 1 km tunnel	24			
Fig	ure A.2	2 – Temperature profile along a 10 km tunnel	24			
Fig	ure B. <sup>2</sup>	1 – Delta-star transformation	26			
Figure C.1 – Spacing definitions						
Tab	ole 1 –	F <sub>m</sub> C <sub>Fm</sub> coefficient for radiation thermal resistance calculation	12			
Tak	ble 2 –	Values of parameter $K_{CV}$	14			
		– Installation data				
		<ul> <li>Iterative process for a 1 km long tunnel</li> </ul>				

IEC 60287-2-3:2024 RLV © IEC 2024 - 3 -

# iTeh Standards (https://standards.iteh.ai) Document Preview

<u>IEC 60287-2-3:2024</u> https://standards.iteh.ai/catalog/standards/iec/79bcf173-38af-42d0-b781-82af4cc87bda/iec-60287-2-3-2024

# INTERNATIONAL ELECTROTECHNICAL COMMISSION

# ELECTRIC CABLES – CALCULATION OF THE CURRENT RATING –

# Part 2-3: Thermal resistance – Cables installed in ventilated tunnels

# FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
  - 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
  - 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 60287-2-3:2017. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC 60287-2-3 has been prepared by IEC technical committee 20: Electric cables. It is an International Standard.

This second edition cancels and replaces the first edition published in 2017. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) symbols alignment with other parts of the IEC 60287 series.

The text of this International Standard is based on the following documents:

Draft	Report on voting	
20/2175/FDIS	20/2182/RVD	

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members\_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 60287 series, published under the general title *Electric cables* – *Calculation of the current rating*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be 4200-b781-82a44cc87bda4cc-60287-23-2024

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

# INTRODUCTION

In the IEC 60287 series, IEC 60287-1 provides general formulae for ratings and power losses of electric cables.

The IEC 60287-2 series presents formulae or calculation methods for thermal resistances.

IEC 60287-2-1 provides calculation methods for dealing with cables installed in free air (see IEC 60287-2-1:2015, 4.2.1).

IEC 60287-2-2 provides a method and data for calculating reduction factors for cables in groups running horizontally in free air.

IEC 60287-2-1 and IEC 60287-2-2 consider heat transfer only in a plane perpendicular to the cables; they assume there is no longitudinal heat transfer.

This part of IEC 60287 deals with the rating for cables installed in ventilated tunnels. In such situations, consideration of longitudinal temperature gradients is involved as the air flowing in the tunnel removes some heat from the cables.

Heat transfer with the moving air is convective and is assumed to be either laminar or turbulent depending on the air velocity. The transition situation between laminar and turbulent air flows is ignored.

# iTeh Standards

A general simplified method is provided to estimate the permissible current-carrying capacity of cables installed in ventilated tunnels, the ventilation being either natural or forced.

Only steady states are considered, where the inlet air temperature and the cable loading are constant for a sufficient time for steady temperatures to be achieved.

Where multiple circuits are involved, their characteristics are assumed to be identical.

The main features of the calculation method for cables in tunnels with forced ventilation can be found in Electra  $n^{\circ}143 - 144 (1992)[1]^{1}$ , as the report of a CIGRE working group, including the erratum in Electra  $n^{\circ}209 (2003)$ .

<sup>&</sup>lt;sup>1</sup> Numbers in square brackets refer to the Bibliography.

# ELECTRIC CABLES – CALCULATION OF THE CURRENT RATING –

# Part 2-3: Thermal resistance – Cables installed in ventilated tunnels

# 1 Scope

This part of IEC 60287 describes a method for calculating the continuous current rating factor for cables of all voltages installed in ventilated tunnels. The method is applicable to any type of cable.

The method applies to natural as well as forced ventilation.

Longitudinal heat transfer within the cables and the surroundings of the tunnel is assumed to be negligible.

All cables are assumed to be identical within the tunnel and it is assumed that the tunnel crosssection does not change with distance along the tunnel.

# 2 Normative references iTeh Standards

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60287-1-1, Electric cables – Calculation of the current rating – Part 1-1: Current rating equations (100 % load factor) and calculation of losses – General

IEC 60287-2-1:2015, Electric cables – Calculation of the current rating – Part 2-1: Thermal resistance – Calculation of thermal resistance

# 3 Terms, definitions and symbols

## 3.1 Terms and definitions

No terms and definitions are listed in this document.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at https://www.electropedia.org/
- ISO Online browsing platform: available at <a href="https://www.iso.org/obp">https://www.iso.org/obp</a>

# 3.2 Symbols

At	inner tunnel cross-sectional area	m <sup>2</sup>
Cav	heat capacity of the air flow	W/K
C <sub>vair</sub>	volumetric heat capacity of air	W · s/(m <sup>3</sup> · K
$D_{e}^{*}$	external diameter of cable	m
Dt	inner diameter of the tunnel	m
₣ <sub>m</sub> C <sub>Fm</sub>	coefficient for the calculation of radiation shape factor	_
I	current in one conductor (RMS value)	A
K <sub>cv</sub>	convection factor	-
K <sub>r</sub>	radiation shape factor	-
K <sub>t</sub>	effective emissivity	-
<b>Ŀ</b> ŧ <sup>Ľ</sup> t	depth of tunnel axis	m
Ν	number of cables	-
P <sub>r</sub>	Prandtl number	-
Re	Reynolds number	-
<mark>₽</mark> ₽ ₽	alternating current resistance of conductor at its maximum operating temperature	
T <sub>1</sub>	thermal resistance per core between conductor and sheath	K · m/W
T <sub>2</sub>	thermal resistance between sheath and armour	K · m/W
T <sub>3</sub>	thermal resistance of external serving entry review	K · m/W
T <sub>4t</sub>	equivalent thermal resistance of cable surrounding	K · m/W
T <sub>as</sub>	convection thermal resistance between cable and air	K · m/W
tandard T <sub>at</sub>	convection thermal resistance between air and inner wall of the tunnel	K · m/W
T <sub>e</sub>	external thermal resistance of the tunnel	K · m/W
T <sub>st</sub>	radiation thermal resistance between cable and inner wall of the tunnel	K · m/W
<mark>₽</mark> а <sup>Т*</sup> а	equivalent star thermal resistance of air	K · m/W
<b>₽<sub>sT*</sub></b> s	equivalent star thermal resistance of cable	K · m/W
$\frac{T_t}{T_t}T_t^*$	equivalent star thermal resistance of tunnel wall	K · m/W
<b>₽</b> V <sub>air</sub>	air velocity	m/s
$W_{a}(z_{t})$	heat removed by the air, at the point $\frac{1}{z}z_t$ on the cable route	W/m
W <sub>a</sub> ( <mark>⊾</mark> z <sub>tot</sub> )	heat removed by the air, at tunnel outlet	W/m
W <sub>c</sub>	losses in a conductor per unit length, assuming maximum conductor temperature	W/m
W <sub>d</sub>	dielectric losses per unit length per phase	W/m
<mark>₩</mark> kwktot	total heat generated by cable	W/m
h	heat dissipation coefficient given in IEC 60287-2-1 for cables in still air	W/(m <sup>2</sup> · K <sup>5/4</sup> )
k <sub>air</sub>	thermal conductivity for air	W/(m · K)
n	number of conductors or cores in a cable	
<sup>s</sup> 1	axial separation between two adjacent cables (mm)	mm
s <sub>r</sub>	ratio between spacing and cable diameter	-

-2024

<b>₽</b> ₽ <sup>2</sup> 0	reference length (see Formula (16))	m
zz <sub>t</sub>	coordinate corresponding to the tunnel axis	m
<u></u> <i>Lz</i> <sub>tot</sub>	length of the tunnel	m
$\Delta \theta_0$	fictitious increase of ambient temperature to account for the ventilation	К
$\theta_{a}$	temperature at ground level	°C
$\theta_{at}(0)$	air temperature at tunnel inlet	°C
$\theta_{at}(\mathbf{z}\mathbf{z}_{t})$	air temperature, at the point $\frac{z}{z}$ on the cable route	°C
θ <sub>at</sub> (≟z <sub>tot</sub> )	air temperature at tunnel outlet	°C
$\frac{\theta(z)}{\theta_{c}(z_{t})}$	conductor temperature, at the point $\frac{1}{2}z_t$ on the cable route	°C
$\theta_{\rm c_max}$	maximum permissible conductor temperature	°C
$\theta_{e}(\mathbf{z}\mathbf{z}_{t})$	temperature at the star point after delta-star transformation	°C
$\theta_{s}(\mathbf{z}_{t})$	temperature of the cable surface, at the point $\mathbf{z}\mathbf{z}_t$ on the cable route	°C
$\theta_{s}(Lz_{tot})$	temperature of the cable surface, at tunnel outlet	°C
$\theta_t(\mathbf{z}_t)$	temperature of the inner tunnel wall, at the point $\mathbf{z}_{t}$ on the cable route	°C
$\theta_{t}(Lz_{tot})$	temperature of the inner tunnel wall, at tunnel outlet	°C
λ <sub>1</sub>	ratio of the total losses in metallic sheaths to the total conductor losses (sheath/ or screen loss factor)	-
λ2	ratio of the total losses in armour to the total conductor losses (armour loss factor)	-
ν	kinematic viscosity for air	m²/s
ρ <sub>soil</sub> ρ	soil thermal resistivity <b>Document Preview</b>	K · m/W
$\sigma_{B}$	Stefan-Boltzmann constant	$W/(m^2 \cdot K^4)$

EC 60287-2-3:2024

ttps://standards.iteh.ai/catalog/standards/iec/79bcf173-38af-42d0-b781-82af4cc87bda/iec-60287-2-3-2024 4 Description of method

# 4.1 General description

The method is based on the calculation of the temperature of the cable surface, the air in the tunnel and the tunnel wall, as a function of the heat generated by the cables.

For any location along the cable route, a set of formulae is developed, involving:

- heat transfer formulae describing heat transfer mechanisms by radiation and convection between the cables, the air in the tunnel and the tunnel wall;
- energy balance formulae for cables, air in the tunnel and tunnel wall;
- heat transfer formulae for conduction in the surroundings of the tunnel.

This set of formulae may be written in such a way that:

- the heat removed by the air, W<sub>a</sub>(zz<sub>t</sub>), is linked to the derivative of the air temperature with respect to the longitudinal coordinate of the tunnel;
- every other formula is approximated as a thermal Ohm's law linking temperature drop and heat flow through a thermal resistance; the heat flow is derived from the heat generated by the cables, \(\mathcal{W}\_k W\_{ktot}\), and the heat removed by the air, \(W\_a(\mathcal{z}z\_t)\).

Some of the thermal resistances depend on the air temperature and consequently on the distance along the tunnel.

This may be dealt with by dividing the tunnel route into elementary lengths, so that:

- the heat removed by the air is proportional to the difference in the air temperature between elementary length outlet and inlet;
- the thermal resistances may be considered constant for the elementary length.


For typical installations considered in the CIGRE work [1], it was recognized that assuming constant thermal resistances along the tunnel route, computed using temperatures at the tunnel outlet, does not lead to a serious error.

With this assumption, solving the set of formulae is straightforward and the temperatures of the cable surface, air and tunnel wall are easily derived as a function of the cable losses.

The permissible current is then derived from the heat transfer formula for conduction within the cable linking the temperature drop between the conductor and the cable surface to the losses in the cables.

As temperatures at the tunnel outlet are not known, an iterative process is necessary.

The heat generated by a cable,  $\#_{k}W_{ktot}$ , is assumed to be constant along the cable route and is calculated for the maximum permissible conductor temperature, leading to an estimate of the current rating that is on the safe side.



# $\frac{W_{\rm C}-R}{K}$

# where

- $\frac{W_k}{W_{ktot}}$  is the total heat generated by a cable (W/m);
- *n* is the number of conductors in a cable;
- $W_{c}$  is the losses in a conductor per unit length, assuming maximum conductor temperature (W/m);
- $\lambda_1$  is the ratio of the total losses in metallic sheaths to the total conductor losses;
- $\lambda_2$  is the ratio of the total losses in armour to the total conductor losses;
- $W_{d}$  is the dielectric losses per unit length per phase (W/m);
- $R_R$  is the alternating current resistance of conductor at its maximum operating temperature with sustained application of a rated  $I_R$  current i.e. at standard maximum permissible temperature ( $\Omega$ /m);
- *I* is the current in one conductor (RMS value) (A).

## 4.2 Basic formulae

# 4.2.1 General

The following heat transfer mechanisms are taken into account:

- radial heat transfer by conduction within the cable;
- heat transfer by radiation from the cable surface to the tunnel wall;
- heat transfer by convection from the cable surface to the air inside the tunnel;
- heat transfer by convection from the air inside the tunnel to the tunnel wall;
- longitudinal heat transfer by convection resulting from the forced or natural flow of air along the tunnel.

# 4.2.2 Radial heat transfer by conduction within the cable

The conductor temperature is derived from the formula given in IEC 60287-1-1.

$$\frac{\theta(z) - \theta_{s}(z) + W_{c} \left[T_{1} + n \cdot (1 + \lambda_{1}) \cdot T_{2} + n \cdot (1 + \lambda_{1} + \lambda_{2}) \cdot T_{3}\right] + W_{d} \left[\frac{T_{1}}{2} + n \cdot (T_{2} + T_{3})\right]}{2}$$
  
$$\theta_{c}(z_{t}) = \theta_{s}(z_{t}) + W_{c} \cdot \left[T_{1} + n \cdot (1 + \lambda_{1}) \cdot T_{2} + n \cdot (1 + \lambda_{1} + \lambda_{2}) \cdot T_{3}\right] + W_{d} \cdot \left[\frac{T_{1}}{2} + n \cdot (T_{2} + T_{3})\right]$$
(3)

## where

 $\theta(z)\theta_c(z_t)$  is the conductor temperature, at the point  $z z_t$  on the cable route (°C);

 $\theta_{s}(\mathbf{z}z_{t})$  is the temperature of the cable surface, at the point  $\mathbf{z}z_{t}$  on the cable route (°C);

 $T_1$  is the thermal resistance per core between conductor and sheath (K · m/W);

 $T_2$  is the thermal resistance between sheath and armour (K · m/W);

 $T_3$  is the thermal resistance of external serving (K  $\cdot$  m/W);

z<sub>t</sub> is the coordinate corresponding to the tunnel axis (m).

The loss coefficients and thermal resistances are defined in IEC 60287-1-1 and IEC 60287-2-1.

# 4.2.3 Heat transfer by radiation from the cable surface to the inner wall of the tunnel

This heat transfer is modelled by Ohm's thermal law, characterized by a thermal resistance:

$$\frac{T_{st} - \frac{1}{\pi \cdot D_{e}^{*} \cdot K_{t} \cdot K_{r} \cdot \sigma_{b} \cdot \left[(\theta_{s}(L) + 273)^{2} + (\theta_{t}(L) + 273)^{2}\right] \cdot \left[\overline{(\theta_{s}(L) + 273) + (\theta_{t}(L) + 273)}\right]}{\left[\overline{(\theta_{s}(L) + 273)^{2}} + \left(\theta_{t}(z_{tot}) + 273\right)^{2}\right] \cdot \left[\overline{(\theta_{s}(L) + 273) + (\theta_{t}(L) + 273)}\right]}$$

$$T_{st} = \frac{1}{\pi \cdot D_{e}^{*} \cdot K_{t} \cdot K_{r} \cdot \sigma_{b} \cdot \left[\left(\theta_{s}(z_{tot}) + 273\right)^{2} + \left(\theta_{t}(z_{tot}) + 273\right)^{2}\right]} \cdot \left[\overline{(\theta_{s}(z_{tot}) + 273) + (\theta_{t}(z_{tot}) + 273)}\right]$$
(4)

where

 $D_e^*$  is the cable diameter (m);

 $\sigma_{\rm B}$  is Stefan-Boltzmann constant, 5,67 × 10<sup>-8</sup> (W/m<sup>2</sup> · K<sup>4</sup>);

 $\theta_{s}(L)\theta_{s}(z_{tot})$  is the cable surface at the tunnel outlet (°C);

 $\theta_t(L)\theta_t(z_{tot})$  is the tunnel surface temperatures at the tunnel outlet (°C);

is the emissivity of the cable surface (typically 0,9 for served cable); Kt

K<sub>r</sub> is the radiation shape factor taking into account the radiation areas;

is the length of the tunnel (m). Z<sub>tot</sub>

 $K_{\rm r}$  may be expressed as:

$$\frac{K_{\rm r}}{1 - (1 - K_{\rm t}) \cdot F_{\rm m}}$$

$$K_{\rm r} = \frac{1 - C_{\rm Fm}}{1 - (1 - K_{\rm t}) \cdot C_{\rm Fm}}$$

where

 $C_{\text{Fm}} \models_{\text{m}}$ - is a coefficient given in Table 1 and in Annex C.



	Installation	F <sub>m</sub> C <sub>Fm</sub>	
	Single cable	0	
	Two cables touching	0,182	1)
	Two cables spaced 2 × $D_e^*$	0,081	
	Two cables spaced 3 × $D_{e}^{*}$	0,054	
		M: 0,363	
	Three cables touching (287-2-3)	O: 0,182	4cc87bda/iec-60287-2-3-2024
	Three cables spaced 2 × $D_e^*$ Three cables spaced 3 × $D_e^*$	M: 0,163	+00287-2-3-202
		O: 0,081	
		M: 0,107	
		O: 0,054	
	Trefoil touching	0,348	
	Кеу		
	M Middle cable		
	O Outer cable		

#### 4.2.4 Heat transfer by convection from the cable surface to the air inside the tunnel

The convective heat transfer from the cable surface to the air in the tunnel depends on the air flow characteristics, the velocity of the air being the leading parameter.