



Designation: D1982 – 13 (Reapproved 2022)

Standard Test Method for Titer of Fatty Acids¹

This standard is issued under the fixed designation D1982; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This test method covers the determination of the solidification (titer) point of fatty acids and is applicable to all fatty acids.

1.2 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.4 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 *ASTM Standards:*²

E1 Specification for ASTM Liquid-in-Glass Thermometers

2.2 *AOCS Standard:*³

Specification H 6-40

3. Significance and Use

3.1 Saturated fatty acids solidify at a higher temperature than unsaturated fatty acids. This test method provides a means of measuring the solidification temperature of a sample containing both unsaturated and saturated fatty acids by cooling the specimen and measuring the temperature at which solidification occurs.

¹ This test method is under the jurisdiction of ASTM Committee D01 on Paint and Related Coatings, Materials, and Applications and is the direct responsibility of Subcommittee D01.34 on Pine Chemicals and Hydrocarbon Resins.

Current edition approved Dec. 1, 2022. Published December 2022. Originally approved in 1961. Last previous edition approved in 2017 as D1982 – 13 (2017). DOI: 10.1520/D1982-13R22.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from American Oil Chemists' Society (AOCS), 2710 S. Boulder, Urbana, IL 61802-6996, <http://www.aocs.org>.

3.2 Samples containing higher levels of saturated acids will have a higher titer (solidification temperature) than those with lower levels of saturated acids.

3.3 Water present in the sample will raise the titer, so provisions are made in the test method to remove traces of moisture.

4. Apparatus

4.1 *Beaker*, Griffin low-form, 2-L capacity.

4.2 *Bottle*, wide-mouth, 450-mL capacity, 190-mm height, inside diameter of neck 40 mm.

4.3 *Test Tubes*, 100 mm in length, 25 mm in diameter, with or without rim. These tubes may have an etched mark extending around the tube at a distance of 57 mm from the bottom to show the height to which the tube is to be filled.

4.4 *Stirrer*, 2 mm to 3 mm in outside diameter, with one end bent in the form of a loop 20 mm in outside diameter. Glass or stainless steel wire may be used. The upper end can be formed to accommodate hand stirring or to be attached to a mechanical stirrer.

4.5 *Laboratory Thermometer*, having a range from 0 °C to 150 °C.

4.6 *Titer Test Thermometer*—An ASTM Titer Test Thermometer having a range from –2 °C to +68 °C and conforming to the requirements for Thermometer 36C as prescribed in Specification E1. Thermometric devices such as RTDs, thermistors and liquid-in-glass thermometers of equal or better accuracy in the specified temperature range, may be used.

NOTE 1—Thermometers conforming to the requirements for the AOCS Titer Thermometer (AOCS Specification H 6-40) meet these requirements.

5. Procedure

5.1 Heat the sample on a hot plate to 130 °C to remove traces of moisture, and fill a test tube (see 4.3) to a height of 57 mm from the bottom.

5.1.1 Do not hold the sample at 130 °C nor reheat to this temperature more than once. If excessive moisture is present, allow the water to settle, decant the fatty acids, and then refilter and reheat. The acids must be dry and free of suspended matter.




FIG. 1 Apparatus Assembly for Titer Test

5.2 Fill the water bath to the designated level (Fig. 1) and adjust the temperature to 15 °C to 20 °C below the expected titer point.

5.3 Place the test tube containing the fatty acids in the assembly as shown in Fig. 1. Insert the titer thermometer to the immersion mark so that it will be equidistant from the sides of the tube.

5.4 Stir with the stirring rod through a vertical distance of about 40 mm at the rate of 100 complete up-and-down motions per minute (Note 2). Start the agitation while the temperature is at least 10 °C above the titer point.

NOTE 2—Stirring may be performed mechanically by attaching a small motor with suitable speed-reducing mechanism to the stirring rod.

5.5 Stir at the specified rate until the temperature remains constant for 30 s or begins to rise in less than a 30-s interval.

Discontinue stirring immediately, remove the stirrer or raise it out of the specimen, and observe the increase in temperature. The titer point is the highest temperature indicated by the thermometer during this rise.

6. Precision and Bias

6.1 *Precision*—Duplicate determinations by the same operator should agree within 0.2 °C.

6.2 *Bias*—Bias has not been determined.

7. Keywords

7.1 fatty acids; saturated fatty acids; solidification point; titer

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; http://www.copyright.com/