

SLOVENSKI STANDARD

SIST EN 60870-6-802:2000

01-februar-2000

Telecontrol equipment and systems - Part 6: Telecontrol protocols compatible with ISO standards and ITU-T recommendations - Section 802: TASE.2 object models (IEC 60870-6-802:1998)

Telecontrol equipment and systems - Part 6: Telecontrol protocols compatible with ISO standards and ITU-T recommendations -- Section 802: TASE.2 Object models (IEC 60870-6-802:1998)

Fernwirkeinrichtungen und -systeme -- Teil 6: Fernwirkprotokolle, die mit ISO-Normen und ITU-T-Empfehlungen kompatibel sind -- Hauptabschnitt 802: TASE.2, Objektmodelle

Matériels et systèmes de téléconduite -- Partie 6: Protocoles de téléconduite compatibles avec les normes ISO et les recommandations de l'ITU-T -- Section 802: Modèles d'objets TASE.2

Ta slovenski standard je istoveten z: EN 60870-6-802:1997

ICS:

33.200 Daljinsko krmiljenje, daljinske Telecontrol. Telemetering meritve (telemetrija)

SIST EN 60870-6-802:2000

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60870-6-802:2000

<https://standards.iteh.ai/catalog/standards/sist/1d5d258c-3833-498d-83ac-9dd378037bc1/sist-en-60870-6-802-2000>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 60870-6-802

November 1997

ICS 33.200

Descriptors: Telecontrol, protocol, object model

English version

Telecontrol equipment and systems
Part 6: Telecontrol protocols compatible with ISO standards and
ITU-T recommendations
Section 802: TASE.2 Object models
(IEC 60870-6-802:1997)

Matériels et systèmes de téléconduite
Partie 6: Protocoles de téléconduite
compatibles avec les normes ISO et
les recommandations de l'UIT-T
Section 802: Modèles d'objets TASE.2
(CEI 60870-6-802:1997)

Fernwirkrichtungen und -systeme
Teil 6: Fernwirkprotokolle, die mit
ISO-Normen und ITU-T-Empfehlungen
kompatibel sind
Hauptabschnitt 802: TASE.2,
Objektmodelle
(IEC 60870-6-802:1997)

<https://standards.iteh.ai/catalog/standards/sist/1d5125cc-0029-46e8-9dd378037bc1/sist-en-60870-6-802-2000>

This European Standard was approved by CENELEC on 1997-10-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

© 1997 CENELEC - All rights of exploitation in any form and by any means reserved worldwide for CENELEC members.

Ref. No. EN 60870-6-802:1997 E

Foreword

The text of document 57/314/FDIS, future edition 1 of IEC 60870-6-802, prepared by IEC TC 57, Power system control and associated communications, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60870-6-802 on 1997-10-01.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 1998-07-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 1998-07-01

Annexes designated "normative" are part of the body of the standard.
Annexes designated "informative" are given for information only.
In this standard, annex ZA is normative and annex A is informative.
Annex ZA has been added by CENELEC.

iTeh STANDARD PREVIEW Endorsement notice (standards.iteh.ai)

The text of the International Standard IEC 60870-6-802:1997 was approved by CENELEC as a European Standard without any modification.

[SIST EN 60870-6-802:2000](https://standards.iteh.ai/catalog/standards/sist/1d5d258c-3833-498d-83ac-9dd378037bc1/sist-en-60870-6-802-2000)

<https://standards.iteh.ai/catalog/standards/sist/1d5d258c-3833-498d-83ac-9dd378037bc1/sist-en-60870-6-802-2000>



Annex ZA (normative)

Normative references to international publications
with their corresponding European publications

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

NOTE: When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60870-5-101	1995	Telecontrol equipment and systems Part 5: Transmission protocols Section 101: Companion standard for basic telecontrol tasks	EN 60870-5-101	1996
IEC 60870-6-503	1997	Part 6: Telecontrol protocols compatible with ISO standards and ITU-T recommendations Section 503: TASE.2 Services and protocol	EN 60870-6-503	1997
ISO/IEC 9506-1	1990	Industrial automation systems Manufacturing message specification Part 1: Service definition	-	-
ISO/IEC 9506-2	1990	Part 2: Protocol specification	-	-

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60870-6-802:2000

<https://standards.iteh.ai/catalog/standards/sist/1d5d258c-3833-498d-83ac-9dd378037bc1/sist-en-60870-6-802-2000>

NORME
INTERNATIONALE

CEI
IEC

INTERNATIONAL
STANDARD

60870-6-802

Première édition
First edition
1997-10

Matériels et systèmes de téléconduite –

Partie 6:

**Protocoles de téléconduite compatibles
avec les normes ISO et les recommandations
de l'UIT-T –**

Section 802: Modèles d'objets TASE.2

(standards.iteh.ai)

Telecontrol equipment and systems –

<https://standards.iteh.ai/catalog/standards/sist/1d5d258c-3833-498d-83ac-9dd378037bc1/sist-en-60870-6-802-2000>

Part 6:

**Telecontrol protocols compatible
with ISO standards and ITU-T recommendations –
Section 802: TASE.2 Object models**

© IEC 1997 Droits de reproduction réservés — Copyright - all rights reserved

Aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'éditeur.

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission
Telefax: +41 22 919 0300

3, rue de Varembé Geneva, Switzerland
e-mail: inmail@iec.ch IEC web site <http://www.iec.ch>



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

CODE PRIX
PRICE CODE **XB**

*Pour prix, voir catalogue en vigueur
For price, see current catalogue*

CONTENTS

	Page
FOREWORD	7
INTRODUCTION	9
Clause	
1 Scope	11
2 Normative references	11
3 Definitions	11
4 Abbreviations	11
5 Object models	13
5.1 Supervisory Control and Data Acquisition	13
5.1.1 IndicationPoint Object	13
5.1.2 ControlPoint Object	19
5.1.3 Protection Equipment Event Object Model	21
5.2 Transfer Accounts	27
5.2.1 TransferAccount Object	27
5.2.2 TransmissionSegment Object	33
5.2.3 ProfileValue Object	37
5.2.4 AccountRequest Object	39
5.3 Device Outage Object	39
5.4 InformationBuffer Object	45
5.5 Power Plant Objects	47
5.5.1 Availability Report Object	47
5.5.2 Real Time Status Object	55
5.5.3 Forecast Schedule Object	59
5.5.4 Curve Object	61
5.5.5 Power System Dynamics Objects	63
6 MMS types for object exchange	63
6.1 Supervisory Control and Data Acquisition Types	65
6.1.1 IndicationPoint Type Descriptions	65
6.1.2 ControlPoint Type Descriptions	69
6.1.3 Protection Equipment Type Descriptions	71
6.2 Transfer Account Types	73
6.2.1 TransferAccount Type Descriptions	75
6.2.2 TransmissionSegment Type Descriptions	77
6.2.3 ProfileValue Type Descriptions	77
6.2.4 AccountRequest Type Descriptions	77
6.3 Device Outage Type Descriptions	77
6.4 InformationBuffer Type Descriptions	81

Clause	Page
6.5 Power Plant Type Descriptions.....	81
6.5.1 Availability Report Type Descriptions	83
6.5.2 Real Time Status Type Descriptions.....	85
6.5.3 Forecast Type Descriptions.....	85
6.5.4 Curve Type Descriptions.....	85
6.6 Power System Dynamics.....	87
6.7 Matrix Data Types.....	87
7 Mapping of object models to MMS types	89
7.1 Supervisory Control and Data Mapping.....	89
7.1.1 Indication Object Mapping.....	89
7.1.2 ControlPoint Object Mapping.....	91
7.1.3 Protection Event Mapping	93
7.2 Transfer Accounts Mapping	99
7.2.1 TransferAccount Mapping	99
7.2.2 TransmissionSegment Mapping	107
7.2.3 ProfileValue Mapping.....	109
7.2.4 AccountRequest Mapping	111
7.3 Device Outage Mapping	111
7.4 Information Buffer Mapping.....	115
7.5 Power Plant Mapping.....	115
7.5.1 Availability Report Mapping.....	115
7.5.2 Real Time Status Mapping.....	121
7.5.3 Forecast Mapping.....	127
7.5.4 Curve Mapping.....	129
8 Use of supervisory control objects	131
8.1 Use of IndicationPoint Model.....	131
8.2 Use of ControlPoint Model	133
8.3 Device Outage Usage.....	133
8.4 Information Buffer Usage	133
8.5 Power Plant Usage	133
9 Conformance.....	133
Annex A – Transfer account examples.....	137

INTERNATIONAL ELECTROTECHNICAL COMMISSION

TELECONTROL EQUIPMENT AND SYSTEMS –

**Part 6: Telecontrol protocols compatible with ISO standards
and ITU-T recommendations –
Section 802: TASE.2 Object models**

FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60870-6-802 has been prepared by IEC technical committee 57: Power system control and associated communications.

The text of this standard is based on the following documents:

FDIS	Report on voting
57/314/FDIS	57/328/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

Annex A is for information only.

INTRODUCTION

The primary purpose of Telecontrol Application Service Element (TASE.2) is to transfer data between control systems and to initiate control actions. Data is represented by object instances. This section of IEC 60870-6 proposes object models from which to define object instances. The object models represent objects for transfer. The local system may not maintain a copy of every attribute of an object instance.

The object models presented herein are specific to "control centre" or "utility" operations and applications; objects required to implement the TASE.2 protocol and services are found in IEC 60870-6-503. Since needs will vary, the object models presented here provide only a base; extensions or additional models may be necessary for two systems to exchange data not defined within this standard.

It is by definition that the attribute values (i.e. data) are managed by the owner (i.e. source) of an object instance. The method of acquiring the values are implementation dependent; therefore accuracy is a local matter.

The notation of the object modelling used for the objects specified in clause 5 is defined in IEC 60870-6-503. It should be noted that this section of IEC 60870-6 is based on the TASE.2 services and protocol. To understand the modelling and semantics of this standard, some basic knowledge of IEC 60870-6-503 is recommended.

Clause 5 describes the control centre-specific object models and their application. They are intended to provide information to explain the function of the data.

Clause 6 defines a set of MMS type descriptions for use in exchanging the values of instances of the defined object models. It is important to note that not all attributes of the object models are mapped to types. Some attributes are described simply to define the processing required by the owner of the data and are never exchanged between control centers. Other attributes are used to determine the specific types of MMS variables used for the mapping, and therefore do not appear as exchanged values themselves. A single object model may also be mapped onto several distinct MMS variables, based on the type of access and the TASE.2 services required.

Clause 7 describes the mapping of instances of each object type MMS variables and named variable lists for implementing the exchange.

Clause 8 describes device-specific codes and semantics to be used with the general objects.

An informative annex is included which describes some typical interchange scheduling scenarios, along with the use of TASE.2 objects to implement the schedule exchange.

TELECONTROL EQUIPMENT AND SYSTEMS –

Part 6: Telecontrol protocols compatible with ISO standards and ITU-T recommendations – Section 802: TASE.2 Object models

1 Scope

This section of IEC 60870-6 specifies a method of exchanging time-critical control centre data through wide- and local-area networks using a full ISO compliant protocol stack. It contains provisions for supporting both centralized and distributed architectures. The standard includes the exchange of real-time data indications, control operations, time series data, scheduling and accounting information, remote program control and event notification.

2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this section of IEC 60870-6. At the time of publication, the editions indicated were valid. All normative documents are subject to revision, and parties to agreements based on this section of IEC 60870-6 are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

IEC 60870-5-101: 1995, *Telecontrol equipment and systems – Part 5: Transmission protocols – Section 101: Companion standard for basic telecontrol tasks*

IEC 60870-6-503: 1997, *Telecontrol equipment and systems – Part 6: Telecontrol protocols compatible with ISO standards and ITU-T recommendations – Section 503: TASE.2 Services and protocol*

ISO/IEC 9506-1: 1990, *Industrial automation systems – Manufacturing message specification – Part 1: Service definition*

ISO/IEC 9506-2: 1990, *Industrial automation systems – Manufacturing message specification – Part 2: Protocol specification*

3 Definitions

For the purpose of this standard, the definitions in the above referenced standards apply.

4 Abbreviations

For the purpose of this standard, all the abbreviations defined in the above referenced standards apply.

5 Object models

Object models are required for various functions within a system. This clause delineates abstract object models based on functionality. Object models within one functional area may be used in another functional area.

5.1 Supervisory Control and Data Acquisition

The object models in this clause are derived from the historical perspective of Supervisory Control and Data Acquisition (SCADA) systems. The following text presents the context within which the object models are defined.

Fundamental to SCADA systems are two key functions: control and indication. The control function is associated with the output of data whereas the indication function is associated with the input of data. A more recent concept that is finding usage is the control and indication function where data output may also be input (i.e. bi-directional).

The previous identified functions within SCADA systems are mapped to point equipment (point). The primary attribute of a point is the data value. SCADA systems define three types of data for points: analog, digital and state.

The association of one or more points together is used to represent devices. For example, a breaker device may be represented by a control point and an indication point. The control point represents the new state that one desires for the breaker device. The indication point represents the current state of the breaker device. For SCADA to SCADA data exchange (e.g. control centre to control centre, control centre to SCADA master etc.), additional data is often associated with point data. Quality of point data is often exchanged to defined whether the data is valid or not. In addition, for data that may be updated from alternate sources, quality often identifies the alternate source. Select-Before-Operate control is associated with Control Points for momentary inhibiting access except from one source. Two other informative data values are: time stamp and change of value counter. The time stamp, when available, details when a data value last changed. The change of value counter, when available, details the number of changes to the value.

From the context presented, the primary object models required are: Indication Point, and Control Point. The attributes Point Value, Quality, Select-Before-Operate, Time Stamp, and Change of Value Counter are required to meet the desired functionality for data exchange. The Indication Point and Control Point models may be logically combined to a single model to represent a device which implements a control function with a status indication as to its success/failure. The combined logical model will result in the same logical attributes, and map onto the same MMS types as the independent models.

5.1.1 IndicationPoint Object

An IndicationPoint object represents an actual input point.

Object: **IndicationPoint** (Read Only)

Key Attribute: PointName

Attribute: PointType (REAL, STATE, DISCRETE)

Constraint PointType=REAL

Attribute: PointRealValue

Constraint PointType=STATE

Attribute: PointStateValue

Constraint PointType=DISCRETE

Attribute: PointDiscreteValue

Attribute: QualityClass: (QUALITY, NOQUALITY)

Constraint: QualityClass = QUALITY

Attribute: Validity (VALID, HELD, SUSPECT, NOTVALID)

Attribute: CurrentSource (TELEMETERED, CALCULATED, ENTERED, ESTIMATED)

Attribute: NormalSource (TELEMETERED, CALCULATED, ENTERED, ESTIMATED)

Attribute: NormalValue (NORMAL, ABNORMAL)

Attribute: TimeStampClass: (TIMESTAMP, NOTTIMESTAMP)

Constraint: TimeStampClass = TIMESTAMP

Attribute: TimeStamp

Attribute: TimeStampQuality: (VALID, INVALID)

Attribute: COVClass: (COV, NOCOV)

Constraint: COVClass = COV

Attribute: COVCounter

iTeh STANDARD PREVIEW

PointName

(standards.iteh.ai)

The PointName attribute uniquely identifies the object.

[SIST EN 60870-6-802:2000](https://standards.iteh.ai/catalog/standards/sist/1d5d258c-3833-498d-83ac-9ad3790378c1/sist-en-60870-6-802-2000)

PointType

The PointType attribute identifies the type of input point, and must be one of the following: REAL, STATE, DISCRETE.

PointRealValue

The current value of the IndicationPoint, if the PointType attribute is REAL.

PointStateValue

The current value of the IndicationPoint, if the PointType attribute is STATE.

PointDiscreteValue

The current value of the IndicationPoint, if the PointType attribute is DISCRETE.

QualityClass

The QualityClass has the value QUALITY if the object instance has any of the quality attributes (Validity, CurrentSource, or NormalValue), and takes the value NOQUALITY if none of the attributes are present.

Validity

The Validity attribute specifies the validity or quality of the PointValue data it is associated with. These are based on the source system's interpretation as follows:

Validity	Description
VALID	Data value is valid.
HELD	Previous data value has been held over. Interpretation is local.
SUSPECT	Data value is questionable. Interpretation is local.
NOTVALID	Data value is not valid.

CurrentSource

The CurrentSource attribute specifies the current source of the PointValue data it is associated with as follows:

CurrentSource	Description
TELEMETERED	The data value was received from a telemetered site.
CALCULATED	The data value was calculated based on other data values.
ENTERED	The data value was entered manually.
ESTIMATED	The data value was estimated. (State Estimator, etc.)

NormalSource

The NormalSource attribute specifies the normal source of the PointValue data it is associated with as follows:

NormalSource	Description
TELEMETERED	The data value is normally received from a telemetered site.
CALCULATED	The data value is normally calculated based on other data values.
ENTERED	The data value is normally entered manually.
ESTIMATED	The data value is normally estimated. (State Estimator, etc.)

NormalValue

The NormalValue attribute reports whether value of the PointValue attribute is normal. Only one bit is set, it is defined as follows:

NormalValue	Description
NORMAL	The point value is that which has been configured as normal for the point.
ABNORMAL	The point value is not that which has been configured as normal for the point.

TimeStampClass

The TimeStampClass attribute has the value TIMESTAMP if the IndicationPoint is time stamped, and has the value NOTTIMESTAMP if the IndicationPoint contains no TimeStamp attribute.

TimeStamp

The TimeStamp attribute provides a time stamp of when the value (attribute PointRealValue, PointStateValue or PointDiscreteValue) of the IndicationPoint was last changed. It is set at the earliest possible time after collection of the IndicationPoint value from the end device.