

SLOVENSKI STANDARD
SIST EN 61008-2-1:1996/A11:1999
01-april-1999

Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's) - Part 2-1: Applicability of the general rules to RCCB's functionally independent of line voltage - Amendment A11

Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's) -- Part 2-1: Applicability of the general rules to RCCB's functionally independent of line voltage

iTeh STANDARD PREVIEW

Fehlerstrom-/Differenzstrom-Schutzschalter ohne eingebauten Überstromschutz für Hausinstallationen und für ähnliche Anwendungen -- Teil 2-1: Anwendung der allgemeinen Anforderungen auf netzspannungs-unabhängige RCCB

[SIST EN 61008-2-1:1996/A11:1999](https://standards.iteh.ai/catalog/standards/sist/d7929fa5-7850-450b-9a45-88204d11e1c6/sist-en-61008-2-1:1996/a11:1999)

<https://standards.iteh.ai/catalog/standards/sist/d7929fa5-7850-450b-9a45-88204d11e1c6/sist-en-61008-2-1:1996/a11:1999>

Interrupteurs automatiques à courant différentiel résiduel pour usages domestiques et analogues sans dispositif de protection contre les surintensités incorporé (ID) -- Partie 2-1: Applicabilité des règles générales aux ID fonctionnellement indépendants de la tension d'alimentation

Ta slovenski standard je istoveten z: EN 61008-2-1:1994/A11:1998

ICS:

29.120.50	Varovalke in druga medtokovna zaščita	Fuses and other overcurrent protection devices
-----------	---------------------------------------	--

SIST EN 61008-2-1:1996/A11:1999 en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 61008-2-1:1996/A11:1999

<https://standards.iteh.ai/catalog/standards/sist/d7929fa5-7850-450b-9a45-687cd74d6eff/sist-en-61008-2-1-1996-a11-1999>

EUROPEAN STANDARD
 NORME EUROPÉENNE
 EUROPÄISCHE NORM

EN 61008-2-1/A11

April 1998

ICS 29.120.50
 UDC 621.316.57:621.316.9:620.1

Descriptors: Electrical household accessory, low-voltage equipment, residual current operated switching device, definition, characteristics, construction, tests

English version

**Residual current operated circuit-breakers without integral
 overcurrent protection for household and similar uses (RCCB's)
 Part 2-1: Applicability of the general rules to RCCB's
 functionally independent of line voltage**

Interrupteurs automatiques à courant
 différentiel résiduel pour usages
 domestiques et analogues sans
 dispositif de protection contre les
 surintensités incorporé (ID)
 Partie 2-1: Applicabilité des règles
 générales aux ID fonctionnellement
 indépendants de la tension
 d'alimentation

Fehlerstrom-/Differenzstrom-
 Schutzschalter ohne eingebauten
 Überstromschutz für Hausinstallationen
 und für ähnliche Anwendungen
 Teil 2-1: Anwendung der allgemeinen
 Anforderungen auf netzspannungs-
 unabhängige RCCB

This amendment A11 modifies the European Standard EN 61008-2-1:1994; it was approved by CENELEC on 1998-04-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this amendment the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This amendment exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
 Comité Européen de Normalisation Electrotechnique
 Europäisches Komitee für Elektrotechnische Normung
 Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

This amendment was prepared by the Technical Committee CENELEC TC 23E, Circuit breakers and similar devices for household and similar applications.

The text of the draft was submitted to the Unique Acceptance Procedure and was approved by CENELEC as amendment A11 to EN 61008-2-1:1994 on 1998-04-01.

The following dates were fixed:

- latest date by which the amendment has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 1998-11-01
- latest date by which the national standards conflicting with the amendment have to be withdrawn (dow) 2003-03-01

9 Tests

9.23 Add after the 1st paragraph:

In case there are no electronic components connected between phase poles and/or between phase poles and the neutral pole, the RCCB is loaded with rated current at any convenient voltage.

[SIST EN 61008-2-1:1996/A11:1999](https://standards.iteh.ai/catalog/standards/sist/d7929fa5-7850-450b-9a45-687cd74d6eff/sist-en-61008-2-1-1996-a11-1999)

<https://standards.iteh.ai/catalog/standards/sist/d7929fa5-7850-450b-9a45-687cd74d6eff/sist-en-61008-2-1-1996-a11-1999>