

INTERNATIONAL STANDARD

**Industrial communication networks – Fieldbus specifications –
Part 6-24: Application layer protocol specification – Type 24 elements**

IEC 61158-6-24:2023

<https://standards.iteh.ai/catalog/standards/sist/7b02b105-fe59-4e54-8642-c3b6a68bdcb9/iec-61158-6-24-2023>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2023 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

[IEC 61158-6-24:2023](https://standards.iteh.ai/catalog/standards/sist/7b02b105-1e59-4e54-8642-c3b6a68bdeb9/iec-61158-6-24-2023)

<https://standards.iteh.ai/catalog/standards/sist/7b02b105-1e59-4e54-8642-c3b6a68bdeb9/iec-61158-6-24-2023>



IEC 61158-6-24

Edition 2.0 2023-03

INTERNATIONAL STANDARD

**Industrial communication networks – Fieldbus specifications –
Part 6-24: Application layer protocol specification – Type 24 elements**

[IEC 61158-6-24:2023](https://standards.iteh.ai/catalog/standards/sist/7b02b105-fe59-4e54-8642-c3b6a68bdcb9/iec-61158-6-24-2023)

<https://standards.iteh.ai/catalog/standards/sist/7b02b105-fe59-4e54-8642-c3b6a68bdcb9/iec-61158-6-24-2023>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 25.040.40; 35.100.70; 35.110

ISBN 978-2-8322-6642-7

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
1.1 General.....	9
1.2 Specifications	9
1.3 Conformance	10
2 Normative references	10
3 Terms, definitions, symbols, abbreviated terms, and conventions	10
3.1 Referenced terms and definitions.....	10
3.1.1 Terms and definitions from ISO/IEC 7498-1	11
3.1.2 Terms and definitions from ISO/IEC 9545	11
3.1.3 Terms and definitions from ISO/IEC 8824-1	11
3.1.4 Terms and definitions from ISO/IEC 10731	11
3.1.5 Terms and definitions from ISO/IEC 19501	12
3.2 Additional terms and definitions	12
3.3 Abbreviations and symbols	17
3.4 Conventions.....	19
3.4.1 General conventions.....	19
3.4.2 PDU data type conventions.....	19
3.4.3 State machine conventions.....	19
4 Abstract syntax.....	22
4.1 Basic Data types.....	22
4.2 FAL PDU types	23
4.2.1 Top of APDU types: _APDU.....	23
4.2.2 PDUs for field device control service	24
4.2.3 PDUs for message service.....	37
4.3 Detailed definitions of _FDCService-PDUs.....	38
4.3.1 Short PDU type.....	38
4.3.2 Long PDU type	45
4.3.3 Enhanced PDU type	48
4.3.4 SubCommand PDU type	58
4.3.5 Short PDU type II.....	59
4.4 Device profile.....	66
5 Transfer syntax.....	66
5.1 Concepts	66
5.2 Encode rules.....	66
5.2.1 INTEGER and its subtypes	66
5.2.2 REAL type and its subtypes	68
5.2.3 BIT STRING type.....	69
5.2.4 OCTET STRING type and IA5String type.....	70
5.2.5 NULL type	71
5.2.6 Structure type and Array type	71
6 Structure of FAL protocol state machine	71
7 AP-context state machine (APC SM)	73
7.1 Overview.....	73
7.2 State descriptions	74

7.3	Triggering events	75
7.4	Action descriptions at state transitions	75
8	FAL service protocol machines (FSPM)	77
8.1	Overview.....	77
8.2	Field Device Control Protocol Machine (FDC PM)	77
8.2.1	Protocol overview	77
8.2.2	Cyclic communication mode.....	78
8.2.3	Event driven communication mode	82
8.2.4	Master Protocol Machine (FDCPM-M).....	83
8.2.5	Slave Protocol Machine (FDCPM-S)	92
8.2.6	Monitor Protocol Machine (FDCPM-MN)	102
8.2.7	Error procedure summary	104
8.3	Message Protocol Machine (MSGPM).....	106
8.3.1	Protocol overview	106
8.3.2	Requester Protocol Machine (MSGPM-RQ)	108
8.3.3	Responder Protocol Machine (MSGPM-RS).....	111
9	Application relationship protocol machine (ARPM).....	113
9.1	General.....	113
9.2	ARPM for FDC ASE	114
9.2.1	Overview	114
9.2.2	ARPM for FDC Master (ARPM-FDCM)	116
9.2.3	ARPM for FDC Slave (ARPM-FDCS)	122
9.2.4	ARPM for FDC Monitor (ARPM-FDCMN).....	129
9.3	ARPM for MSG ASE (ARPM-MSG)	131
9.3.1	State descriptions	131
9.3.2	Triggering events.....	132
9.3.3	Action descriptions at state transitions.....	133
10	DLL mapping protocol machine (DMPM).....	134
	Annex A (informative) Device profile and FDC command sets	135
	Annex B (normative) Virtual memory space and Device Information	137
	B.1 Overview.....	137
	B.2 Device Information.....	137
	B.2.1 Device identifier area structure	137
	B.2.2 Detail specifications of device IDs	138
	Annex C (informative) Basic message function	144
	Bibliography.....	145
	Figure 1 – Tree structure of APDU types.....	24
	Figure 2 – Encode of Integer subtypes	67
	Figure 3 – Example of transfer of INTEGER value	67
	Figure 4 – Encode of Unsigned subtypes	68
	Figure 5 – <i>Float</i> ₃₂ type encode.....	68
	Figure 6 – <i>Float</i> ₆₄ type encode.....	69
	Figure 7 – Bit field definition example with named bits	70
	Figure 8 – Bit field definition example with field size	70
	Figure 9 – SEQUENCE type encode	71

Figure 10 – Structure of FAL protocol state machines	73
Figure 11 – Statechart diagram of APCSM.....	74
Figure 12 – Example communication cycle of FDC master AP.....	79
Figure 13 – Example communication cycle of FDC slave AP	79
Figure 14 – Synchronous command communication in sync state	80
Figure 15 – Asynchronous command communication in sync state.....	81
Figure 16 – Asynchronous command communication in async state.....	82
Figure 17 – Event-driven communication	83
Figure 18 – Statechart diagram of FDCPM-M.....	84
Figure 19 – Statechart diagram of FDCPM-S	93
Figure 20 – Statechart diagram of FDCPM-MN	102
Figure 21 – PDU transmission flow for user message	107
Figure 22 – PDU transmission flow for one-way message	108
Figure 23 – Statechart diagram of MSGPM-RQ.....	109
Figure 24 – Statechart diagram of MSGPM-RS	111
Figure 25 – Example of single transfer process.....	114
Figure 26 – Example of dual transfer process	114
Figure 27 – Example of Synchronous command communication.....	115
Figure 28 – Timing chart for individual communication cycle setting.....	116
Figure 29 – Statechart diagram of ARPM-FDCM	117
Figure 30 – Statechart diagram of ARPM-FDCS.....	123
Figure 31 – Statechart diagram of ARPM-FDCMN.....	129
Figure 32 – Statechart diagram of ARPM-MSG	132
Figure B.1 – Memory map of virtual memory space	137
Figure B.2 – Memory map of device ID area	138
Table 1 – State transition descriptions	20
Table 2 – Description of state machine elements	20
Table 3 – Conventions used in state machines	21
Table 4 – Mapping for Protocol State Machines	72
Table 5 – State descriptions of APC SM	74
Table 6 – Trigger event descriptions of APC SM	75
Table 7 – Transitions of APC SM	75
Table 8 – FDC protocol mode	77
Table 9 – State descriptions of FDCPM-M.....	84
Table 10 – Trigger event descriptions of FDCPM-M	86
Table 11 – Transitions of main SM of FDCPM-M.....	87
Table 12 – Transitions of submachine of FDCPM-M.....	89
Table 13 – State descriptions of FDCPM-S	93
Table 14 – Trigger event descriptions of FDCPM-S.....	94
Table 15 – Transitions of main SM of FDCPM-S	95
Table 16 – Transitions of submachine of FDCPM-S	97
Table 17 – State descriptions of FDCPM-MN	102

Table 18 – Trigger event descriptions of FDCPM-MN.....	103
Table 19 – Transitions of main SM of FDCPM-MN	103
Table 20 – Transitions of submachine of FDCPM-MN	104
Table 21 – State descriptions of MSGPM-RQ.....	109
Table 22 – Trigger event descriptions of MSGPM-RQ	110
Table 23 – Transitions of MSGPM-RQ	110
Table 24 – State descriptions of MSGPM-RS	112
Table 25 – Trigger event descriptions of MSGPM-RS.....	112
Table 26 – Transitions of MSGPM-RS.....	113
Table 27 – State descriptions of ARPM-FDCM.....	117
Table 28 – Trigger event descriptions of ARPM-FDCM	119
Table 29 – Transitions of main SM of ARPM-FDCM	120
Table 30 – Transitions of submachine of ARPM-FDCM	121
Table 31 – State descriptions of ARPM-FDCS	123
Table 32 – Trigger event descriptions of ARPM-FDCS	125
Table 33 – Transitions of main SM of ARPM-FDCS.....	126
Table 34 – Transitions of submachine of ARPM-FDCS.....	127
Table 35 – State descriptions of ARPM-FDCMN	129
Table 36 – Trigger event descriptions of ARPM-FDCMN	130
Table 37 – Transitions of main SM of ARPM-FDCMN.....	130
Table 38 – Transitions of submachine of ARPM-FDCMN.....	131
Table 39 – State descriptions of ARPM-MSG.....	132
Table 40 – Trigger event descriptions of ARPM-MSG.....	133
Table 41 – Transitions of ARPM-MSG.....	133
Table A.1 – Example of registered device profiles.....	135
Table A.2 – Example command list of the profile '00'H.....	136
Table B.1 – Specifications of device IDs	138
Table C.1 – Example of message command set.....	144

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
FIELDBUS SPECIFICATIONS –****Part 6-24: Application layer protocol specification –
Type 24 elements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in the IEC 61784-1 series and the IEC 61784-2 series.

IEC 61158-6-24 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation. It is an International Standard.

This second edition cancels and replaces the first edition published in 2014. This edition constitutes a technical revision.

The main changes with respect to the previous edition are listed below:

- addition of a new PDU type which called "Short PDU type II" in 4.2;
- update of Table 4;
- addition of examples of Synchronous Command communication in 9.2.1, Figure 27 and Figure 28.

The text of this International Standard is based on the following documents:

Draft	Report on voting
65C/1204/FDIS	65C/1245/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

This document is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the "three-layer" fieldbus reference model described in IEC 61158-1.

The application protocol provides the application service by making use of the services available from the data-link or other immediately lower layer. The primary aim of this document is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer application entities (AEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- as a guide for implementers and designers;
- for use in the testing and procurement of equipment;
- as part of an agreement for the admittance of systems into the open systems environment;
- as a refinement to the understanding of time-critical communications within OSI.

This document is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this document together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems can work together in any combination.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 61158-6-24:2023](#)

<https://standards.iteh.ai/catalog/standards/sist/7b02b105-fe59-4e54-8642-c3b6a68bdcb9/iec-61158-6-24-2023>

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 6-24: Application layer protocol specification – Type 24 elements

1 Scope

1.1 General

The Fieldbus Application Layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a "window between corresponding application programs".

This part of IEC 61158 provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 24 fieldbus. The term "time-critical" is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This document defines in an abstract way the externally visible behavior provided by the Type 24 fieldbus application layer in terms of

- the abstract syntax defining the application layer protocol data units conveyed between communicating application entities,
- the transfer syntax defining the application layer protocol data units conveyed between communicating application entities,
- the application context state machines defining the application service behavior visibly between communicating application entities, and
- the application relationship state machines defining the communication behavior visibly between communicating application entities.

The purpose of this document is to define the protocol provided to

- define the representation-on-wire of the service primitives defined in IEC 61158-5-24, and
- define the externally visible behavior associated with their transfer.

This document specifies the protocol of the Type 24 fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI Application Layer Structure (ISO/IEC 9545).

1.2 Specifications

The principal objective of this document is to specify the syntax and behavior of the application layer protocol that conveys the application layer services defined in IEC 61158-5-24.

A secondary objective is to provide migration paths from previously existing industrial communications protocols. It is this latter objective which gives rise to the diversity of protocols standardized in the IEC 61158-6 series.

1.3 Conformance

This document does not specify individual implementations or products, nor does it constrain the implementations of application layer entities within industrial automation systems.

Conformance is achieved through implementation of this application layer protocol specification.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE All parts of the IEC 61158 series, as well as the IEC 61784-1 series and the IEC 61784-2 series are maintained simultaneously. Cross-references to these documents within the text therefore refer to the editions as dated in this list of normative references.

IEC 61158-5-24:2023, *Industrial communication networks – Fieldbus specifications – Part 5-24: Application layer service definition – Type 24 elements*

ISO/IEC 646, *Information technology – ISO 7-bit coded character set for information interchange*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model – Part 1: The Basic Model*

ISO/IEC 9545, *Information technology – Open Systems Interconnection – Application Layer structure*

ISO/IEC 9899, *Information technology – Programming languages – C*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

ISO/IEC 19501:2005, *Information technology – Open Distributed Processing – Unified Modeling Language (UML) Version 1.4.2*

ISO/IEC/IEEE 60559:2020, *Information technology – Microprocessor Systems – Floating-Point arithmetic*

3 Terms, definitions, symbols, abbreviated terms, and conventions

For the purposes of this document, the following terms, definitions, symbols, abbreviated terms and conventions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1 Referenced terms and definitions

For the purposes of this document, the following terms, definitions, symbols, abbreviations and conventions apply.

3.1.1 Terms and definitions from ISO/IEC 7498-1

For the purposes of this document, the following terms as defined in ISO/IEC 7498-1 apply:

- a) abstract syntax;
- b) application-entity;
- c) application process;
- d) application protocol data unit;
- e) application-process-invocation;
- f) (N)-facility;
- g) (N)-function;
- h) peer-(N)-entities;
- i) presentation context;
- j) real system;
- k) transfer syntax.

3.1.2 Terms and definitions from ISO/IEC 9545

For the purposes of this document, the following terms as defined in ISO/IEC 9545 apply:

- a) application-association;
- b) application-context;
- c) application-entity-invocation;
- d) application-entity-type;
- e) application-service-element.

3.1.3 Terms and definitions from ISO/IEC 8824-1

For the purposes of this document, the following terms as defined in ISO/IEC 8824-1 apply:

- a) simple type;
- b) component;
- c) component type;
- d) integer type;
- e) bitstring type;
- f) octetstring type;
- g) null type;
- h) sequence type;
- i) sequence of type;
- j) choice type;
- k) IA5String type;
- l) encoding.

3.1.4 Terms and definitions from ISO/IEC 10731

For the purposes of this document, the following terms as defined in ISO/IEC 10731 apply:

- a) OSI-service-primitive; primitive;
- b) OSI-service-provider; provider;
- c) OSI-service-user; user.

3.1.5 Terms and definitions from ISO/IEC 19501

For the purposes of this document, the following terms as defined in ISO/IEC 19501 apply:

- a) event;
- b) state;
- c) state machine;
- d) substate;
- e) submachine;
- f) transition.

3.2 Additional terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.2.1

alarm

field device status to tell that the device has detected a fatal problem to be solved and cannot continue normal working, through the field device control (FDC) service of the Type 24 fieldbus

Note 1 to entry: Any alarm statuses are latched and need some operations to be cleared.

Note 2 to entry: Alarms are classified into three groups; communication alarms, illegal-command-related ones, and application specific ones. But concrete definitions are dependent on implementation of each field devices.

3.2.2

application process object

network representation of a specific aspect of an application process (AP), which is modelled as a network accessible object contained within an AP or within another APO

Note 1 to entry: Refer to IEC 61158-1, 9.3.4.

3.2.3

application process context

AP context

shared knowledge or a common set of rules, governing communication of FAL application entities (AEs) and describing the permissible collective communications behavior between the AEs that are party to a specific set of application relationships (ARs)

Note 1 to entry: Data within AP context can be specified by the user in advance, by the option selected while the user uses a field bus management (FSM) service to read out the facility of peer AP, by the automatic negotiation function that the FSM system handles, and so on. The method that is to be adopted depends on the specification of each implementation.

3.2.4

application process type

AP type

description of a classification of application processes (APs) in terms of a set of capabilities for FAL of the Type 24 fieldbus

Note 1 to entry: AP types are classified into three, C1 master AP, C2 master AP and slave AP, by their application roles in the fieldbus network.

3.2.5

async command

type of a command application protocol data unit (APDU) of the FDC service of the Type 24 FAL, which can be issued any time after the previous transaction without consideration of synchronization with the communication cycle

Note 1 to entry: Definitions, which command should be async one or not, are dependent on an application. They can be provided as a registered set of commands and responses or device profiles, see 4.4 and Annex A.

3.2.6**asynchronous communication**

state or a way of communication for the FDC service of the Type 24 FAL, in which a command can be issued any time after the previous transaction without consideration of synchronization with the communication cycle

Note 1 to entry: In this state, sync commands cannot be issued, but async commands can.

3.2.7**attribute**

information or parameter contained in variable portions of an object

Note 1 to entry: Typically, they provide status information or govern the operation of an object. Attributes also affect the behavior of an object.

3.2.8**C1 master**

AP type that has master facilities for the FDC service of the Type 24 FAL, or the device implementing that AP type

Note 1 to entry: Only one C1 master exists in a network of the Type 24 fieldbus.

3.2.9**C2 master**

AP type that has only monitor facilities for the FDC service but requester facilities for message (MSG) service of the Type 24 FAL, or the device implementing that AP type

Note 1 to entry: Less than two C2 masters can exist in a network of the Type 24 fieldbus.

3.2.10**command**

PDU issued by a requester or a master to make a responder or a slave execute some functions

3.2.11**communication**

process to exchange information in a formal manner between two or more devices, users, APs or entities

3.2.12**transfer**

process to convey a PDU from a sender to a receiver

3.2.13**transmission**

process to send out and propagate electrical signals or encoded data

3.2.14**communication cycle**

period of repetitive activities synchronized with the transmission cycle while the connection establishing for the FDC protocol of the Type 24 FAL

Note 1 to entry: Communication cycle can synchronize with the transmission cycle multiplied by a specified scaling factor.

3.2.15**connection**

context or logical binding under specific conditions for the FDC protocol between a master object and a slave object for the Type 24 FAL