

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial networks – Profiles –
Part 2-10: Additional real-time fieldbus profiles based on ISO/IEC/IEEE 8802-3 –
CPF 10**

**Réseaux industriels – Profils –
Partie 2-10: Profils de bus de terrain supplémentaires pour les réseaux en temps
réel fondés sur l'ISO/IEC/IEEE 8802-3 – CPF 10**



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2023 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch



IEC 61784-2-10

Edition 1.0 2023-03

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial networks – Profiles –
Part 2-10: Additional real-time fieldbus profiles based on ISO/IEC/IEEE 8802-3 –
CPF 10**

**Réseaux industriels – Profils –
Partie 2-10: Profils de bus de terrain supplémentaires pour les réseaux en
temps réel fondés sur l'ISO/IEC/IEEE 8802-3 – CPF 10**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 35.100.20; 35.240.50

ISBN 978-2-8322-6623-6

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references	6
3 Terms, definitions, abbreviated terms, acronyms, and conventions.....	7
3.1 Terms and definitions.....	7
3.2 Abbreviated terms and acronyms	8
3.3 Symbols.....	8
3.4 Conventions.....	9
4 CPF 10 (Vnet/IP) – RTE communication profiles.....	9
4.1 General overview	9
4.2 CP 10/1	10
4.2.1 Physical layer	10
4.2.2 Data link layer	10
4.2.3 Application layer.....	13
4.2.4 Performance indicator selection.....	14
Bibliography.....	20
Table 1 – CPF 10 symbols.....	9
Table 2 – OSI layers and CPF 10 layers	10
Table 3 – Overview of CPF 10 profile.....	10
Table 4 – CP 10/1: DLL service selection.....	11
Table 5 – CP 10/1: DLL protocol selection	12
Table 6 – Transport Layer Parameter selection.....	12
Table 7 – CP 10/1: AL service selection.....	14
Table 8 – CP 10/1: AL protocol selection	14
Table 9 – CP 10/1: PI overview.....	15
Table 10 – CP 10/1: PI dependency matrix	15
Table 11 – CP 10/1: Consistent set of PIs for the communication between two end-stations belonging to the same domain	18
Table 12 – CP 10/1: Consistent set of PIs for the communication between two end-stations belonging to different domains	18
Table 13 – CP 10/1: Consistent set of PIs for the communication between two end-stations belonging to the same domain with one lost frame	19
Table 14 – CP 10/1: Consistent set of PIs for the communication between two end-stations belonging to different domains with one lost frame.....	19

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL NETWORKS –
PROFILES –****Part 2-10: Additional real-time fieldbus profiles
based on ISO/IEC/IEEE 8802-3 –
CPF 10****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by their respective intellectual property right holders.

NOTE Combinations of protocol types are specified in the IEC 61784-1 series and the IEC 61784-2 series.

IEC 61784-2-10 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation. It is an International Standard.

This first edition, together with the other parts of the same series, cancels and replaces the fourth edition of IEC 61784-2 published in 2019. This first edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to IEC 61784-2:2019:

- a) split of the original IEC 61784-2 into several subparts, one subpart for the material of a generic nature, and one subpart for each Communication Profile Family specified in the original document.

The text of this International Standard is based on the following documents:

Draft	Report on voting
65C/1209/FDIS	65C/1237/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 61784-2 series, published under the general title *Industrial networks – Profiles – Part 2: Additional real-time fieldbus profiles based on ISO/IEC/IEEE 8802-3*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

The IEC 61784-2 series provides additional Communication Profiles (CP) to the existing Communication Profile Families (CPF) of the IEC 61784-1 series and additional CPFs with one or more CPs. These profiles meet the industrial automation market objective of identifying Real-Time Ethernet (RTE) communication networks coexisting with ISO/IEC/IEEE 8802-3 – commonly known as Ethernet. These RTE communication networks use provisions of ISO/IEC/IEEE 8802-3 for the lower communication stack layers and additionally provide more predictable and reliable real-time data transfer and means for support of precise synchronization of automation equipment.

More specifically, these profiles help to correctly state the compliance of RTE communication networks with ISO/IEC/IEEE 8802-3, and to avoid the spreading of divergent implementations.

Adoption of Ethernet technology for industrial communication between controllers and even for communication with field devices promotes the use of Internet technologies in the field area. This availability would be unacceptable if it causes the loss of features required in the field area for industrial communication automation networks, such as:

- real-time,
- synchronized actions between field devices like drives,
- efficient, frequent exchange of very small data records.

These new RTE profiles can take advantage of the improvements of Ethernet networks in terms of transmission bandwidth and network span.

Another implicit but essential requirement is that the typical Ethernet communication capabilities, as used in the office world, are fully retained, so that the software involved remains applicable.

<https://standards.iteh.ai/catalog/standards/sist/53359790-3088-4cc3-b319-88cc036df388/iec-61784-2-10-2023>
The market is in need of several network solutions, each with different performance characteristics and functional capabilities, matching the diverse application requirements. RTE performance indicators, whose values will be provided with RTE devices based on communication profiles specified in the IEC 61784-2 series, enable the user to match network devices with application-dependent performance requirements of an RTE network.

INDUSTRIAL NETWORKS – PROFILES –

Part 2-10: Additional real-time fieldbus profiles based on ISO/IEC/IEEE 8802-3 – CPF 10

1 Scope

This part of IEC 61784-2 defines Communication Profile Family 10 (CPF 10). CPF 10 specifies a Real-Time Ethernet (RTE) communication profile (CP) and related network components based on the IEC 61158 series (Type 17), ISO/IEC/IEEE 8802-3 and other standards.

For each RTE communication profile, this document also specifies the relevant RTE performance indicators and the dependencies between these RTE performance indicators.

NOTE 1 All CPs are based on standards or draft standards or International Standards published by the IEC or on standards or International Standards established by other standards bodies or open standards processes.

NOTE 2 The RTE communication profiles use ISO/IEC/IEEE 8802-3 communication networks and its related network components and in some cases amend those standards to obtain RTE features.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE All parts of the IEC 61158 series, as well as the IEC 61784-1 series and the IEC 61784-2 series, are maintained simultaneously. Cross-references to these documents within the text therefore refer to the editions as dated in this list of normative references.

IEC 61158 (all parts), *Industrial communication networks – Fieldbus specifications*

IEC 61158-3-17:2007, *Industrial communication networks – Fieldbus specifications – Part 3-17: Data-link layer service definition – Type 17 elements*

IEC 61158-4-17:2007, *Industrial communication networks – Fieldbus specifications – Part 4-17: Data-link layer protocol specification – Type 17 elements*

IEC 61158-5-17:2007, *Industrial communication networks – Fieldbus specifications – Part 5-17: Application layer service definition – Type 17 elements*

IEC 61158-6-17:2007, *Industrial communication networks – Fieldbus specifications – Part 6-17: Application layer protocol specification – Type 17 elements*

IEC 61784-2-0:2023, *Industrial networks – Profiles – Part 2-0: Additional real-time fieldbus profiles based on ISO/IEC/IEEE 8802-3 – General concepts and terminology*

ISO/IEC 8802-2, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 2: Logical link control*

ISO/IEC/IEEE 8802-3, *Telecommunications and exchange between information technology systems – Requirements for local and metropolitan area networks – Part 3: Standard for Ethernet*

IEEE Std 802-2014, *IEEE Standard for Local and Metropolitan Area Networks: Overview and Architecture*

IEEE Std 802.1AB-2016, *IEEE Standard for Local and metropolitan area networks – Station and Media Access Control Connectivity Discovery*

IEEE Std 802.1AS-2020, *IEEE Standard for Local and Metropolitan Area Networks – Timing and Synchronization for Time-Sensitive Applications*

IEEE Std 802.1Q-2018, *IEEE Standard for Local and Metropolitan Area Networks – Bridges and Bridged Networks*

IETF RFC 768, J. Postel, *User Datagram Protocol*, August 1980, available at <https://www.rfc-editor.org/info/rfc768> [viewed 2022-02-18]

IETF RFC 791, J. Postel, *Internet Protocol*, September 1981, available at <https://www.rfc-editor.org/info/rfc791> [viewed 2022-02-18]

IETF RFC 792, J. Postel, *Internet Control Message Protocol*, September 1981, available at <https://www.rfc-editor.org/info/rfc792> [viewed 2022-02-18]

IETF RFC 793, J. Postel, *Transmission Control Protocol*, September 1981, available at <https://www.rfc-editor.org/info/rfc793> [viewed 2022-02-18]

IETF RFC 2236, W. Fenner, *Internet Group Management Protocol, Version 2*, November 1997, available at <https://www.rfc-editor.org/info/rfc2236> [viewed 2022-02-18]

3 Terms, definitions, abbreviated terms, acronyms, and conventions

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61784-2-0, ISO/IEC/IEEE 8802-3, IEEE Std 802-2014, IEEE Std 802.1AB-2016, IEEE Std 802.1AS-2020, IEEE Std 802.1Q-2018 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1.1

domain

part of the network consisting of one or two subnetwork(s)

Note 1 to entry: Two subnetworks are required to compose a dual-redundant network, and each end-station in the domain is connected to both of the subnetworks.

3.1.2

router

intermediate equipment that connects two or more subnetworks using a network layer relay function

3.1.3 subnetwork

part of a network that does not contain any routers

Note 1 to entry: A subnetwork consists of end-stations, bridges and segments.

Note 2 to entry: Every end-station included in a subnetwork has the same IP network address.

3.2 Abbreviated terms and acronyms

For the purposes of this document, abbreviated terms and acronyms defined in IEC 61784-2-0 and the following apply.

CP	Communication Profile [according to IEC 61784-1-0]
CPF	Communication Profile Family [according to IEC 61784-1-0]
IANA	Internet Assigned Numbers Authority
ICMP	Internet Control Message Protocol (see IETF RFC 792)
IETF	Internet Engineering Task Force
IP	Internet Protocol (see IETF RFC 791)
IPv4	Internet Protocol version 4 (see IETF RFC 791)
LLDP	Link Layer Discovery Protocol (see IEEE Std 802.1AB-2016)
NoS	Number of Switches
PI	Performance indicator
RSTP	Rapid Spanning Tree Algorithm and Protocol (see IEEE Std 802.1Q-2018)
TCP	Transmission Control Protocol (see IETF RFC 793)
TOS	Type of Service
UDP	User Datagram Protocol (see IETF RFC 768)

3.3 Symbols

For the purposes of this document, symbols defined in IEC 61784-2-0 and Table 1 apply.

NOTE Definitions of symbols in this Subclause 3.3 do not use the italic font, as they are already identified as symbols.

Table 1 – CPF 10 symbols

Symbol	Definition	Unit
Cdly	Cable delay	µs
Clen	Cable length	m
Dlen	Length of the complete Ethernet frame	bit
DT	Delivery time	µs
DTlost1	Maximum delivery time with one lost frame for communication between two end-stations belonging to the same domain	µs
DTlost2	Maximum delivery time with one lost frame for communication between two end-stations belonging to different domains	µs
DTmax1	Maximum delivery time for communication between two end-stations belonging to the same domain	µs
DTmax2	Maximum delivery time for communication between two end-stations belonging to different domains	µs
NoS	Number of switches in path from sender to receiver	–
Spd	Switch delay under not congested condition	µs
STTr	Receiver stack transversal time including PhL, DLL and AP	µs
STTs	Sender stack transversal time including PhL, DLL and AP	µs
Trate	Transfer bit rate	Mbit/s

3.4 Conventions

For the purposes of this document, the conventions defined in IEC 61784-2-0 apply.

4 CPF 10 (Vnet/IP¹) – RTE communication profiles

4.1 General overview

Communication Profile Family 10 (CPF 10) defines communication profiles using the principles, methodology and model of ISO/IEC 7498-1. In addition, it also follows the three-layer basic fieldbus reference model described in IEC 61158-1.

The OSI model provides a layered approach to communication standards, whereby the layers can be developed and modified independently. CPF 10 is based on the three-layer structure, and each layer of OSI seven layers is mapped onto these three layers as follows.

Functions of the intermediate OSI layers, layers 5, 6 and 7, are consolidated into the Application layer.

Functions of the intermediate OSI layers, layers 2, 3 and 4, are consolidated into the data-link layer.

Likewise, some features common to users of the Fieldbus Application layer are provided to simplify user operation.

Table 2 shows the OSI layers, their functions and the equivalent layers in the CPF10 layer model.

¹ Vnet/IP is a trade name of Yokogawa Electric Corporation. This information is given for the convenience of users of this document and does not constitute an endorsement by IEC of the trademark holder or any of its products. Compliance with this profile does not require use of the trade name. Use of the trade name requires permission of the trade name holder.

Table 2 – OSI layers and CPF 10 layers

OSI layer	Function	CPF 10 layer
7 Application	Translates demands placed on the communication stack into a form understood by the lower layers and vice versa	Application
6 Presentation	Converts data to/from standardized network formats	
5 Session	Synchronizes and manages data	
4 Transport	Provides transparent reliable data transfer	Data-link
3 Network	Performs message routing	
2 Data-link	Controls access to the communication medium. Performs error detection	
1 Physical	Encodes/decodes signals for transmission/reception in a form appropriate to the communication medium. Specifies communication media characteristics	Physical

Table 3 shows an overview of the communication profile for CPF 10.

Table 3 – Overview of CPF 10 profile

Layer	Protocol
Application	IEC 61158-6-17
Transport	IETF RFC 768 and IEC 61158-4-17
Network	IETF RFC 791
Data-link	ISO/IEC 8802-2 and ISO/IEC/IEEE 8802-3
Physical	ISO/IEC/IEEE 8802-3

4.2 CP 10/1

4.2.1 Physical layer

ISO/IEC/IEEE 8802-3 shall be used.

4.2.2 Data link layer

4.2.2.1 MAC sublayer

ISO/IEC/IEEE 8802-3 shall be used.

4.2.2.2 LLC sublayer

ISO/IEC/IEEE 8802-3 shall be used.

4.2.2.3 Network sublayer

4.2.2.3.1 General

Internet standard IETF RFC 791 and its amendments and successors shall be used.

Internet standard IETF RFC 2236 shall be used to perform multicasting.

4.2.2.3.2 Unicast address

IPv4 class C private address scope shall be used. Each subnetwork of a domain has the respective IP network address as follows.

IP address for the interface connected to the primary network:

- 192.168.(Domain number).(Host address)

IP address for the interface connected to the secondary network:

- 192.168.128+(Domain number).(Host address)

Each node of a redundant station has a respective IP host address as follows.

- Host address: (Station number) × 2 or (Station number) × 2 + 1

4.2.2.3.3 Group address

IPv4 class D Organization-Local Scope shall be used as group addresses for multicasting. Both the primary network and the secondary network require two group addresses: one for multicasting to all stations in the domain, and another for multicasting to all stations in the multi-domain network.

To assign these group addresses to the stations, AD-HOC Block group address 224.0.23.33 may be used.

NOTE This group address is registered with the Internet Assigned Numbers Authority (IANA).

4.2.2.3.4 TOS

The following four TOS parameter values shall be used for the data-link service:

- time synchronization;
- high priority;
- low priority;
- general purpose.

4.2.2.4 Transport sublayer

4.2.2.4.1 Transport service selection

Internet standard IETF RFC 768 (UDP) and its amendments and successors, and the data-link layer specified in IEC 61158-3-17 and IEC 61158-4-17 shall be used.

UDP port number 5313 shall be used.

NOTE This UDP port number is registered with the Internet Assigned Numbers Authority (IANA).

Table 4 specifies the DLL service selection within IEC 61158-3-17.

Table 4 – CP 10/1: DLL service selection

Clause	Header	Presence	Constraints
1	Scope	YES	–
2	Normative references	YES	–
3	Definitions	YES	–
4	Overview of the data-link layer service	YES	–
5	DLSAP management service	YES	–
6	Connectionless-mode Data Link Service	YES	–
7	DL-management Service	YES	–