

**Electrical apparatus for explosive gas atmospheres –  
Part 1: Flameproof enclosures “d”**

**CORRIGENDUM 1**

Page 14

*In table 2, replace the first row regarding flanged joints with the following:*

Flanged joints <sup>1)</sup>	6	0,10	–	–	–
	9,5	0,10	0,10	–	–
	15,8	0,10	0,10	0,04	–
	25	0,10	0,10	0,04	0,04

Page 17

*In 6.3, replace the entire text regarding width of cemented joints with the following:*

The shortest path through a cemented joint from the inside to the outside of a flameproof enclosure of volume  $V$  shall be:

$\geq 3$ mm if	$V \leq 10 \text{ cm}^3$
$\geq 6$ mm if	$10 \text{ cm}^3 < V \leq 100 \text{ cm}^3$
$\geq 10$ mm if	$V > 100 \text{ cm}^3$

Page 36

*In 15.2.1.2, replace the text of the second dash as follows:*

- electrical apparatus of Group IIB:  $(6,5 \pm 0,5)$  % ethylene