

INTERNATIONAL ELECTROTECHNICAL COMMISSION
COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

IEC 60947-6-2
Edition 3.0 2020-12

IEC 60947-6-2
Édition 3.0 2020-12

**LOW-VOLTAGE SWITCHGEAR AND
CONTROLGEAR–**

**Part 6-2: Multiple function equipment – Control
and protective switching devices (or equipment)
(CPS)**

APPAREILLAGE À BASSE TENSION–

**Partie 6-2: Matériels à fonctions multiples –
Appareils (ou matériel) de connexion de
commande de protection (ACP)**

CORRIGENDUM 2

Corrections to the French version appear after the English text.

Les corrections à la version française sont données après le texte anglais.

[IEC 60947-6-2:2020/COR2:2023](https://standards.iteh.ai/catalog/standards/sist/20968e2d-2e43-4cbf-9134-d33a8fb3cecb/iec-60947-6-2-2020-cor2-2023)

9.5.4.3 Test at prospective conventional currents I_{cr} and I_r

Replace the existing first paragraph as follows:

A short-circuit test is made under the general conditions of 9.3.4.1 with the values of conventional prospective currents I_{cr} and I_r in accordance with 8.2.5 a).

9.5.5.3 Rated service short-circuit breaking capacity test at I_{cs}

Replace the existing first paragraph as follows:

A short-circuit test is made under the general conditions of 9.3.4.1 with a value of prospective current I_{cs} (see 5.3.6), as declared by the manufacturer.